

# Transit Bus Fleet Size

Utility Bus and Truck Working Council

Mark Kosowski  
Electric Transportation  
mkosowski@epri.com

White Plains, New York  
October 22, 2019




What happens when you get into big deployment of buses - how does the onsite infrastructure differ when you have a 100- bus depot versus a 10-bus depot?

# Manual Chargers

- With a small fleet of transit buses, all that is needed in the depot are manually-connected DC chargers
- Facilities may have enough excess power to provide for the needs of a small fleet
- Dedicated spaces for Buses with chargers are used
- Chargers can be floor-mounted, wall-mounted, or ceiling-mounted
- Cable management is required



# Schiphol Airport All-Electric Transit Bus Fleet



- 100 x 60-foot Transit Buses (VDL)
- 13 MW installed Power
- 84 x 30 kW Charging Hoods
- 23 x 450 kW Opportunity Charging Hoods
- 2 x 25 kW Mobile Chargers in the Workshop
- Two Outside Depots
- Five Opportunity Charging sites
- Full Operation with 24/7 Service

# Schiphol Depot 1 of 2




**Five Independent transformers for resilience**

**Forty Eight 30 kW Charge Hoods**


**Five 450 kW Charge Hoods**

**Total: ~4 MW**

# Schiphol Opportunity Charging 1



2 x > 900 kVA Transformers  
Independent for resilience



4 x 450 kW Chargers

Total: ~2 MW

# Proterra Rendering of a 60 kW Depot



# Together...Shaping the Future of Electricity



# Questions

Given a site, what is the available power at the site?

Should a depot site energy have its own meter and account instead of integrating the energy with the existing building?

What do you do for resilience?

What are the voltage levels for utility transformers?

Should DCaaS be deployed?

# Example- 100 Buses

	100 Bus Depot and On-route Charging			
	Cross Rail J-3105-1		Bus-Up J-3105-2	
	Automatic Depot Charging	Manual Depot Charging	Automatic Depot Charging	Manual Depot Charging
Incremental # of Passengers	1	1	Neutral	Neutral
# of Pantographs	80	10	80	10
Moving Parts on Bus	None	None	Yes	Yes
Moving Parts on Infrastructure	Yes	Yes	None	None
Affect of Breakdown of Pantograph	Few Buses	Many Buses	Few Buses	Many Buses




# J-3105 Sub-Document Definition



**J-3105-1**  
**Infrastructure-mounted Cross Rail Connection**




**J-3105-2**  
**Vehicle-mounted Pantograph Connection**



**J-3105-3**  
**Enclosed Pin and Socket Connection**

# Schiphol Airport, Amsterdam



Depot 1



On-Route Charging 1

On-Route Charging 2

Depot 2

# Eindhoven Opportunity Charging



**43 All-Electric Buses with Automatic Depot Charging Indoors**

**Heliox and VDL initial deployment**

**Heliox and VDL headquarters and manufacturing is near Eindhoven**

# Chile



285 All-electric Buses in Santiago, Chile

# Schiphol Opportunity Charging 1



UL Listed DC Chargers	
50 kW	\$62k
450 kW	\$333k

# Eindhoven Indoors Depot





# Schiphol Opportunity Charging 1



# Eindhoven Opportunity Charging Alignment



Operator aligns the yellow line on the bus floor with the white line on the street

# Eindhoven Opportunity Charging



On-route chargers are located at the depot and the Eindhoven Airport



A bumper on the pavement stops the bus for the alignment with the hood.

# Eindhoven Indoors Depot



Charger Cabinets are up off the floor to easily get the power in and out.

Power is routed in conduit to the ceiling and then to each charging hood

# Summary


- Before starting to plan, engage the proper city departments that have a stake in the program including the utility
- Plan the need for adequate electric capacity
- Locate the depot where there is a potential for electricity and decide indoors or outdoors
- Consider Automatic connections, manual connections can be made, but hanging cables will provide an untidy site and not provide smooth handling for the operators.
- Select the automated connection that best provides for your needs

# Backup


# Grand Avenue Depot Electrical Room and Panels



# Schiphol Airport, Amsterdam



**Depot**



**On-Route Charging**



# Electric Bus Fleet Demonstration and Data Collection

Sites can be field approved by Underwriters Laboratories (UL) or others. If the components for the site are not UL qualified, then UL can do a field approval of the site. UL comes to the site and performs the characteristic tests subscribed by the requirements.

Organizational entities were gathered for the NYC program including the New York City Transit (NYCT), Bridges and Tunnels, NY State Department of Transportation (NYDOT), New York City Department of Transportation (NYC DOT), Hudson River Park, New Flyer, Black and Veatch, and Ciocchini Design. Much coordination had to occur between departments. One large delay was having a plan from the NYDOT for traffic control during construction. Evidently, the requirements went back and forth between departments causing a sizable delay.

During the planning process, it is necessary to determine the designated dedicated parking spaces for the buses to be charged. Chargers can be overhead, on a nearby wall, or floor-mounted near each parking place. Chargers can be located between or near several buses for effective utilization. It is important to determine whether the operator/personnel plugs in the charger or an automated charging system is warranted.

The automated charging system could be the same system used on-route. Currently, there are three automated charging systems defined with a common set of requirements.

Consideration needs to be made regarding the power conduit. The conduit can be placed underground or overhead. The underground type is more esthetically pleasing but it cost more to either drill under the ground or dig up streets and lay asphalt or concrete over. The overhead version can more easily be put up but esthetically it is not as pleasing. If the system is automated and on public streets it may be wise to have a more esthetically pleasing system. If the chargers are in a depot, the conduit can be run on existing walls or overhead. The system is less expensive.

# Proterra Buses in Brooklyn


- 5 Proterra buses (440 kWh) capable of charging with two chargers at a time (100 kW)
- Blade On-Route\* Charging System (500 kW) at terminal near the Williamsburg Bridge in Brooklyn
- Six 50 kW DC Chargers (Tritium) located at the Grand Avenue Depot in Queens



\* Per Proterra, the Blade system has been eliminated from the SAE J3105 Recommended Practice


# Location for the Proterra Overhead Charger

Manhattan



Plan was for 2 routes (B32 and B39), however, multiple routes are being used as the need arises.

# Williamsburg Terminal Layout



# Proterra Bus at Williamsburg Terminal in Brooklyn



**400 V DC Charger**

# Manhattan Routes (M42 and M50) along 42nd Street- New Flyer




**West Side started in Charging in December 2018**  
**Pole is on Driver side**



**East Side started in Charging in January 2019**  
**Pole is on passenger side**

# Cross Section of a NYC Street

## Understand the Ground Below



# MJ Quill Depot- Manhattan

~280 buses at the MJ Quill Depot

5 New Flyer Electric buses are housed

15 more buses have been ordered and to be placed at Quill

Two 60 kW chargers (Siemens) and 8 more being added on the roof






# Operational Data


# Technology Differences Evaluated

## Slow Charge (50 to 100 kW)



- Charges at Depot
- Range of 10 hours
- ~ 4 to 7 hours to charge overnight
- Proterra


## Fast Charge (350 kW)



- Charges at Bus Layover
- Range of 3 hours
- ~ 10 minutes to charge
- New Flyer

# Sample New York City Routes: Manhattan

M42




- New Flyer buses
- MJ Quill depot on Manhattan
- NYCT is currently operating the buses conservatively

From Google Maps  
Approximately noon on Thurs 11/15/2018.

# Sample Routes: Brooklyn/Queens


- Proterra buses
- Grand Ave depot in Brooklyn
- NYCT has operated Proterra buses on all routes out of Grand Ave

## B39



From Google Maps  
Approximately noon on Thurs 11/15/2018.

## B32



# Driving Data Summary

	Number of Drive Events	Total Distance (miles)	Operating Time (hours)
New Flyer	7,083	23,000	6,716
Proterra	1,019*	32,347	3,780*
Total	<b>8,102</b>	<b>55,348</b>	<b>10,497</b>

New Flyer data from 2/1/2018 to 11/30/2018

Proterra data from 12/26/2017 to 11/28/2018

\* Proterra data does not include long dwells

- Many short New Flyer events
- Four Proterra buses have been out of service since mid-August. One other was in service until the end of November.
- Proterra data is missing long dwell periods

# Driving Data Summary

	Number of Drive Events	Total Distance (miles)	Operating Time (hours)	Overall Average Speed (mph)	Moving Average Speed (mph)
New Flyer	7,083	23,000	6,716	3.16	7.20
Proterra	1,019*	32,347	3,780*	8.89*	9.81
Total	<b>8,102</b>	<b>55,348</b>	<b>10,497</b>	<b>5.22</b>	<b>8.60</b>

New Flyer data from 2/1/2018 to 11/30/2018

Proterra data from 12/26/2017 to 11/28/2018

\* Proterra data does not include long dwells

# Driving Data Summary

	Number of Drive Events	Total Distance (miles)	Operating Time (hours)	Overall Average Speed (mph)	Moving Average Speed (mph)	Total Energy Consumed (kWh)	Energy Consumption (kWh/mi)
<b>New Flyer</b>	7,083	23,000	6,716	3.16	7.20	78,896	3.72
<b>Proterra</b>	1,019*	32,347	3,780*	8.89*	9.81	89,481*	2.66*
<b>Total</b>	<b>8,102</b>	<b>55,348</b>	<b>10,497</b>	<b>5.22</b>	<b>8.60</b>	<b>168,378</b>	<b>3.07</b>

New Flyer data from 2/1/2018 to 11/30/2018

Proterra data from 12/26/2017 to 11/28/2018

\* Proterra data does not include long dwells

# Charging Data Summary


	<b>Number of Depot Charge Events</b>	<b>Total Duration (hours)</b>	<b>Active Charging Time (hours)</b>
<b>New Flyer</b>	2,127	5,362	3,239
<b>Proterra</b>	1,118	4,047	2,284
<b>Total</b>	<b>3,245</b>	<b>9,409</b>	<b>5,523</b>

New Flyer data from 2/1/2018 to 11/30/2018

Proterra data from 12/26/2017 to 11/28/2018




# Example Battery SOC History: New Flyer Bus #11, 4/6/2018




- Daily totals:
- 28 miles
  - 130.8 kWh
  - 4.7 kWh/mile

■ Charge  
■ Drive

# Example Battery SOC History: New Flyer Bus #11, April 2018




# Example Battery SOC History: Proterra Bus #16, 6/22/2018




- Daily totals:
- 107.6 miles
  - 281.2 kWh
  - 2.6 kWh/mile

# Example Battery SOC History: Proterra Bus #16, June 2018



# Ambient Temperature Impact: New Flyer Fleet



# Lessons Learned

- The initial on-route charger set the template for the others
- Power at the on-route sites was:
  - Insufficient at the Williamsburg Terminal (New power was pulled and a new Transformer in a new Vault)
  - West Side had excess of 280 kW (Charge limited to 280 kW)
  - East Side had excess of 500 kW
- Establish stakeholders early and engage
  - DOTs, Landowners, Road Commissions, Designers, Fleet Managers, Facility personnel, etc.
- Consider Road conditions- Ramp angles, Crowns

# Summary

- Program started on time missing only 2 of the three on-route chargers (last 2 charging now)
- Buses have been collecting data since January 2018 (more than 55,000 miles and charging more than 170 MWh)
- Big Battery/ Slow Charge and Little Battery/ Fast Charge is being evaluated
- Data is being evaluated for performance, charging statistics, economics, etc.
- Need to determine how to electrify a bus depot for 100 or more buses in the future

# Electric School Bus Program Funding

Funding for this project is divided over the three-year life of the project.

## Site Hosts

Minimum of \$50,000/year (who already have or plan to deploy an electric school bus) = \$150,000 total. Additional scope may be added per the host.

## Collaborators

\$25,000/year for (who will not deploy an electric school bus) = \$75,000 total

Investigating lease options at additional cost

This project qualifies for tailored collaboration (TC) or self-directed funding (SDF).

If you are already hosting a school bus fleet, EPRI could assist with the data analysis, assist in steering the project, and provide technical information to collect. Comparison data would be available with environmental, performance, and route schedules. It would be reported in this supplemental report and the funders would also have the data results from the other hosts involved.





# Electric School Bus Program

- Supplement Still Available: HECO (host), NYPA, and NC Coop
- Hawaiian Electric one Type D Electric School bus will be placed into 3 different school districts over three years
  - Bus is currently being ordered
  - Plans are to begin on school route next school year (August 2019)
  - Data will be collected and analyzed
- This project will demonstrate and/or analyze:
  - the ability to adequately serve various driving distances, terrains, charging schedules, and school programs,
  - the ability batteries to provide grid services specifically supporting the integration of renewable generation,
  - the ability batteries to be charged at times other than during the system peak,
  - incentives and savings of TOU rate tariffs,
  - needs of charging infrastructure,
  - cost/benefits of operations.



**Electric School Bus programs are getting attention**

# Together...Shaping the Future of Electricity

# Backup

# 2017 Electric Transportation Supplemental Project Urban electric bus fleet demonstration and data collection

## Objective

- Identify what utilities can do to encourage electric bus adoption by identify and quantifying the key installation and operational issues for a fleet of electric buses
- Attempts to help answer:
  - What is required to deploy a fleet of plug-in electric buses?
  - What are the costs?
  - How can this scale?

## Value

- Supports utilities in developing and prioritizing plans to encourage electric bus adoption
- Increased grid utilization
- Lower environmental impact of transportation sector



## Price

- \$180k host/\$90k collaborator, qualifies for TC and SDF

## Contact



- Mark Kosowski  
[mkosowski@epri.com](mailto:mkosowski@epri.com)  
(248) 421-7124

# 2017 Electric Transportation Supplemental Project

## Urban electric bus fleet demonstration and data collection

1. Phase 1 (Design and implementation of Host 10 bus pilot)
  - a. Map out the technical requirements needed to charge up to 5 plug-in electric buses at a single depot
  - b. Assist host utilities in setting up bus depot charging for up to 5 buses
  - c. Assist host utilities in integrating depot charging into building energy management systems, if possible
  - d. Assist host utilities in in setting up on-route charging for up to 10 buses
  - e. Collect data on bus usage, performance, energy consumption, power, etc.
  - f. Collect financial data related to energy and power (energy as well as capacity charges), installation, operation and other costs
  - g. Map out a technical glide path for increasing number of buses within a facility
  - h. Identify load reduction opportunities to offset or minimize increased charger loads
  - i. Define facility characteristics compatible with lowest cost first adoption strategies
2. Phase 2 (100 bus pilot)
  - a. Repeat Phase 1 by modeling a use case of 100 buses
  - b. Provide an Excel Spreadsheet Calculator as a Planning Tool
3. Produce briefings and technical report of findings

# Road way dig up



Several Brooklyn streets had to be trenched about 1/3 mile to bury the required cable for 208 V AC power to the charging site





# MJ Quill Depot- 50 kW Chargers





# New York City Electric Transit Buses

Type	Mfg	Charging Power	# Buses	Location
Overhead/Depot	New Flyer	350 kW; 50 kW	5	NYC/Manhattan
Overhead/Depot	Proterra	500 kW; 50 kW	5	NYC/Brooklyn


- Background
  - In North America, ~51 fleets with 683+ electric buses on road by 2021
- Project overview and status
  - Depot and on-route charging are being evaluated along with battery sizing
  - NYC has 10 electric transit buses running in Manhattan and Brooklyn
  - Driven more than 55k miles since January 2018 (Proterra and New Flyer)
  - Installed 3 automated on-route chargers (350 kW and 500 kW) and 8 depot chargers (50 kW)
  - Data has being collected and analyzed
- Expect to complete the analysis and write report in Q2 2019 with learnings
  - Early coordination of departments and design is critical - (Transit Fleet, State DOT, City DOT, Parks, Bridges and Tunnels, etc.)



**Many Transit agencies are deploying**

# Together...Shaping the Future of Electricity

# Charging Equipment located near the sight




Two different enclosures with benches will be located on the street near the overhead charging unit. One shall contain the transformers and switch gear and the other will contain the DC Charger.

# Williamsburg Terminal in the Brooklyn



Tear up 1/3 mile of road way to get medium voltage to location



Install Vault for medium voltage to 208 V AC at site




Switch Gear

# Williamsburg Terminal in the Brooklyn



400 V DC Charger



# Williamsburg Terminal

Several Brooklyn streets had to be trenched about 1/3 mile to bury the required cable for 208 V AC power to the charging site

