

S5-GC(25-50)K

Solis Three Phase Grid-Tied Inverters

Efficient

- Max. efficiency 98.8%
- String current up to 16A
- 3/4 MPPT design, supports multiple orientation system design
- Night time PID recovery function, increases overall system yield (optional)
- Wide voltage range and low startup voltage

Smart

- Supports export power control
- Intelligent string monitoring, smart I-V curve scan
- Supports RS485, WiFi, GPRS
- Scan to register on SolisCloud, supports remote upgrade and control

Safe

- IP66
- AFCI protection, proactively reduces fire risk
- Globally recognised branded componentry for longer life
- Intelligent redundant fan-cooling

Economic

- Supports GPRS/WiFi communication with less wiring and reduced installation costs
- > 150% DC/AC ratio
- Supports high power modules for lower installation costs

Models:

S5-GC25K / S5-GC30K

S5-GC33K / S5-GC36K

S5-GC40K / S5-GC40K-HV

S5-GC50K-HV









DATASHEET

S5-GC(25-50)K

Models	25K	30K	33K	36K	40K	40K-HV	50K-HV
Input DC							
Recommended max. PV power	37.5 kW	45 kW	49.5 kW	54 kW	60 kW	60 kW	75 kW
Max. input voltage				1100 V			
Rated voltage				600 V			
Start-up voltage				180 V			
MPPT voltage range				200-1000 V			
Max. input current		32 A / 32 A / 32 A			4*32	2 A	
Max. short circuit current		40 A / 40 A / 40 A			4*40	D A	
MPPT number/Max. input strings number		3/6			4/	8	
Output AC							
Rated output power	25 kW	30 kW	33 kW	36 kW	40 kW	40 kW	50 kW
Max. apparent output power	27.5 kVA	33 kVA	36.3 kVA	39.6 kVA	44 kVA	44 kVA	55 kVA
Max. output power	27.5 kW	33 kW	36.3 kW	39.6 kW	44 kW	44 kW	55 kW
lated grid voltage			, 220 V / 380 V, 230 V				, 480 V
lated grid frequency		-1 1	, . , ,	50 Hz / 60 Hz		-, ,	
lated grid output current	38.0 A / 36.1 A	45.6 A / 43.3 A	50.1 A / 47.6 A	54.7 A / 52.0 A	60.8 A / 57.7 A	48.1 A	60.1 A
Max. output current	41.8 A	50.2 A	55.1 A	60.2 A	66.9 A	53.0 A	66.2 A
Power factor	12.071	55.271		(0.8 leading - 0.8 la		00.071	00.271
"HDi			- 0.33 (<3%	-00'''01		
Efficiency				-570			
Max. efficiency	QQ	.5%	98.6%	9.8	.7%	9.8	.8%
EU efficiency		.1%	98.2%		.3%		.4%
Protection	30	.170	36.270	30	.370	30.	.470
				Yes			
OC reverse-polarity protection							
Short circuit protection				Yes			
Output over current protection			2	Yes			
Surge protection			D	C Type II / AC Type	5 11		
Grid monitoring				Yes			
Anti-islanding protection				Yes			
Temperature protection				Yes			
Strings monitoring				Yes			
/V Curve scanning				Yes			
ntegrated AFCI (DC arc-fault circuit protection)				Yes (1)			
ntegrated PID recovery				Optional			
ntegrated DC switch				Optional			
General Data							
Dimensions (W*H*D)				647*629*252 mm			
Neight		38.2 kg			42.1	kg	
Topology				Transformerless			
Self-consumption (night)				<1 W			
Operating ambient temperature range				-25 ~ +60°C			
Relative humidity				0-100%			
ngress protection				IP66			
Cooling concept			Intellige	ent redundant fan	-cooling		
Max. operation altitude				4000 m			
Grid connection standard					15 / VFR:2019, RD 10 2116, IEC 61727, IEC		
Safety/EMC standard			IEC/EN 62109	-1/-2, IEC/EN 6100	00-6-1/-2/-3/-4		
eatures							
OC connection				MC4 connector			
AC connection				OT terminal			
Display				LCD			
Communication			RS48	5, Optional: Wi-Fi,	GPRS		



of Conformity Low Voltage Directive 2014/35/EU

Registration No.:

AN 50519833 0001

Report No.:

50263108 010

Holder:

Ginlong technologies Co., Ltd.

No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: S5-GC25K S5-GC30K S5-GC33K S5-GC36K

\$5-GC40K \$5-GC40K-HV \$5-GC50K-HV \$5-GC15K-LV \$5-GC20K-LV \$5-GC23K-LV \$5-GC25K-AU \$5-GC30K-AU \$5-GC33K-AU \$5-GC36K-AU \$5-GC40K-AU \$5-GC40K-HV-AU

S5-GC50K-HV-AU

Continued on page 0002

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date <u>26.09.2021</u>

A. Chen

Certification Body

TÜVRheinland

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

(E The CE marking may be used if all relevant and effective EC Directives are complied with.

CE





of Conformity Low Voltage Directive 2014/35/EU

Registration No.:

AN 50519833 0002

Report No.:

50263108 010

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Serial Number

: Engineering Sample

Remark(s)

: Issued in conjunction with TÜV Rheinland

license R 50518312 0001-0006.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 26.09.2021

A. Chen

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

(The CE marking may be used if all relevant and effective EC Directives are complied with.

CE

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Zhang Kun

Date : 27.09.2021 Our ref. : Kese 01 Your ref.: Zhang kun

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AN 50519833 0001 : 50263108 010 Report No.

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Enclosure

Tel: (8610)8524 2222 Fax: (8610)8524 2200 e-mail: info@bj.chn.tuv.com Internet: http://www.chn.tuv.com



of Conformity

Registration No.:

AK 50522088 0001

Report No .:

50281041 007

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: Solis-aaK-5G (aa=25,30,33,36,40)

Solis-bbK-HV-5G (bb=40,50) Solis-ccK-LV-5G (cc=15,20,23) S5-GCxxK (xx=25,30,33,36,40) S5-GCyyK-HV (yy=40,50) S5-GCzzK-LV (zz=15,20,23)

Serial Number : Engineering Samples

Firmware version : V31

Remark(s) : Refer to report 50281041 007 for details.

Tested acc. to:

IEC 61727:2004 IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date

22.10.2021

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Certification



S5-GC(50-60)K

Solis Three Phase Inverters

Efficient

- Max. efficiency 98.7%
- String current up to 16A
- 5/6 MPPT design, supports multiple orientation system design
- Night time PID recovery function, increases overall system yield (optional)

Smart

- Night SVG function
- Supports export power control
- Intelligent string monitoring, smart I-V curve scan
- Scan to register on SolisCloud, supports remote upgrade and control

Safe

- IP66, C5 Anti-Corrosion Level
- Intelligent redundant fan-cooling
- Globally recognised branded componentry for longer life
- AFCI protection, proactively reduces fire risk

Economic

- Supports GPRS/WiFi communication with less wiring and reduced installation costs
- DC side supports "Y" connector
- 10/12 string inputs allow for 150%+ DC oversizing





DATASHEET S5-GC(50-60)K

Models	50K	60K				
Input DC						
Max. input voltage	110	0 V				
Rated voltage	600 V					
Start-up voltage	19:	5 V				
MPPT voltage range	180-1	000 V				
Max. input current	5*32 A	6*32 A				
Max. short circuit current	5*40 A	6*40 A				
MPPT number/Max. input strings number	5/10	6/12				
Output AC						
Rated output power	50 kW	60 kW				
Max. apparent output power	55 kVA	66 kVA				
Max. output power	55 kW	66 kW				
Rated grid voltage	3/N/PE, 220 V / 38					
Rated grid frequency	50 Hz /					
Rated grid output current	76.0 A / 72.2 A	91.2 A / 86.6 A				
Max. output current	83.6 A	100.3 A				
Power factor	>0.99 (0.8 leadin					
THDi	- 0.55 (0.0 teadii - 3					
Efficiency	~	70				
Max. efficiency	00	707				
•	98.7% 98.3%					
EU efficiency	30.	570				
Protection	V					
DC reverse-polarity protection	Yes Yes					
Short circuit protection						
Output over current protection	Yes					
Surge protection	DC Type II / AC Type II					
Grid monitoring	Yes					
Anti-islanding protection	Ye					
Temperature protection	Ye					
Strings monitoring	Ye					
I/V Curve scanning	Ye					
Integrated AFCI (DC arc-fault circuit protection)		25 (1)				
Integrated PID recovery	Optional ⁽²⁾					
Integrated DC switch	Opti	onal				
General Data						
Dimensions (W*H*D)	691*5783					
Weight	54.5					
Topology	Transfor	merless				
Self-consumption (night)	<1	W				
Operating ambient temperature range	-25 ~ ·	+60°C				
Relative humidity	0-10	00%				
Ingress protection	IP					
Cooling concept	Intelligent redun	dant fan-cooling				
Max. operation altitude	400	0 m				
Grid connection standard	G99, VDE-AR-N 4105 / VDE V 0124, EN 50549-1, VDE 0126 / UTE C 15 / VFR:2019, RD 1699 / RD 244 / UNE 206006 / UNE 206007-1, CEI 0-21, C10/11, NRS 097-2-1, EIFS 2018.2, IEC 62116, IEC 61727, IEC60068, IEC 61683, EN 50530					
Safety/EMC standard	IEC 62109-1/-2, IEC62116	& IEC 61000-6-1/-2/-3/-4				
Features						
DC connection	MC4 cor	nnector				
AC connection	OT terminal (ı	max. 70 mm²)				
Display	LCD, Capacitive	touch buttons				
Communication	RS485, USB, Opti	onal: Wi-Fi, GPRS				



of Conformity Low Voltage Directive 2014/35/EU

Registration No.:

AN 50519833 0001

Report No.:

50263108 010

Holder:

Ginlong technologies Co., Ltd.

No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: S5-GC25K S5-GC30K S5-GC33K S5-GC36K

\$5-GC40K \$5-GC40K-HV \$5-GC50K-HV \$5-GC15K-LV \$5-GC20K-LV \$5-GC23K-LV \$5-GC25K-AU \$5-GC30K-AU \$5-GC33K-AU \$5-GC36K-AU \$5-GC40K-AU \$5-GC40K-HV-AU

S5-GC50K-HV-AU

Continued on page 0002

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date <u>26.09.2021</u>

A. Chen

Certification Body

TÜVRheinland

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

(E The CE marking may be used if all relevant and effective EC Directives are complied with.

CE





of Conformity Low Voltage Directive 2014/35/EU

Registration No.:

AN 50519833 0002

Report No.:

50263108 010

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Serial Number

: Engineering Sample

Remark(s)

: Issued in conjunction with TÜV Rheinland

license R 50518312 0001-0006.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 26.09.2021

A. Chen

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

(The CE marking may be used if all relevant and effective EC Directives are complied with.

CE

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Zhang Kun

Date : 27.09.2021 Our ref. : Kese 01 Your ref.: Zhang kun

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AN 50519833 0001 : 50263108 010 Report No.

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Enclosure

Tel: (8610)8524 2222 Fax: (8610)8524 2200 e-mail: info@bj.chn.tuv.com Internet: http://www.chn.tuv.com



of Conformity

Registration No.:

AK 50522088 0001

Report No .:

50281041 007

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: Solis-aaK-5G (aa=25,30,33,36,40)

Solis-bbK-HV-5G (bb=40,50) Solis-ccK-LV-5G (cc=15,20,23) S5-GCxxK (xx=25,30,33,36,40) S5-GCyyK-HV (yy=40,50) S5-GCzzK-LV (zz=15,20,23)

Serial Number : Engineering Samples

Firmware version : V31

Remark(s) : Refer to report 50281041 007 for details.

Tested acc. to:

IEC 61727:2004 IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date

22.10.2021

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Certification



No. 57 Jintong Road, Binhai (Sea front) Industrial Park, Xiangshan, Ningbo, Zhejiang, 315712, P.R.China Tel: (+86) 574 6578 1806 Fax: (+86) 574 6578 1606 E-Mail: info@Ginlong.com

13th June 2021 To whom it may concern

letter of intent

Our company, Ginlong Technologies Co., Ltd, with headquarters in Zhejiang, China, are pioneers in PV inverters. Although Ginlong Technologies has become one of the world's most competitive manufacturers of PV inverters and maintains a strong investment in R&D and continual improvements in production methods, customer service remains a primary focus and a key to the company's success

Ginlong hereby confirm that Gunda Power Pvt Ltd, with its registered office in 123/10, Pannipitiya Road, Battaramulla, Sri Lanka, is one of our customers and we hereby authorize them to sale our products in Sri Lanka

Yours sincerely Ginlong Technologies Co.,私战股份有限公司, GINLONG TECHNOLOGIES CO.,LTD.



SOLIS INVERTER WARRANTY

Ginlong(Ningbo) Technologies Co., Ltd.

No. 57 Jintong Road, Binhai Industrial Park, Xiangshan, Ningbo, Zhejiang 315712, China Tel: (+86) 574 6578 1806 Email: sales@ginlong.com

Solis Inverter are manufactured by Ginlong (Ningbo) Technologies Co., Ltd. (The Company) (refered to as Ginlong) provides the following Warranty to the purchaser (The Customer) of the Inverter (The Goods). (The Customer is deemed to be the owner of the installed Goods at first sale.

1. Warranty Terms

The Company warrants all Goods to be free from defects in material or workmanship under normal use and service for a period of 5 years from the date of sale to the Customer.

The Warranty covers the cost of repairs or replacement parts. The Goods must be returned to the Company for inspection.

The company may repair or replace faulty components at its discretion.

This warranty extends the Customer's statutory rights and cannot be construed so as to diminish such statutory rights.

2. Warranty Extension

The purchaser may apply for a warranty extension within 12 months of purchase by providing the serial number of the unit along with proof of purchase. An extended warranty can be purchased for a further 5 years (Total 10 years).

The Warranty is valid only for Goods purchased either directly from the Company or from an authorized reseller of the company.

The Warranty is not transferable and applies to brand new Goods only.

Defective parts replaced under Warranty become the property of the Company.

The Warranty does not cover:

- (a) Access or transport costs:
- (b) Consequential damages including but not limited to loss of revenue;
- (C) Claims by third parties other than the Customer:
- (d) Defects of installation. (Except where the installation is performed by the Company);
- (e) Goods damaged as a consequence of incorrect installation. (Except where the installation is performed by the Company);
- Items ancillary to installation not supplied by the Company;
- (g) Duties, import/export fees or costs and other general administrative costs;
- (h) Damage to Goods caused by misuse, improper handling or unauthorized modification;
- Loss or damage occurring whilst in transit;
- Accidental or willful damage;
- Any Goods described in a quotation or delivery note as 'ex-display' or 'reconditioned'. (A separate Warranty extension may have been issued to cover such Goods.)

Labour, travel and delivery (to and from customer) will be charged if goods returned found to be not faulty following a warranty claim.

Any part or component that shall have been subject to abuse, misuse, negligence, accident or natural disaster, including but not limited to lightning, hail storm, tornado, acts neither foreseen nor controlled and commonly defined as force majeure.

4. Warranty Claims Procedure

To make a warranty claim the following information needs to be provided:

- Completed RTM Inspection Form
- Product Model (ie. Solis 1.5kW) and Product Serial Number (ie. A1110011)
- Copy of the invoice for the inverter Copy of the installation report and installation certificate

The authorised reseller will liaise with the Company regarding repair or replacement. The cost of repair or replacement will be borne by the Company provided the Warranty has been validated and the Warranty period has not expired.

Where repairs must be effected at the Company's headquarters, the Company will endeavor to minimize the down time for the Goods.

Mini 4G 700W 3600W

Solis Mini 4G Series Inverter

- MINI series Extended to 3600W
- ▶ High frequency switching technology Smaller, smarter
- ▶ DRM integrated, fully comply with AS4777.2:2015
- Compact and lightweight
- ▶ 50V-500V input voltage range ultra low startup
- Over 97.5% Max. effciency
- Precise MPPT algorithm
- ▶ Intergrated Export Power Manager(EPM)
- Rs485, WiFi/LAN/GPRS (optional) interface
- ▶ WiFi monitoring available-iphone and android app available
- ▶ 5 years standard warranty, 20 years optional upgrade



Model:

120V Solis-mini-1000-4G -LV

220V Solis-mini-700-4G Solis-mini-1000-4G Solis-mini-1500-4G Solis-mini-2000-4G Solis-mini-2500-4G Solis-mini-3000-4G Solis-mini-3600-4G

Features:



HF SWITCH

WiFi/GPRS

60V



IP65

Datasheet

Model	Solis-mini-1000-4G-LV	Solis-mini-700-4G	Solis-mini-1000-4G	Solis-mini-1500-4G	Solis-mini-2000-4G	Solis-mini-2500-4G	Solis-mini-3000-4G	Solis-mini-36	
Energy Source				P	V				
Input Side(DC)									
Max. DC input power(kW)	1.2	0.9	1.2	1.8	2.3	3	3.5	4	
Max. DC input voltage(V)				60					
Start-up voltage(V)	90		60			9	0		
MPPT voltage range(V)		50)-500			80-			
Max. input current per MPPT(A)				11A				19A	
MPPT number/Max input strings number				1/1				1/2	
Output Side (AC)									
Rated output power(kW)	1	0.7	1	1.5	2	2.5	3	3.6	
Max. apparent output power(kVA)	1.1	0.8	1.1	1.7	2.2	2.8	3.3	3.6	
Max. output power(kW)	1.1	0.8	1.1	1.7	2.2	2.8	3.3	3.6	
Rated grid voltage(V _{LL})	101/120/127	0.0	1.1	1.,	220/230	2.0	0.0	0.0	
Rated grid frequency(Hz)	101/120/12/			50/					
Operation phase									
Rated grid output current(A)	0.2	3 2/2 0	A 5/A 2	Sin	-	11 4/10 0	12 6/12	16	
	8.3	3.2/3.0	4.5/4.3	6.8/6.5	9.1/8.7	11.4/10.9	13.6/13		
Max. output current(A)	9.2	4.4	5.2	8.1	10.5	13.3	15.7	16	
Power Factor (at rated output power)				0.8 leading					
THDi				<3					
DC injection current(mA)				<0.5					
Grid frequency range(Hz)				47 - 52 o	r 57-62				
Efficiency									
Max.efficiency			97.2%				97.5%		
EU efficiency			96.5%				96.8%		
MPPT efficiency				>99	.5%				
Protection									
DC reverse-polarity protection				Ye	s				
Short circuit protection				Ye	s				
Output over current protection				Ye	s				
Output over voltage protection				Ye	es				
Insulation resistance monitoring				Ye	es				
Residual current detection				Ye	es				
Surge protection				Ye	es				
Islanding protection				Υe	s				
Temperature protection				Υe	s				
Integrated DC switch				Opti	onal				
General Data									
Dimensions(mm)				310W*37	3H*160D				
Weight(kg)			8.5				8.8		
Topology				Transfor	merless				
Self consumption (night)				<1W(i	Night)				
Operating ambient temperature range				-25~					
Ingress protection				IP	65				
Noise emission{typical}				<20	dBA				
Cooling concept				Natural co					
Max.operation altitude				400					
				>20 y					
						C61727. VDE N41	05		
Designed lifetime		F	N50438. G83/2 A	S4777.2:2015. VI	EN50438, G83/2, AS4777.2:2015, VDE0126-1-1, IEC61727, VDE N4105				
Designed lifetime Grid connection standard		E	N50438, G83/2, A						
Designed lifetime Grid connection standard Relative humidity		E		0~10	00%	N61000-6-3			
Designed lifetime Grid connection standard Relative humidity Safety/EMC standard		E			00%	EN61000-6-3			
Designed lifetime Grid connection standard Relative humidity Safety/EMC standard Features		E		0~10 1/-2, NB/T 32004,	00% EN61000-6-1, E	N61000-6-3			
Designed lifetime Grid connection standard Relative humidity Safety/EMC standard Features DC connection		E		0~10 1/-2, NB/T 32004, MC-4 m	00% EN61000-6-1, E ateable	N61000-6-3			
Designed lifetime Grid connection standard Relative humidity Safety/EMC standard Features DC connection AC connection		E		0~10 1/-2, NB/T 32004, MC-4 m IP67 rat	00% EN61000-6-1, E ateable ed plug	:N61000-6-3			
Designed lifetime Grid connection standard Relative humidity Safety/EMC standard Features DC connection		E		0~10 1/-2, NB/T 32004, MC-4 m	00% EN61000-6-1, E ateable ed plug ×20 Z.	:N61000-6-3			

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ningbo Ginlong technologies Co.,

Ltd.

Zhang Kun

Date : 18.05,2017 Our ref. : DJW 01 Your ref.: 52109827

No.57 Jintong Road, Binhai, (seafront) industrial Park, Xiangshan Ningbo, Zhejiang 315712 P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificaté No. : R 50379026 0001 : 50081618 001 Report No.

Dear Zhang Kun,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

Enclosure

证书的介绍成科通费经www.sartipedia.com查询,成为打技和客服的线800 959 3668 / 400 683 1305后进

Certificate



Zertifikat Nr. Certificate No. R 50379026

Blutt Sheet 0001

Ihr Zeichen Client Reference

52109827

Unser Zeichen Our Reference

01-DJW-50081618 001

Ausstellungsdatum Date of Issue 18.05.2017

(day/mo/yr)

Genehmlgungsinhaber License Holder Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai, (seafront)

industrial Park, Kiangshan Ningbo, Zhejiang 315712 P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Bauert gegebb Saherielt SoppindSign Fronktions

Geprüft nach Fested occ. to IBC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product (Product Identification)

Lizenzentgelte - Kinheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

Type Designation

: Bolis-mini-700-4G Solis-mini-1000-43

Vnax PV [Vd.c.]

: 17.2 Isc PV [Ad.c.]

66-500/94-400 MPP Voltage Range [Vd.c.]

Max. Input Current[Ad.c.] 1 11

Overvoltage Category (OVC) : II for PV

Rated Output Voltage[Va.c.]: 230V Rated Output Frequency[Hz] : 50/60 Rated Output Power[kM] : 700/10 1 700/1000 Rated Output Power [kM]

Max. Output Current [As.c.] : 4.4/5.2 Power Factor : [-0.80, 0.80] Overvoltage Category (OVC) : III for AC mains

continued on page 0002

ANLAGE (Appendix): 1

Dem Zentifiket tingt ansere Priif- and Zerrificterungsordnung zugrande und zu brakhtet die Konformielts des Produktes mit den oben gewannten Standards und Priifigeundlugen. Zastizzliche Anforderungen in Ländern, in denne den Priifikel in Ferlebe gefracht verden zoll, nikszen zusätzlich Anforderungen in Ländern, in denne den Priifikel in Ferlebe gefracht verden zoll, nikszen zusätzlich bestanden bereiten. Die Berteitlung des produktes vord übervaacht. This veräfictute in Stand ein nur Testing and Certification Regulation und mitte die vonformity of the product with the standards and resting enquirements us indicated above, des additional requirements in countries where the product is going to be standards have as he countries additionally. The manufacturing of the certified product it subject to quere blasse.

TÜV Rheinland LGA Products GmbH, Tillystrafle 2, 90431 Nürnberg

Tel.: +49 221 806-1371 c-exil: cert-validity@de.tax.com Fax: +48 221 806-3935 hep://www.rax.com/afety

Zertif

Weichun Li

Certificate



Zertiffkat Nr. Certificate No. R 50379026

Blatt Sheet 0002

the Zeichen Client Reference

Unser Zeichen Our Reference 01-DJW-50081618 001

Ausstellungsdatum 18.05.2017

Date of Issue (day/mo/yr)

52109827

Genehmigungsinhaber License Holder Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai, (seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712 P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Geprüft nach Tested acc. to IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product (Product Identification) Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

Continuation

Type Designation

r Solis-mini-1500-4G Solis-mini-2000-4G

Vnax PV [Vd.c.] Isc PV [Ad.c.] + 17.2

MPP Voltage Range[Vd.c.] Max. Input Current[Ad.c.] 1 141-400/187-400

1 11

Overvoltage Category (OVC) : II for FV

Rated Output Voltage[Va.c.]: 230V Rated Output Frequency[Hz] : 50/60

Rated Output Power [kW] : 1500/2000 Max. Output Current[As.c.] : 8.1/9.1 Power Pactor : [-0.80, 0.80] Overvoltage Category (OVC) : III for AC mains

continued on page 0003

ANLAGE (Appendix): 1

Done Zertifikar Negt watere Priifi und Zertifitierungsverleung ingrinde und es bezeitigt die Konformität des Produktes mit dem ohen genannten Standards und Priifiprondispen. Zezitzbieke Anfordemungen in Ländern, in denen das Produkt in Verlahr gebrockt verden zull, mittern zusätzbieh behrachten vereiten. Die Heiserthing des zertifizierien Franklate und überweite dem Meterolika. Dies vertifizierien Franklate und states the conformity af ihr product with the standards und states und vertifizierien kepstetion und states the conformity af ihr product with the standards und states op experiencests as indicated above. Any additional registerient in promotite vielere iks product is guig to be meterolikan in be considered und site of the overlifted product is subject to starveillance.

TÜV Rheinfand LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel., +49.221 806-1371 o-mail: cot-validity@de.tuv.com Fan; +49.221 806-3935 http://www.tuv.com/safety

Welchun Li

Certificate



Zertifikat Nr. Certificate No. R 50379026

Blatt Sheet 0003

Der Zeichen Client Reference

Unser Zeichen Our Reference 01-DJW-50081618 001

Ausstellungsdatum 18.05.2017

Date of Issue (day/ma/yr)

52109827

Genehmigungsinhaber License Holder Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712 P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Basari geprütt Sicharheit Regelmäßige Produktions-überwachung

Geprüft nach Tested occ. to

IEC 62109-1:2010 IEC 62109-2:2011

EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

. 600

Continuation

Type Designation

: Solis-mini-2500-4G

Solis-mini-3000-4G

Weak PV [Vd.c.]

1 17.2

ISC PV [Ad.c.] MPP Voltage Range[Vd.c.] : 234-400/281-500 Max. Input Current[Ad.c.] : 11

Overvoltage Category (OVC) : II for DV

Rated Output Voltage[Va.c.]: 230V

Rated Output Prequency(Hz): 50/60
Rated Output Power(kW]: 2500/3000
Max. Output Current[Aa.c.]: 11.4/13.6
Power Factor: [-0.80, 0.80]

Overvoltage Category (OVC) : III for AC mains

continued on page 0004

ANLAGE (Appendix): 1

Don Zertifikat liegt ansere Priif- und Zertifizierungsandung zugrunde und as bestängt die Eurformität des Produktes ols dem oben genomenn Sandards und Priifprondisgen. Zusäulische Anforderungen in Ländern, in denne das Produkt in Verlacht gebracht werden zoll, mitzen zusäulisch betrachtet vereinen. Die Herstellung des zertifiziertes Froduktes wird übersecht: This enriftente is band on eur Tarting und Certification Regulation and states die conformity of the product with the standards and testing requirements at indicated above. Asy additional requirements in countries where the product is going to be marketed have in the considered additional reductments. The manufacturing of the certified product is subject to surreliance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1373 e-mail: con-salidity@de.suv.com Fax: +49 221 806-3935 http://www.luv.com/rafety



Certificate



Zertifikat Nr. Certificate No. R 50379026

Blatt Sheet 0004

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum Date of Issue

52109827

01-DJW-50081618 001

18.05.2017

(day/ma/yr)

Genehmigungsinhaber License Holder

Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant Ningbo Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Becart paper29 Sicherheit Registräßige Produktiona-Literwachung

Geprüft nach Tested occ. to IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

Type Designation : Solis-mini-3500-40

Vmax PV [Vd.c.] Isc PV [Ad.c.] MPP Voltage Hange[Vd.c.] 600 : 17.2 337-500

Max. Input Current[Ad.c.] - 11

Overvoltage Category (CVC) : II for PV

Rated Output Voltage[Va.c.]: 230V Rated Output Frequency[Hx] : 50/60 Rated Output Power[kk] : 3600 Max. Output Current[Aa.c.] : 16

Power Factor [-0.80, 0.80]

Overvoltage Category (OVC) : III for AC mains

continued on page 0005

ANLAGE (Appendix): 1

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg.

Tel.: +69 221 856-1371 o-mail: cert-validity@de.tav.com Fax: +69 221 806-3935 http://www.nav.com/ankty

Zertifi

Certificate



Zertifikat Nr. Certificate No. R 50379026

Blatt Sheet 0005

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum Date of Issue

52109827

01-DJW-50081618 001

18.05.2017

(day/mo/yr)

Genehmigungsinhaber License Holder

Ningbo Ginlong technologies Ltd.

No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Kiangshan Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai,

(seafront)

industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Dauert gegebilt. Registratifige Fredutrions-überweckung

Geprüft nach Tested acc. to IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteldentifikation) Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0004

Continuation

Protective Class

Altitude [m]

Operating Temperature [°C] : -25 to 60 (> 45 derating)

Type of Inverter

Enclosure Protection (IP) : IP65 Pollution degree (PD) : PD 2(inside), PD3(outside) 4000

: Non-isolated

The installation has to be carried out according to the Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

15


ANLAGE (Appendix): 1

Dem Zertifikal kiegi untere Pritif- und Zertifizierungsordnung zugrunde und es bestängt die Konformität des Produktes mit den aben genannten Stoudorits und Pritigewellagen. Zeislistliche Anfordreningen in Ländere, in denne des Produkt in Verlache gebrucht werden soll, mitsen zusätzlich betrachtet norden. Die Heistellung des pertigiereren Produkter wird überwecht. Eint certificene is beseit en our Testing und Certification fregoletion wird states the conformity of the product with the shoulderst and stating requirements at indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to inventioner.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 98431 Nürnberg

Tel.: 449 221 806-1371 e-mail: cert-validity@de.tuv.com Pan: 449 221 806-3935 http://www.tuv.com/anfety

Weichun Li





Ningbo Ginlong technologies Co.,

Ltd.

Zhang Kun

Date : 18.05.2017 Our ref. : DJW 01 Your ref.: 52109827

No.57 Jintong Road, Binhai, (seafront) industrial Park, Xiangehan Ningbo, Zhejiang 315712 P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-connected PV Inverter Model Designation : See Certificate Certificate No. : AN 50379081 0001 : 50081618 001 Report No.

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Enclosure

证书的详细类科佛型基eww.cartipadia.com查验.或没打卖现在最热线800 996 3668 / 600 883 1300高效



of Conformity Low Voltage Directive 2014/35/EU

Registration No.:

AN 50379081 0001

Report No.:

50081618 001

Holder:

Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai, (seafront) industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Product:

PV-Invertor

(Grid-connected PV Inverter)

Identification:

Type Designation : Solis-mini-700-4G Solis-mini-1000-4G

Solis-mini-1500-4G Solis-mini-2000-4G Solis-mini-2500-4G Solis-mini-3000-4G

Solis-mini-3500-4G

Serial Number

Remark

: A000534491-001 : Issued in conjunction with TDV Rheinland

license R 50379026 0001-0005.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.



Date ___18.05.2017__

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

€ The CE marking may be used if all relevant and effective EC Directives are complied with. (€



of Conformity

Registration No.:

AK 50403825 0001

Report No .:

50132560 001

Holder:

Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo, Zhejiang 315712 P. R. China

Product:

PV-Inverter

(Grid-Connected PV Inverter)

Identification:

Type Designation : Solis-mini-3000-4G Solis-mini-2500-4G

Solis-mini-2500-4G Solis-mini-2000-4G

Solis-mini-1000-4G

Serial Number

: Engineering Samples

Firmware version : V13

Remark(s)

: Refer to report 50132560 001 for details.

Tested acc. to:

IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does into imply assessment of the production of the product and does not permit the use of a TUV Briefpland operk of conformity.

Date

29.03.2018

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

1P 4G 2.5kW 6kW

Solis 1P 4G Single Phase Inverter

- ▶ Solis 1P 4G Single Phase Range
- ► High frequency switching technology Smaller, smarter
- ▶ Dual MPPT design with precise MPPT algorithm
- ▶ Intergrated Export Power Manager(EPM)
- ▶ Over 98.1% Max.efficiency
- ▶ RS485, WiFi/LAN/GPRS (optional) interface
- ▶ WiFi monitoring available-iphone and android app available
- ▶ 5 years standard warranty, 20 years optional upgrade



Model:

Solis-1P2.5K-4G Solis-1P3K-4G Solis-1P3.6K-4G

Solis-1P4K-4G Solis-1P4.6K-4G Solis-1P5K-4G

Solis-1P6K-4G

Features:



HF SWITCH
High switch
frequency

AFCI
——Optional

IP65

WiFi/GPRS

Real time
monitoring



Datasheet

Model	Solis-1P2.5K-4G	Solis-1P3K-4G	Solis-1P3.6K-4G	Solis-1P4K-4G	Solis-1P4.6K-4G	Solis-1P5K-4G	Solis-1P6K-4G
Energy Source				PV			
Input Side(DC)				1 V			
Max. DC input power(kW)	3	3.5	4.2	4.6	5.3	5.8	6.6
		3.5	4.2			5.6	0.0
Max. DC input voltage(V)	550			60			
Start-up voltage(V)	60			12			
MPPT voltage range(V)	50-450			90-	520		
Max. input current per MPPT(A/B)				11A+11A			
MPPT number/Max input strings number				2/2			
Output Side (AC)		l					
Rated output power(kW)	2.5	3	3.6	4	4.6	5	6
Max. apparent output power(kVA)	2.8	3.3	4	4.4	5	5	6
Max. output power(kW)	2.8	3.3	4	4.4	5	5	6
Rated grid voltage(V _{LL})				220/230			
Rated grid frequency(Hz)				50/60			
Operation phase		I	1	Single		ı	ı
Rated grid output current(A)	11.4/10.9	13.6/13	16/15.7	18.2/17.4	20.9/20	22.7/21.7	27.3
Max. output current(A)	13.3	15.7	16	21	23.8	25	27.3
Power Factor (at rated output power)			0.	8 leading 0.8 laggi	ng		
THDi				<3%			
DC injection current(mA)				<0.5%In			
Grid frequency range(Hz)				47-52 or 57-62			
Max.efficiency		97.8%			98.	.1%	
EU efficiency		97.1%			97.	.3%	
MPPT efficiency				>99.5%			
Protection							
DC reverse-polarity protection				Yes			
Short circuit protection				Yes			
Output over current protection				Yes			
Output over voltage protection				Yes			
Insulation resistance monitoring				Yes			
Residual current detection				Yes			
Surge protection				Yes			
Islanding protection				Yes			
Temperature protection	Yes						
Integrated DC switch	Optional						
General Data				- p			
Dimensions(mm)				310W*543H*160D			
Weight(kg)				11.5			
Topology				Transformerless			
Self consumption (night)				<1W(Night)			
Operating ambient temperature range				-25~60°C			
Ingress protection				IP65			
Noise emission{typical}				<30 dBA			
Cooling concept				Natural convection			
Max.operation altitude				4000m			
Designed lifetime				>20 years			
-		ENE0400	C02/2 CE0/2 AC4		06 1 1 IFO64707 11	DE N4405	
Grid connection standard		EN5U438	, G03/2, G39/3, AS4	777.2:2015, VDE012	.0-1-1, IEC01/2/, V	D ⊆ 104 105	
Relative humidity			IEC62400 4/ 0 **	0~100%	6.1 ENG1000 0.0		
Safety/EMC standard			IEC02109-1/-2, N	B/T 32004,EN61000	-o-1, EN61000-6-3		
Features							
DC connection				MC-4 mateable			
AC connection				IP67 rated plug			
Display				LCD,2×20 Z.			
Communication connections			4	pins RS485 connect	or		
Warranty			5 years	standard (extend to 2	0 years)		



of Conformity

Registration No.: AK 50403828 0001

Report No.:

50132563 001

Holder:

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P. Ř. China

Product:

PV-Inverter

(Grid-Connected PV Inverter)

Identification:

Type Designation : Solis-1P5K-4G Solis-1P4K-4G

Serial Number : Engineering Samples

Firmware version : V13

Remark(s) : Refer to report 50132563 001 for details.

Tested acc. to:

IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificat assessment of the production of the product and does not permit the use of conformity.

Date 29.03.2018

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



No. B 17 04 86470 019

Ningbo Ginlong Technologies Co., Ltd. Holder of Certificate:

No.57 Jintong Road

Binhai Industrial Park, Xiangshan

315712 Ningbo, Zhejiang

PEOPLE'S REPUBLIC OF CHINA



Certification Mark:



Product: Converter

Grid-Tied Inverter

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

704091623704-00

Valid until:

2022-03-31



TUV®

Date, 2017-04-08

Page 1 of 3







CERTIFICATE No. B 17 04 86470 019

Model(s):

Solis-1P5K-4G, Solis-1P4.6K-4G, Solis-1P4K-4G. Solis-1P3.6K-4G, Solis-1P3K-4G, Solis-1P2.5K-4G, Solis-1P2K-4G, Solis-1P1.5K-4G, Solis-1P1K-4G, URE-1P5K-4G, URE-1P4.6K-4G, URE-1P4K-4G, URE-1P3.6K-4G, URE-1P3K-4G, URE-1P2.5K-4G, URE-1P2K-4G, URE-1P1.5K-4G, URE-1P1K-4G, GCI-1P5K-4G, GCI-1P4.6K-4G, GCI-1P4K-4G, GCI-1P3.6K-4G, GCI-1P3K-4G, GCI-1P2.5K-4G, GCI-1P2K-4G, GCI-1P1.5K-4G, GCI-1P1K-4G, Mate-5K-4G, Mate-4.6K-4G, Mate-4K-4G, Mate-3.6K-4G, Mate-3K-4G, Mate-2.5K-4G, Mate-2K-4G, Mate-1.5K-4G, Mate-1K-4G, Solis-1P3K-4G-ST, URE-1P3K-4G-ST, GCI-1P3K-4G-ST, Mate-3K-4G-ST.

Parameters:

Max. input voltage: see attachment. See attachment MPP voltage range: See attachment Max. input current: isc PV (absolute See attachment maximum):

a.c. 230/240V Rated grid voltage: Rated grid frequency 50/60Hz

Max. AC output active power: Max. AC output apparent power: Max continuous

See attachment output current Adjustable cos(ø): 0.8...1...0.8

Protection class: Degree of protection: Overvoltage category: Ambient temperature:

IP65 III(MAINS), II(PV) -25 ... +60°C

See attachment

See attachement

Other ratings refer to attachment.

Tested according to:

IEC 62109-1(ed 1) IEC 62109-2(ed 1) EN 62109-1:2010 EN 62109-2:2011

Production Facility(ies):

86470

Page 2 of 3



N

CERTIFICATE No. B 17 04 86470 019



Product Service

Electrical ratings for various models:

Models	Solis-1P1K-4G GCI-1P1K-4G Mate-1K-4G URE-1P1K-4G	Solis-1P1.5K-4G GCI-1P1.5K-4G Mate-1.5K-4G URE-1P1.5K-4G	Solis-1P2K-4G GCI-1P2K-4G Mate-2K-4G URE-1P2K-4G	Solis-1P2.5K-4G GCI-1P2.5K-4G Mate-2.5K-4G URE-1P2.5K-4G		
PV input ratigns:	AND THE PARTY OF THE		All Parlicus Carros	All securioralities		
Max. input voltage:		d.c. 5	50 V			
MPP voltage range:		d.c. 50	- 450V			
Max. Input current:	d.c. 11A					
Isc PV (absolute maximum):	d.c. 17.2A					
AC output:						
Rated grid voltage:		a.c. 23	0/240V			
Rated grid frequency:		50/6	0Hz			
Max. AC output active power:	1100W	1700W	2200W	2800W		
Max. AC output apparent power:	1100VA	1700VA	2200VA	2800VA		
Max. Continuous output current:	a.c. 5.2A	a.c. 8.1A	a.c. 10.5A	a.c. 13.3A		

Models	Solis-1P3K-4G GCI-1P3K-4G Mate-3K-4G URE-1P3K-4G	Solis-1P3.6K-4G GCI-1P3.6K-4G Mate-3.6K-4G URE-1P3.6K-4G	Solis-1P4K-4G GCI-1P4K-4G Mate-4K-4G URE-1P4K-4G	Solis-1P4.6K-4G GCI-1P4.6K-4G Mate-4.6K-4G URE-1P4.6K-4G	Solis-1P5K-4G GCI-1P5K-4G Mate-5K-4G URE-1P5K-4G
PV input ratigns:	1 10000 11 010 190	1		1	
Max. input voltage:			d.c. 600 V		
MPP voltage range:			d.c. 100 - 500V		
Max. input current:			d.c. 2x11A		
Isc PV (absolute maximum):			d.c. 2x17,2A		
AC output:					
Rated grid voltage:			a.c. 230/240V		
Rated grid frequency:			50/60Hz		
Max. AC output active power:	3300W	4000VV	4400VV	4600VV	5000W
Max. AC output apparent power:	3300VA	4000VA	4400VA	4600VA	5000VA
Max. Continuous output current:	a.c. 15.7A	a.c. 16A	a.c. 21A	a c. 25A	a.c. 25A

Models	Solin-1P3K-4G-ST, GCI-1P3K-4G-ST, Mate-3K-4G-ST, URE-1P3K-4G-S				
PV input ratigns:					
Max. input voltage:	d.c. 600 V				
MPP voltage range:	d.c. 100 – 500V				
Max. Input current:	d.c. 11A				
Isc PV (absolute maximum):	d.c. 17.2A				
AC output:	William And Andreas An				
Rated grid voltage:	a.c. 230/240V				
Rated grid frequency:	50/60Hz				
Max. AC output active power.	3300VV				
Max. AC output apparent power:	3300VA				
Max. Continuous output current:	a.c. 15.7A				

Page 3 of 3

A17.04.33





of Conformity

Registration No.: AK 50419820 0001

Report No.:

50181860 001

Holder:

Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo, Zhejiang 315712

P. R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: Solis-1P6K-4G Solis-1P5K-4G

Solis-1P4.6K-4G Solis-1P4K-4G Solis-1P3.6K-4G Solis-1P3K-4G

Solis-1P2.5K-4G

Firmware Version: 1F0010

Remark(s)

: Refer to report 50181860 001 for details.

Tested acc. to:

UTE C15-712-1/07.13

DIN VDE 0126-1-1/A1 VFR2014

Enedis-NOI-RES 13E

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TUV Rheinland mark of conformity.

Cartification Body

Date 10.10.2018

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



Certificat de conformité

Fabricant:

Ningbo Ginlong technologies Co., Ltd.

No.57 Jintong Road, Binhai, (seafront) Industrial Park, Xiangshan,

Ningbo, zhejiang, 315712, P.R. China

Type unité de production :

onduleur photovoltaïque lié au réseau

Modèle:

Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G,

Solis-1P4.6K-4G, Solis-1P5K-4G, Solis-1P6K-4G

Version micrologiciel:

1F0010

Règles de raccordement

au réseau :

UTE C 15-712-1/07.13

UNION TECHNIQUE DE L'ELECTRICITE, GUIDE PRATIQUE, Installations

photovoltaïques raccordées au réseau public de distribution

ENEDIS-NOI-RES_13E: 2016

Protections of production facilities connected to the public distribution network

DIN VDE 0126-1-1/A1 VFR 2014

Organe de commutation automatique entre une installation de production autonome parallèle au réseau et le réseau à basse tension public

Numéro rapport d'essai :

50181860 001

Numéro de certificat :

AK 50419820 0001

Date d'émission :

Otcober 10, 2018

Li Waichun Generai Manager

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Compliance Document

No. D 086470 0039 Rev. 00

Holder of Certificate: Ningbo Ginlong Technologies Co., Ltd.

No.57 Jintong Road

Binhal Industrial Park, Xiangshan 315712 Ningbo, Zhejiang PEOPLE'S REPUBLIC OF CHINA

Product: Converter

Grid-Tied Inverter

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. See also notes overleaf.

Test report no .:

704091805709-00

Date.

2018-10-25

(Zhengdong Ma)



Compliance Document

No. D 086470 0039 Rev. 00

Model(s):

Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G, Solis-1P5K-4G, Solis-1P6K-4G

Parameters:

Models	Solis-1P2.5K-4G	Solis-1P3K-4G	Solis-1P3.6K-4G	Solis-1P4K-4G
PV input ratigns:	Y			
Max. Input voltage:	d.c. 550 V	d.c. 600 V	d.d. 600 V	d.c. 600 V
MPP voltage range:	d.c. 50 - 450V	d.c. 90 - 520V	d.c. 90 - 520V	d.c. 90 - 520V
Max. input current:	d.c. 2x11A	d.c. 2x11A	d.c. 2x11A	d.c. 2x11A
Isc PV (absolute maximum)	d.c. 2x17.2A	d.c. 2x17 2A	d.c. 2x17.2A	d.c. 2x17.2A
AC output:			2	
Rated grid voltage:		B.C. 23	50/240V	
Rated grid frequency		50/	BOHz	
Rated output power:	2500W	3000W	3600W	4000W
Max. AC output active power.	2800W	3300W	4000W	4400W
Max. AC output apparent power.	2800VA	3300VA	4000VA	4400VA
Max. Continuous output current:	a.c. 13.3A	a.c. 15.7A	a.c. 16A	a.c. 21A
Adjustable cos(φ)		-0.8	1+0.8	

Models	Solis-1P4.6K-4G	Solis-1P5K-4G	Solis-1P6K-4G
PV input ratigns:	200000000000000000000000000000000000000	THE CONSTRUCTION OF THE CONTROL OF T	
Max. input voltage:		d.c. 800 V	
MPP voltage ranga		d.c; 90 - 520V	
Max. input current		d.c. 2x11A	
Isc PV (absolute maximum):		d.c. 2x17.2A	
AC output:			
Rated grid voltage:		a.c. 230/240V	
Rated grid frequency:		50/60Hz	
Rated output power.	4600W	5000W	6000VV
Max. AC output active power:	5000W	5000W	6000VV
Max. AC output apparent power:	5000VA	500DVA	6000VA
Max. Continuous output current	a.c. 23.8A	ac 25A	a.c. 27.3A
Adjustable cos(φ)		-0.81+0.8	

General specifications		
Protection class	UE:	
Degree of protection	IP65	
Overvoltage category	II(PV), III(MAINS)	
Ambient temperature	-25 +60°C	

DIN VDE 0126-1-1 (VDE V 0126-1-1):2013 Tested according to:







S6-GR1P(2.5-6)K

Solis Single Phase Inverters





360 degree

Features:

- ► Max. efficiency 97.7%
- ► String current up to **14A**
- ► Super high frequency switching technology
- ▶ Wide voltage range and low startup voltage
- ▶ 2 MPPT design with precise MPPT algorithm
- ► Intergrated Export Power Manager (EPM)
- ► Integrated AFCI (DC arc-fault circuit protection)
- ► Compact and lightweight
- ▶ Friendly and adaptable connection to the grid





S6-GR1P2.5K S6-GR1P3K S6-GR1P3.6K S6-GR1P4K S6-GR1P4.6K S6-GR1P5K S6-GR1P6K



Datasheet										
Model Name	S6-GR1P2.5K	S6-GR1P3K	S6-GR1P3.6K	S6-GR1P4K	S6-GR1P4.6K	S6-GR1P5K	S6-GR1P6K			
Input DC										
Recommended max. PV power	3.75 kW	4.5 kW	5.4 kW	6 kW	6.9 kW	7.5 kW	9 kW			
Max. input voltage	550 V			60	0 V					
Rated voltage	250 V			33	0 V					
Start-up voltage	60 V									
MPPT voltage range	50-450 V			90-5	520 V					
Max. input current		14 A / 14 A								
Max. short circuit current		22 A / 22 A								
MPPT number/Max. input strings number				2/2						
Output AC										
Rated output power	2.5 kW	3 kW	3.6 kW	4 kW	4.6 kW	5 kW	6 kW			
Max. apparent output power	2.8 kVA	3.3 kVA	4 kVA	4.4 kVA	5 kVA	5 kVA	6 kVA			
Max. output power	2.8 kW	3.3 kW	4 kW	4.4 kW	5 kW	5 kW	6 kW			
Rated grid voltage				/N/PE, 220 V / 230						
Rated grid frequency				50 Hz / 60 Hz						
Rated grid output current	11.4 A / 10.9 A	13.6 A / 13.0 A	16.0 A / 15.7 A	18.2 A / 17.4 A	20.9 A / 20.0 A	22.7 A / 21.7 A	27.3 A			
Max. output current	13.3 A	15.7 A	16.0 A	21.0 A	23.8 A	25.0 A	27.3 A			
Power Factor	15.5 //	13.17		0.8 leading - 0.8 la		25.0 A	21.5 A			
THDi			70.33 (<3%	² 88 ¹¹¹ 8/					
Efficiency				-570						
Max. efficiency	97.3%	0.7	3%	0.7	6%	97.	70/4			
EU efficiency	96.5%		6%		1%	97.				
Protection	30.3%	30.	070	31.	.170	31.	170			
DC reverse-polarity protection				Yes						
				Yes						
Short circuit protection				Yes						
Output over current protection										
Surge protection				Yes						
Grid monitoring				Yes						
Anti-islanding protection				Yes						
Temperature protection				Yes (1)						
Integrated AFCI (DC arc-fault circuit protection)										
Integrated DC switch				Optional						
General Data				04045404400						
Dimensions (W*H*D)	44.1			310*543*160 mm						
Weight	11 kg	11	2 kg	- ()	12	kg				
Topology				Transformerless						
Self consumption (night)				<1 W						
Operating ambient temperature range				-25 ~ +60°C						
Relative humidity				0-100%						
Ingress protection				IP66						
Cooling concept			I	Natural convection	n					
Max. operation altitude				4000 m						
Grid connection standard						D 1699 / RD 244 / U 1068, IEC 61683, EN				
Safety/EMC standard			IEC/EN 621	.09-1/-2, IEC/EN 6	1000-6-2/-3					
Features										
DC connection				MC4 connector						
AC connection			Qı	uick connection pl	lug					
Display				LCD						
Communication			RS48	5, Optional: Wi-Fi,	GPRS					





No. N8A 086470 0020 Rev. 05

Holder of Certificate: Ginlong Technologies Co., Ltd.

No.57 Jintong Road

Binhai Industrial Park, Xiangshan 315712 Ningbo, Zhejiang PEOPLE'S REPUBLIC OF CHINA

Product: Converter

PV Grid-Tied Inverter

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704091623704-05

Date, 2021-08-17

(Zhengdong Ma)





No. N8A 086470 0020 Rev. 05

Model(s):

Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G, Solis-1P5K-4G-MX, Solis-1P5K-4G, Solis-1P6K-4G, Solis-1P2.5K-4G-C, Solis-1P3K-4G-C, Solis-1P3K-4G-C, Solis-1P4K-4G-C, Solis-1P4K-4G-C, Solis-1P4K-4G-C, Solis-1P4K-4G-C, Solis-1P4K-4G-C,

Solis-1P6K-4G-C, S5-GR1P2.5K, S5-GR1P3K, S5-GR1P3.6K, S5-GR1P4K, S5-GR1P4.6K, S5-GR1P5K, S5-GR1P6K. S5-GR1P5K, S6-GR1P3.6K, S6-GR1P2.5K, S6-GR1P3K, S6-GR1P5K, S6-GR1P4K, S6-GR1P4K-R, S6-GR1P3K-R, S6-GR1P3.6K-R, S6-GR1P3.6K-R, S6-GR1P5K-R, S6-GR1P5K-R,

Parameters:

Models	Solis-1P2.5K-4G	Solis-1P3K-4G	Solis-1P3.6K-4G	Solis-1P4K-4G
	Solis-1P2.5K-4G-C	Solis-1P3K-4G-C	Solis-1P3.6K-4G-C	Solis-1P4K-4G-C
PV input rating	s:			
Max. input voltage:	550Vd.c.	600Vd.c.	600Vd.c.	600Vd.c.
MPP voltage range:	50-450Vd.c.	90-520Vd.c.	90-520Vd.c.	90-520Vd.c.
Max. input current:	2 x 11Ad.c.	2 x 11Ad.c.	2 x 11Ad.c.	2 x 11Ad.c.
lsc PV (absolute maximum):	2 x 17.2Ad.c.	2 x 17.2Ad.c.	2 x 17.2Ad.c.	2 x 17.2Ad.c.
AC output ratin	gs:			
Rated grid voltage:	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.
Rated grid frequency:	50/60Hz	50/60Hz	50/60Hz	50/60Hz
Rated output power:	2500W	3000W	3600W	4000W
Max. AC output active power:	2800W	3300W	4000W	4400W
Max. AC output apparent power:	2800VA	3300VA	4000VA	4400VA
Max. continuous output current:	13.3Aa.c.	15.7Aa.c.	16Aa.c.	21Aa.c.

Page 2 of 6



No. N8A 086470 0020 Rev. 05







No. N8A 086470 0020 Rev. 05

Models	Solis-1P4.6K-4G Solis-1P4.6K-4G-C	Solis-1P5K-4G Solis-1P5K-4G-C	Solis-1P5K-4G- MX Solis-1P5K-4G- MX-C	Solis-1P6K-4G Solis-1P6K-4G-C
PV input ratings:				
Max. input voltage:	600Vd.c.	600Vd.c.	600Vd.c.	600Vd.c.
MPP voltage range:	90-520Vd.c.	90-520Vd.c.	90-520Vd.c.	90-520Vd.c.
Max. input current:	2 x 11Ad.c.	2 x 11Ad.c.	2 x 11Ad.c.	2 x 11Ad.c.
Isc PV (absolute maximum):	2 x 17.2Ad.c.	2 x 17.2Ad.c.	2 x 17.2Ad.c.	2 x 17.2Ad.c.
AC output ratings:				
Rated grid voltage:	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.
Rated grid frequency:	50/60Hz	50/60Hz	50/60Hz	50/60Hz
Rated output power:	4600W	5000W	4999W	6000W
Max. AC output active power:	5000W	5000W	4999W	6000W
Max. AC output apparent power:	5000VA	5000VA	4999VA	6000VA
Max. continuous output current:	23.8Aa.c	25Aa.c	21.7Aa.c.	27.3Aa.c.







No. N8A 086470 0020 Rev. 05

Models	S5-GR1P2.5K S6-GR1P2.5K	S5-GR1P3K S6-GR1P3K	S5-GR1P3.6K S6-GR1P3.6K	S6-GR1P4K S6-GR1P4K
	S6-GR1P2.5K-R	S6-GR1P3K-R	S6-GR1P3.6K-R	S6-GR1P4K-R
PV input ratings	S:	•	•	
Max. input voltage:	550Vd.c.	600Vd.c.	600Vd.c.	600Vd.c.
MPP voltage range:	50-450Vd.c.	90-520Vd.c.	90-520Vd.c.	90-520Vd.c.
Max. input current:	2 x 14Ad.c.	2 x 14Ad.c.	2 x 14Ad.c.	2 x 14Ad.c.
Isc PV (absolute maximum):	2 x 22Ad.c.	2 x 22Ad.c.	2 x 22Ad.c.	2 x 22Ad.c.
AC output ratin	gs:			
Rated grid voltage:	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.	1/N/PE 220/230Va.c.
Rated grid frequency:	50/60Hz	50/60Hz	50/60Hz	50/60Hz
Rated output power:	2500W	3000W	3600W	4000W
Max. AC output active power:	2800W	3300W	4000W	4400W
Max. AC output apparent power:	2800VA	3300VA	4000VA	4400VA
Max. continuous output current:	13.3Aa.c.	15.7Aa.c.	16Aa.c.	21Aa.c.

Page 5 of 6



No. N8A 086470 0020 Rev. 05

Models	S5-GR1P4.6K	S5-GR1P5K	S5-GR1P6K
	S6-GR1P4.6K	S6-GR1P5K	S6-GR1P6K
	S6-GR1P4.6K-R	S6-GR1P5K-R	S6-GR1P6K-R
Max. input voltage:	600Vd.c.	600Vd.c.	600Vd.c.
MPP voltage range:	90-520Vd.c.	90-520Vd.c.	90-520Vd.c.
Max. input current:	2 x 14Ad.c.	2 x 14Ad.c.	2 x 14Ad.c.
Isc PV (absolute maximum):	2 x 22Ad.c.	2 x 22Ad.c.	2 x 22Ad.c.
Rated grid voltage:	1/N/PE	1/N/PE	1/N/PE
	220/230Va.c.	220/230Va.c.	220/230Va.c.
Rated grid frequency:	50/60Hz	50/60Hz	50/60Hz
Rated output power:	4600W	5000W	6000W
Max. AC output active	5000W	5000W	6000W
power:			
Max. AC output apparent power:	5000VA	5000VA	6000VA
Max. continuous output current:	23.8Aa.c.	25Aa.c.	27.3Aa.c.

General specifications:		
Models	S6 series moldes	all other models
Adjustable cos(φ)	-0.81.	+0.8
Protection class	I	
Degree of protection	IP66	IP65
Overvoltage category	II(PV), III(MAINS)
Ambient temperature	-25°C	+60°C
Inverter topology	Non-iso	plated

Tested EN 62109-1:2010 EN 62109-2:2011



CERTIFICATE



of Conformity

AK 50514285 0001 Registration No.:

CN20G2DH 002 Report No .:

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product: **PV-Inverter**

(Grid-Connected PV Inverter)

Identification: Type Designation: S6-GR1PxxK (xx=2.5,3,3.6,4,4.6,5,6)

Solis-1Pxxk-4G (xx=2.5,3,3.6,4,4.6,5,6)

Firmware Version: V2F

Serial Number : Engineering Samples

: Refer to test report CN20G2DH 002 for Remark

detail.

Tested acc. to: IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TUV Rheinland mark of conformity.

27.08.2021 Date

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Zhang Kun

Date : 27.08.2021 Our ref. : LIUPHI 01 Your ref.: Z.K

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-Connected PV Inverter

Model Designation : See Certificate Certificate No. : AK 50514285 0001 Report No. : CN20G2DH 002

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询



S5-GR3P(3-20)K

Solis Three Phase Inverters





360 degree

Model:

S5-GR3P3K S5-GR3P5K S5-GR3P6K S5-GR3P8K S5-GR3P9K S5-GR3P10K S5-GR3P12K S5-GR3P13K S5-GR3P15K S5-GR3P17K S5-GR3P20K



Efficient

- ► Max. efficiency 98.7%
- ► String current up to **16A**
- ► Wide voltage range and low startup voltage



Smart

- ► Supports export power control
- ► Supports RS485, WiFi, GPRS
- ► Scan to register on SolisCloud, supports remote upgrade and control



Safe

- ► IP66
- ► AFCI protection, proactively reduces fire risk
- ➤ Automatic voltage stabilization technology in weak grid conditions



Economic

- ▶ Compact design, simple installation and maintenance
- ▶ > 150% DC/AC ratio
- ► Supports high power modules for lower installation costs



Datasheet												
Model Name	S5-GR3P3K	S5-GR3P4K	S5-GR3P5K	S5-GR3P6K	S5-GR3P8K	S5-GR3P9K	S5-GR3P10K	S5-GR3P12K	S5-GR3P13K	S5-GR3P15K	S5-GR3P17K	S5-GR3P20
Input DC								1				
Recommended max. PV power	4.5 kW	6 kW	7.5 kW	9 kW	12 kW	13.5 kW	15 kW	18 kW	19.5 kW	22.5 kW	25.5 kW	30 kW
Max. input voltage		1100 V										
Rated voltage		600 V										
Start-up voltage		180 V										
MPPT voltage range							.000 V					
Max. input current				16 A / 16 A	A					32 A / 32 A	A	
Max. short circuit current				25 A / 25 A						50 A / 50 A	A	
MPPT number/Max. input strings number				2/2						2/4		
Output AC				,						•		
Rated output power	3 kW	4 kW	5 kW	6 kW	8 kW	9 kW	10 kW	12 kW	13 kW	15 kW	17 kW	20 kW
Max. apparent output power	3.3 kVA	4.4 kVA	5.5 kVA	6.6 kVA	8.8 kVA	9.9 kVA	11 kVA		14.3 kVA			22 kVA
Max. output power	3.3 kW	4.4 kW	5.5 kW	6.6 kW	8.8 kW	9.9 kW	11 kW	13.2 kW	14.3 kW			22 kW
Rated grid voltage	0.0		0.0	0.0		E, 220 V / 3			1.10.111	2010 1111	2011 1111	
Rated grid frequency					5,,.		/ 60 Hz	,				
, ,	4.6 A /	6.1 A /	7.6 A /	9.1 A /	12.2 A /	13.7 A /	15.2 A /	18.2 A /	19.8 A /	22.8 A /	25.8 A /	30.4 A
Rated grid output current	4.3 A	5.8 A	7.2 A	8.7 A	11.5 A	13.0 A	14.4 A	17.3 A	18.8 A	21.7 A	24.6 A	28.9 A
Max. output current	4.7 A	6.4 A	7.9 A	9.5 A	12.7 A	14.3 A	15.9 A	19.1 A	20.7 A	23.8 A	27 A	31.8 A
Power Factor					>0.99	0.8 leadi	ng - 0.8 la	gging)				
THDi						<2	.%					
Efficiency												
Max. efficiency		98.	.3%			98.5%			98.6%		98.	7%
EU efficiency		97.	.7%			97.9%			98.0%		98.	1%
Protection												
DC reverse-polarity protection						Ye	es					
Short circuit protection						Ye	es					
Output over current protection						Ye	es					
Surge protection						Ye	es					
Grid monitoring						Ye	es					
Anti-islanding protection						Ye	es					
Temperature protection						Ye	es					
Integrated AFCI (DC arc-fault circuit protection)						Ye	es (1)					
Integrated DC switch						Opti	onal					
General Data												
Dimensions (W*H*D)						310*563	*219 mm					
Weight				17.	8 kg				18.	8 kg	20	kg
Topology						Transfo	merless					
Self consumption (night)						<1	W					
Operating ambient temperature range						-25 ~	+60°C					
Relative humidity						0-10	00%					
Ingress protection						IP	66					
Cooling concept			Nati	ural conve	ction			li li	ntelligent ı	redundant	fan-coolin	g
Max. operation altitude						400	0 m		-			
Grid connection standard											244 / UNE 2 C 61683, EN	
Safety/EMC standard						9-1/-2, IEC						
Features						,		. , .,				
DC connection						MC4 co	nnector					
AC connection					(Quick conn		ıg				
Display							D D	3				
Communication					RS4	85, Option		GPRS				

CERTIFICATE



of Conformity

Registration No.:

AK 50514507 0001

Report No .:

50171233 006

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: Solis-3PxK-4G S5-GR3PyK

(x=5,6,8,9,10,12,15,17,20)

(y=3,4,5,6,8,9,10,12,13,15,17,20)

Serial Number : Engineering Samples

Firmware version: V18

Remark(s) : Refer to report 50171233 006 for details.

Tested acc. to:

IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a Turnelland mark of conformity.

Date

13.08.2021

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



: 13.08.2021

Ginlong technologies Co., Ltd.

Zhang Kun

Our ref. : PJG 01 Your ref .: Kun Zhang No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AK 50514556 0001 Report No. : 50330358 004

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Date

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Weichun Li

CC: Ginlong technologies Co., Ltd.

Enclosure

Tel: (8610)6566 6660 Fax: (8610)6566 6667 e-mail: info@bj.chn.tuv.com Internet: http://www.chn.tuv.com

Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0016

Ihr Zeichen Client Reference

Qingying Cui

Unser Zeichen Our Reference 01-Kese-50166775 014

Ausstellungsdatum 18.08.2021

Date of Issue (day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

Type Designation

: S5-GR3P3K S5-GR3P4K S5-GR3P5K

Vmax PV [Vd.c.] : 1100 Isc PV [Ad.c.] : 25/25 MPP Voltage Range[Vd.c.] : 160-1000 Max. Input Current[Ad.c.] : 16/16 Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 220/380 V, 230/400 V

Rated Output Freq. [Hz]

: 50/60 : 3000 4000

Rated Output Power[W] Max. Output Curr. [Aa.c.]

5000 7.9 : 4.7 6.4

Power Factor

: [-0.80, 0.80]

continued on page 0017

3

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0017

Ihr Zeichen Client Reference

Qingying Cui

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

01-Kese-50166775 014

18.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

Fertigungsstätte Manufacturing Plant

P.R. China

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

Prüfzeichen Test Mark



P.R. China

Bauart georüft Sicherheit Regelmäßige Produktions überwachung

www.tuv.com ID 1419049315 Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0016 continuation

3

Type Designation : S5-GR3P6K S5-GR3P8K S5-GR3P9K

Vmax PV [Vd.c.] : 1100 Isc PV [Ad.c.] : 25/25 MPP Voltage Range[Vd.c.] : 160-1000 Max. Input Current[Ad.c.] : 16/16 Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 220/380 V, 230/400 V

Rated Output Freq.[Hz] : 50/60

Rated Output Power[W] : 6000 8000 Max. Output Curr. [Aa.c.] : 9.5 12.7 14.3

Power Factor : [-0.80, 0.80]

continued on page 0018

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.; +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0018

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungs datum

Date of Issue

Qingying Cui

01-Kese-50166775 014

18.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1419049315

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0017 continuation

Type Designation : S5-GR3P10K S5-GR3P12K

Vmax PV [Vd.c.] : 1100

Isc PV [Ad.c.] : 25/25 50/50

MPP Voltage Range[Vd.c.] : 160-1000

Max. Input Current[Ad.c.] : 16/16 32/32

Overvoltage Category (OVC) : II for PV

Rated Output Volt.[Va.c.] : 3/N/PE, 220/380 V, 230/400 V

Rated Output Freq.[Hz] : 50/60

Rated Output Power[W] : 10000 12000 Max. Output Curr.[Aa.c.] : 15.9 19.1 Power Factor : [-0.80, 0.80]

continued on page 0019

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



0/020 th 04.08 . TUV, TUEV and TUV are requirened redomarks. Utilisation and application requires prior approx

Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0019

Ihr Zeichen Client Reference

Qingying Cui

Unser Zeichen Our Reference

01-Kese-50166775 014

Ausstellungsdatum

Date of Issue

18.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo

315712 Zhejiang P.R. China

Prüfzeichen Test Mark



P.R. China

Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1419049315 Geprüft nach Tested acc. to

IÉC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0018 continuation

Type Designation

: S5-GR3P13K S5-GR3P15K

Vmax PV [Vd.c.] : 1100
Isc PV [Ad.c.] : 50/50
MPP Voltage Range[Vd.c.] : 160-1000
Max. Input Current[Ad.c.] : 32/32
Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 220/380 V, 230/400 V

Rated Output Freq.[Hz] : 50/60

Rated Output Power[W] : 13000 15000

Max. Output Curr.[Aa.c.] : 20.7 23.8

Power Factor : [-0.80, 0.80]

continued on page 0020

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety Zertifizierungsstell

Weichun Li

220 d. 04.08 B TUV. TUEV and TUV are registered tradamarks. Unlication and application regures and approximate

Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Kese-50166775 014

18.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



P.R. China

Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0019 continuation

2

Type Designation

Vmax PV [Vd.c.] : 1100
Isc PV [Ad.c.] : 50/50
MPP Voltage Range[Vd.c.] : 160-1000
Max. Input Current[Ad.c.] : 32/32
Overvoltage Category (OVC) : II for PV

Rated Output Volt.[Va.c.] : 3/N/PE, 220/380 V, 230/400 V

Rated Output Freq.[Hz] : 50/60

Rated Output Power[W] : 17000 20000
Max. Output Curr.[Aa.c.] : 27 31.8
Power Factor : [-0.80, 0.80]

continued on page 0021

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TUV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



0030 tf 04:08 - TUV. TUEV and TUV are required trademarks. Utilisation and application requires procladers

Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0021

Ihr Zeichen Client Reference Qingying Cui

Unser Zeichen Our Reference 01-Kese-50166775 014

Ausstellungsdatum 18.08.2021

Date of Issue (day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktions überwechung

www.tuv.com ID 1419049315

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0020 continuation

Type Designation: S5-GR3P5K-AU S5-GR3P6K-AU S5-GR3P8K-AU

Vmax PV [Vd.c.]

: 1100 Isc PV [Ad.c.] : 50/25 50/25 50/50

MPP Voltage Range[Vd.c.] : 160-1000

Max. Input Current[Ad.c.] : 32/16 32/16 32/32

Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 230/400 V

Rated Output Freq. [Hz] : 50

Rated Output Power[W] : 5000 6000 8000 : 7.9 Max. Output Curr. [Aa.c.] 9.5 12.7

Power Factor : [-0.80, 0.80]

continued on page 0022

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



3

Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0022

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Kese-50166775 014

18.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Prüfzeichen Test Mark



P.R. China

Bauart geprüft Sicherheit Regelmäßige Produktions überwachung

www.tuv.com ID 1419049315

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

: S5-GR3P9K-AU S5-GR3P10K-AU

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

2

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0021 continuation

Type Designation

Vmax PV [Vd.c.] : 1100 Isc PV [Ad.c.] : 50/50 : 160-1000 MPP Voltage Range[Vd.c.] Max. Input Current[Ad.c.] : 32/32 Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 230/400 V

Rated Output Freq.[Hz] : 50

Rated Output Power[W] : 9000 10000 : 14.3 Max. Output Curr. [Aa.c.] 15.9 : [-0.80, 0.80] Power Factor

continued on page 0023

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0023

Ihr Zeichen Client Reference

Qingying Cui

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

01-Kese-50166775 014

18.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1419049315

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0022 continuation

Type Designation: S5-GR3P5K-LV S5-GR3P6K-LV S5-GR3P10K-LV

Vmax PV [Vd.c.]

: 1100 Isc PV [Ad.c.] : 25/25 25/25 50/50

MPP Voltage Range[Vd.c.] : 160-500

: 16/16 Max. Input Current[Ad.c.] 16/16 32/32

Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 3/N/PE, 208/220/240 V

Rated Output Freq.[Hz] : 50/60

6000 10000 Rated Output Power[W] : 5000 16.7 28.8 Max. Output Curr. [Aa.c.] : 14.4

: [-0.80, 0.80] Power Factor

continued on page 0024

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0024

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Kese-50166775 014

18.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1419049315 Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0023 continuation

Type Designation : S5-GR3P8K-BE S5-GR3P10K-BE

Vmax PV [Vd.c.] : 1100
Isc PV [Ad.c.] : 50/50
MPP Voltage Range[Vd.c.] : 160-1000
Max. Input Current[Ad.c.] : 32/32
Overvoltage Category (OVC) : II for PV

Rated Output Volt.[Va.c.] : 3/N/PE, 230/400 V

Rated Output Freq.[Hz] : 50

Rated Output Power[W] : 8000 10000
Max. Output Curr.[Aa.c.] : 12.7 15.9
Power Factor : [-0.80, 0.80]

continued on page 0025

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety



10/000 til 01.06 - TUV, TUEV and TUV are registered tradomarks. Utilisation and application regures error upprove

Certificate



Zertifikat Nr. Certificate No. R 50384315

Blatt Sheet 0025

Ihr Zeichen Client Reference

Qingying Cui

Unser Zeichen Our Reference

01-Kese-50166775 014

Ausstellungsdatum 18.08.2021 Date of Issue

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1419049315 Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0024 continuation

Protective Class : Class I Ingress Protection (IP) : IP66 Pollution Degree (PD) : PD3

Operating Temperature [°C]: -25 to 60 (> 45 derating)

Type of Inverter : Non-isolated

Remark(s):

The installation has to be carried out according to the attached installation instruction.

Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com Fax: +49 221 806-3935 http://www.tuv.com/safety







Solis 3P 4G Three Phase Inverter

- Solis 4G Three Phase Range
- ▶ 160V-850V MPPT voltage range-ultra low startup
- ▶ Dual MPPT design with precise MPPT algorithm
- ► THDi<1.5%, low harmonic distortion against grid
- ▶ Over 98.7% Max.efficiency
- ▶ RS485, WiFi/LAN/GPRS (optional) interface
- ▶ Multiple protections levels
- ▶ WiFi monitoring available-iphone and android app available
- ▶ 5 years standard warranty, 20 years optional upgrade



Model:

220V Solis-3P5K-4G-LV Solis-3P6K-4G-LV

400V Solis-3P5K-4G Solis-3P6K-4G Solis-3P8K-4G

Solis-3P9K-4G Solis-3P10K-4G

Features:



IP65

160-850 ———— MPPT voltage range AFCI
Optional

WiFi/GPRS
———
Real time
monitoring



,

Datasheet

Proof Score	Model	Solis-3P5K-4G-LV	Solis-3P6K-4G-LV	Solis-3P5K-4G	Solis-3P6K-4G	Solis-3P8K-4G	Solis-3P9K-4G	Solis-3P10K-4G		
Max. OC Plant power (1977)										
Max 100 play along 4000 pt										
Start of control of		6	7.2	6	7.0	0.6	10.9	12		
## The Province of The Provin		0	7.2	0		9.6	10.6	12		
Mate										
MATE (INFER INTERNAL PROPERTY OF THE PROPERTY										
Nome of Summary (Appendix Note) Summa		160-	-500			160-850				
Control S 6 0 0 0 0 0 0 1 0 0 1 0 1 0 0 1 0 1 1 0 1<	Max. input current per MPPT(A/B)				11A+11A					
Max design provide Wigner Wig	MPPT number/Max input strings number				2/2					
Max dependent quity promity (N)	Output Side (AC)									
No. audint principally (V) 6.5.6 6.5.6 6.5.6 6.5.6 9.5.9 9.5.9 1.1.	Rated output power(kW)	5	6	5	6	8	9	10		
Raved grift enquency	Max. apparent output power(kVA)	5.5	6.6	5.5	6.6	8.8	9.9	11		
Pare dig diff fiquency (1) 1 1 1 1 1 1 1 1 1	Max. output power(kW)	5.5	6.6	5.5	6.6	8.8	9.9	11		
Operation phase ———————————————————————————————————	Rated grid voltage(V _{LL})	208/2:	20/240			400				
Read girld output current[3] 00 19.1 19.1 19.7 19.7 19.8 19.8 19.8 19.8 19.8 19.8 19.8 19.8	Rated grid frequency(Hz)				50/60					
Note on place of the contribution of the cont	Operation phase				Three					
Power Factor (at rated output power)	Rated grid output current@400V	13.1	15.7	7.2	8.7	11.5	13.0	14.4		
Power Factor (af rated edingst power)	Max. output current(A)	14.4	16.7	7.9	9.5	12.7	14.3	15.9		
Tribin	, , ,							_		
DC injection current 40,55/15 Grid requenty range (Hz) 47-52 or 57-82 Miss, afficiency 98,0% 98,3% 98,7% EU efficiency 99,0% 97,8% 98,7% EU efficiency 598,7% MPT Pridicatory Protection Protection Protection Protection Protection Output over current protection				0.0		3				
Britany 47-52 or 57-82* Encomy 180 mg/s 98.0% 98.0% 98.0% 98.0% 98.0% 98.1% 180 mg/s 98.0% 98.1% 180 mg/s 99.5% 180 mg/s 99.5% 180 mg/s 99.5% 180 mg/s 99.1% 180 mg/s 180 mg/s <th colspan<="" td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></th>	<td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>									
Efficiency 98.9% 98.3% 98.7% Unificiency 98.9% 97.9% 98.1% MPPT officiency 595.5% 98.1% MPPT officiency ************************************	·									
Max. officiency 98.0% 98.3% 98.7% February February February Converse-polarity protection Or reverse-polarity protection Output over current protection Output over current protection Colspan="4">					47-32 01 37-62					
EU efficiency 97.9% 97.8% 98.5% Protection DC reverse-polarity protection "Yes "Yes Short circuit protection "Yes "Yes Output over vortrapt protection "Yes "Yes Output over vortrapt protection "Yes "Yes Output over vortrapt protection "Yes "Yes Residual current detection "Yes "Yes Surge protection "Yes "Yes Surge protection "Yes "Yes Islanding protection "Yes "Yes Islanding protection "Yes "Yes Islanding protection "Yes "Yes Islanding protection "Yes "Yes Integrated DC switch "Yes "Yes Weight (Yes) 14.1 13.6 14.1 Topology "Yes "Yes Self consumption (mght) "Yes "Yes Self consumption (mght) "Yes "Yes Operating melion "Yes "Yes <td></td> <td></td> <td>0.01</td> <td></td> <td></td> <td>l</td> <td>00.70/</td> <td></td>			0.01			l	00.70/			
MPPT efficiency >99,5% Protection Concevers-polarity protection DC reverse-polarity protection Yes Output over current protection Yes Output over vorlage protection Yes Insulation existance monitoring Yes Residual current dection Yes Surge protection Yes Islanding protection Yes	·									
Protection Yes Short certury protection Yes Output over current protection Yes Output over current protection Yes Output over vidage protection Yes Insulation resistance monitoring Yes Residual current detection Yes Surge protection Yes Integrated DC switch Yes Integrated DC switch Yes Penegrature protection Yes Integrated DC switch Yes Penegrature protection Yes Weight Mgh 14.1 13.6 14.1 Weight Mgh 14.1 13.6 14.1 Yeight Consumption (right) 14.1 13.6 14.1 Yeiges protection Yes Yes Yeiges protection Yes Yes Yeiges protection (right) Yes Yes Yeiges protection (right) Yes Yes Yeiges protection Yes Yes Yeiges protection Yes Yes Yeiges p		97.	.5%	97			98.1%			
DC reverse-polarity protection Yes Output over current protection Yes Output over varitage protection Yes Insulation resistance monitoring Types Residual current defection Types Surge protection Types Islanding protection Types Islanding protection Types Integrated DC switch Types Integrated DC switch Types Integrated DC switch Types Pulled State Types Integrated DC switch Types Integrated DC switch Types Integrated DC switch Types Meleghtikgh 18.1 Meleghtikgh 18.1 Topology Types Selection (night) Types Operating ambient temperature range Types Oblige consept Types Molse emission (hybrida) Types	·				>99.5%					
Short circuit protection Yes Output over voltage protection Yes Insulation resistance on lotering Yes Insulation resistance on lotering Yes Surge protection Yes Surge protection Yes Inlanding protection Yes Temperature protection Yes Inlagrade DC Switch Yes Other Indig Yes Policy Indig Yes Messign Might Yes Weight (kg) 14.14.1 Yes Yes Self colsumption (night) Yes Yes Yes Yes <td col<="" td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></td>	<td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>									
Output over current protection Yes Output over voltage protection 19 yes Insulation resistance monitoring 19 yes Residual current detection 19 yes Surge protection 19 yes Islanding protection 19 yes Integrature protection 19 yes Integrated DC switch 19 yes 10 yes	DC reverse-polarity protection				Yes					
Output over voltage protection Yes Insulation resistance monitoring Yes Residual current detection Yes Surge protection Yes Islanding protection Yes Islanding protection Yes Integrated DC switch Optional Megrated DC switch Optional Megrated DC switch Optional Dimensions(min) Optional Megrated DC switch Optional Megrated DC switch Optional Megrated DC switch Optional Megrated DC switch Optional Megrated DC switch Megrated DC switch Optional Megrated DC switch Optional Megrated DC switch Megrated DC switch <t< td=""><td>Short circuit protection</td><td></td><td></td><td></td><td>Yes</td><td></td><td></td><td></td></t<>	Short circuit protection				Yes					
Insulation resistance monitoring Yes Residual current detection Yes Surge protection Yes Islanding protection Yes Temperature protection Type Integrated DC switch Optional Dimensions(Irm) Meight(kg) 14.1 130W*538H*158 Weight(kg) 14.1 13.0W*538H*158 Self consumption (night) 14.1 13.0W*538H*158 Self consumption (night) 14.1 13.0W*538H*158 14.1 </td <td>Output over current protection</td> <td></td> <td></td> <td></td> <td>Yes</td> <td></td> <td></td> <td></td>	Output over current protection				Yes					
Residual current detection Yes Surge protection Yes Islanding protection Yes Temperature protection Types Integrated DC switch September 1988 Dimensions(mn) September 1988 Weight(kg) 14.1 13.6 14.1 Topology Transformerless Self consumption (night) 1965 Ingress protection 1965 Ingress protection 1965 Use centision(typical) 1965 Coling concept Natural convection Max operation altitude 1965 Grid connection standard 1965 Safetyle humidity 1965 Safetyle Network 1965 Postures 1965 Features 1965 Geometion 1965 Connection 1965 Connection 1965	Output over voltage protection				Yes					
Surge protection Yes Islanding protection Yes Temperature protection Temperature protection Integrated DC switch Optional Central Data Dimensions(mm) Surgetive (Might) Weight(kg) 14,1 13.6° months (Might) 14,1 13.6° months (Might) 14,1 14,1 18,2 18,	Insulation resistance monitoring				Yes					
Islanding protection Yes Temperature protection Yes Integrated DC switch Optional Ceneral Data Selected DC switch Dimensions(mm) Selection (light) Transformetzare range Selection (light) Postetion (light) Notice emission(typical) Notice emission(typical) Natural convection Max. operation allitude Designate lifetime Selection allitude	Residual current detection				Yes					
Temperature protection Yes Integrated DC switch Comeral Data Dimensions(mm) 310W*538H*158D* Weight(kg) 14.1 13.6 14.1 Topology Transformerlass Self consumption (right) Comession(right) Comession(typical) Transformerlass Noise emission(typical) Types	Surge protection				Yes					
General Data Optional Dimensions(mm) 310W*538H*158E Weight(kg) 14.1 13.6 14.1 Topology Transformerless Self consumption (night) Clear to sumption (night) Operating ambient temperature range IP65 Noise emission(typical) Transformerless Cooling concept Natural convex Max.operation altitude Transformerless Grid connection standard En50438, 659/3, A84777, VDE012-1-1, IEC61727 Relative humidity Clear to 100% Safety/EMC standard En50438, 659/3, A84777, VDE012-1-1, IEC61727 Features Preserves DC connection MC-4 mateable AC connection Terminal connectors Display LCD,2×20 Z. Communication connections 4 pins R\$485 connections	Islanding protection				Yes					
General Data January 538H*158D Dimensions(mm) January 538H*158D Weight(kg) 14.1 13.6 14.1 Topology Transformerless Self consumption (night) Caption (Night) Operating ambient temperature range 1P65 Ingress protection IP65 Noise emission(typical) Natural convection Max. operation altitude Natural convection Max. operation altitude 1 August al Convection Grid connection standard En50438, G59/3, AS4777, VDE0125-1-1, IEC61727 Relative humidity 0 -100% Safety/EMC standard IEC62109-1/-2, AS31077, VDE0125-1-1, IEC61727 Features DC connection MC-4 mateable AC connection MC-4 mateable AC connection Terminal connectors Display LCD,2×20 Z. Communication connections 4 pins R5485 connections	Temperature protection				Yes					
Dimensions(mm) 310W*538H*158U Weight(kg) 14.1 13.6 14.1 Topology Transformerless Self consumption (night)	Integrated DC switch				Optional					
Weight(kg) 14.1 13.6 14.1 Topology Transformerless Self consumption (night) <	General Data									
Topology Transformerless Self consumption (night) < 1W(Night)	Dimensions(mm)				310W*538H*158D					
Self consumption (night) <1W(Night)	Weight(kg)	1	4.1	1	3.6		14.1			
Self consumption (night) <1W(Night)					Transformerless					
Operating ambient temperature range -25-60°C Ingress protection IP65 Noise emission{typical} <30 dBA										
Ingress protection IP65 Noise emission{typical} <30 dBA										
Noise emission{typical} < 30 dBA Cooling concept Natural convection Max.operation altitude 4000m Designed lifetime > 20 years Grid connection standard En50438, G59/3, AS4777, VDE0126-1-1, IEC61727 Relative humidity 0~100% Safety/EMC standard IEC62109-1/-2, AS3100 Features DC connection MC-4 mateable AC connection Terminal connectors Display LCD,2×20 Z. Communication connections 4 pins RS485 connector										
Cooling concept Max.operation altitude Designed lifetime Fedures DC connection AC connection AC connection Designed lifetime AC connection Communication connections Ac munication connections Ac material connection Ac munication connections Ac munication connections Ac munication connections Ac munication connections Ac connection Ac munication connections Ac munication connectio										
Max.operation altitude Designed lifetime Crid connection standard En50438, G59/3, AS4777, VDE0126-1-1, IEC61727 Relative humidity Safety/EMC standard DC connection DC connection AC connection Display Communication connections 4000m 4000m A000m A000m En50438, G59/3, AS4777, VDE0126-1-1, IEC61727 A0100m IEC62109-1/-2, AS3100 MC-4 mateable AC connection Terminal connectors LCD,2×20 Z. Communication connections										
Designed lifetime >20 years Grid connection standard En50438, G59/3, AS4777, VDE0126-1-1, IEC61727 Relative humidity 0~100% Safety/EMC standard IEC62109-1/-2, AS3100 Features DC connection MC-4 mateable AC connection Terminal connectors Display LCD,2×20 Z. Communication connections 4 pins RS485 connector										
Grid connection standard En50438, G59/3, AS4777, VDE0126-1-1, IEC61727 Relative humidity Safety/EMC standard IEC62109-1/-2, AS3100 Features DC connection MC-4 mateable AC connection Terminal connectors Display LCD,2×20 Z. Communication connections										
Relative humidity Safety/EMC standard IEC62109-1/-2, AS3100 Features DC connection AC connection Display Communication connections A pins RS485 connector				E-50406 05-11		0.4.4.15.00:				
Safety/EMC standard Features DC connection AC connection Display Communication connections Display DECEDITION OF Terminal connectors A pins RS485 connector				En50438, G59/3		ь-1-1, IEC61727				
Features MC-4 mateable DC connection MC-4 mateable AC connection Terminal connectors Display LCD,2×20 Z. Communication connections 4 pins RS485 connector	<u> </u>									
DC connection MC-4 mateable AC connection Terminal connectors Display LCD,2×20 Z. Communication connections 4 pins RS485 connector				IE	C62109-1/-2, AS31	00				
AC connection Terminal connectors Display LCD,2×20 Z. Communication connections 4 pins RS485 connector	Features									
Display LCD,2×20 Z. Communication connections 4 pins RS485 connector	DC connection				MC-4 mateable					
Communication connections 4 pins RS485 connector	AC connection				Terminal connector	S				
	Display				LCD,2×20 Z.					
Warranty 5 years standard (extend to 20 years)	Communication connections			4	pins RS485 connec	tor				
	Warranty			5 years	standard (extend to	20 years)				

3P 4G 10kW 20kW



Solis 3P 4G Three Phase Inverter

- ▶ Solis 4G Three Phase Range
- ▶ 160V-850V MPPT voltage range-ultra low startup
- ▶ Dual MPPT design with precise MPPT algorithm
- ► THDi<1.5%, low harmonic distortion against grid
- ▶ Over 98.7% Max.efficiency
- ▶ RS485, WiFi/LAN/GPRS (optional) interface
- ▶ Multiple protections levels
- ▶ WiFi monitoring available-iphone and android app available
- ▶ 5 years standard warranty, 20 years optional upgrade



Model:

220V Solis-3P10K-4G-LV

400V Solis-3P12K-4G Solis-3P15K-4G Solis-3P17K-4G Solis-3P20K-4G

Features:



IP65

Weight ——— 18.9kg AFCI —— Optional WiFi/GPRS —— Real time monitoring



9

Datasheet

Model	Solis-3P10K-4G-LV	Solis-3P12K-4G	Solis-3P15K-4G	Solis-3P17K-4G	Solis-3P20K-4G						
Energy Source	30115-3F 10K-4G-LV	3011S-3F 12K-4G	PV	30115-3F 17 K-4G	3011S-3F20K-4G						
Input Side(DC)			1 V								
Max. DC input power(kW)	12	14.5	18	20.4	24						
Max. DC input voltage(V)	12	14.0	1000	20.4	24						
Start-up voltage(V)			180								
MPPT_voltage range(V)	160-500 160-850										
Max. input current per MPPT(A/B)	100-300			-000							
MPPT number/Max input strings number		22A+22A 2/4									
Output Side (AC)			2/4								
Rated output power(kW)	10	12	15	17	20						
Max. apparent output power(kVA)	11	13.2	16.5	18.7	22						
Max. output power(kW)	11	13.2	16.5	18.7	22						
Rated grid voltage(V _{LL})	208/220/240	13.2		00	22						
Rated grid frequency(Hz)	208/220/240			JU							
Operation phase			50/60								
	00.0	47.0	Three	04.0	00.0						
Rated grid output current@400V Max. output current(A)	26.2	17.3	21.7	24.6	28.9						
· · · · · · · · · · · · · · · · · · ·	28.8	19.1	23.8	27	31.8						
Power Factor (at rated output power)			0.8 leading 0.8 lagging								
THDi			<1.5%								
DC injection current(mA)			<0.5%In								
Grid frequency range(Hz)			47-52 or 57-62								
Efficiency											
Max.efficiency	98.0%			7%							
EU efficiency	97.5%			1%							
MPPT efficiency			>99.5%								
Protection											
DC reverse-polarity protection			Yes								
Short circuit protection			Yes								
Output over current protection			Yes								
Output over voltage protection			Yes								
Insulation resistance monitoring			Yes								
Residual current detection			Yes								
Surge protection			Yes								
Islanding protection			Yes								
Temperature protection			Yes								
Integrated DC switch			Optional								
General Data			2401415201152425								
Dimensions(mm)	10.0		310W*563H*219D		0.0						
Weight(kg)	19.8	1	8.9	1	9.8						
Topology Solf consumption (pight)			Transformerless								
Self consumption (night)			<1W(Night)								
Operating ambient temperature range			-25°C~60°C								
Ingress protection			IP65								
Noise emission{typical}			<30 dBA								
Cooling concept		In	telligent redundant fan-cooli	ng							
Max.operation altitude			4000m								
Designed lifetime			>20 years	4 15004707							
Grid connection standard		En50438, G	659/3, AS4777, VDE0126-1-	1,1EU61/2/							
Relative humidity			0~100%								
Safety/EMC standard			IEC62109-1/-2, AS3100								
Features			No. 1								
DC connection			MC-4 mateable								
AC connection			Terminal connectors								
Display			LCD,2×20 Z.								
Communication connections			4 pins RS485 connector								
Warranty		5 years standard (extend to 20 years)									



Solis Three PV Inverter

- ► Three phase output
- Over 98.8% Max. effciency
- 200V- 1000V input voltage range
- ▶ 7.0" LCD color screen display
- Four MPPT design with precise MPPT algorithm
- Compact and light design, easy installation
- ▶ IP65 rated for outdoor installation
- RS485, WiFi/GPRS (optional) interface
- Anti-resonance, single transformer can connect
 6M+ in parallel
- ▶ WiFi and monitoring app available
- 5 years standard warranty, 20 years optional upgrade



Model:

220V Solis-15K-LV Solis-20K-LV

400V Solis-20K Solis-25K Solis-30K Solis-33K

480V Solis-36K-HV Solis-40K-HV

Features:



Four MPPT

7" _____ WiFi/GPRS

Real time
monitoring



IP65

Datasheet

Model	Solis-15K-LV	Solis-20K-LV	Solis-20K	Solis-25K	Solis-30K	Solis-33K	Solis-36K-HV	Solis-40K-HV			
Energy Source			PV								
Input Side(DC)											
Max. DC input power(kW)	18	24	24	30	36	40	43	48			
Max. DC input voltage(V)				10							
Start-up voltage(V)				35							
MPPT voltage range(V)				200-							
Max. input current per MPPT(A/B/C/D)	20A+20A 18A+18A+18A										
MPPT number/Max input strings number		2/4 4/8									
Output Side (AC)											
Rated output power(kW)	15	20	20	25	30	33	36	40			
Max. apparent output power(kVA)	15	20	22	27.5	33	33	40	44			
Max. output power(kW)	15	20	22	27.5	33	33	40	44			
Rated grid voltage(V _{LL})		20		40				30			
Rated grid frequency(Hz)		20		50			1				
Operation phase											
Rated grid output current@400V	20.4	52.5	28.7	Thi		47.0	42.2	40.1			
Max. output current(A)	39.4	52.5		36.1 41.7	43.3	47.8	43.3	48.1 53			
	39.4	52.5	33.3		0.8 lagging	50	47.8	55			
Power Factor (at rated output power) THDi				0.8 leading .							
					%						
DC injection current(mA)					%In						
Grid frequency range(Hz)				47 - 52 c	r 57 - 62						
Efficiency											
Max.efficiency		.0%		98.6%		98.7%	98.				
EU efficiency	96	.5%		98.3%		98.3%	98.	4%			
MPPT efficiency				>99	.9%						
Protection											
DC reverse-polarity protection				Ye	es						
Short circuit protection				Ye	es						
Output over current protection				Ye	es						
Output over voltage protection				Ye	es						
Insulation resistance monitoring				Ye	es						
Residual current detection				Ye	es						
Surge protection				Ye	es						
Islanding protection				Ye	es						
Temperature protection				Ye	es						
Integrated DC switch				Opti	onal						
General Data											
Dimensions(mm)				530W*700	H*356.5D						
Weight(kg)	58	8.2	57.2			58.2					
Topology				Transfo	merless						
Self consumption (night)				<1W(Night)						
Operating ambient temperature range				-25~	60℃						
Ingress protection				IP	65						
Noise emission{typical}				<30	dBA						
Cooling concept				Natural c	onvection						
Max.operation altitude				400	10m						
Designed lifetime				>20 y	rears						
Grid connection standard			EN50438	3, G59/3, AS4777	VDE0126-1-1, I	EC61727					
Relative humidity				0~1	00%						
Safety/EMC standard			IEC62109	9-1/-2, AS3100, E	N61000-6-1, EN	61000-6-3					
Features											
DC connection				MC-4 m	ateable						
AC connection				Terminal o	onnectors						
Display				7.0"LCD color	screen display						
Communication connections			4 pii	ns RS485 connect		ector					
			_	years standard (e		`					



Solis-(40-60)K, Solis-(50-70)K-HV

Solis Three Phase Inverters



Features:

- ► Over 99% Max. effciency
- ► Wide voltage range and low startup voltage
- ▶ 4 MPPT input, each rated current is 22A/28.5A, compatible with high power module
- ► THDi<3%, low harmonic distortion against grid
- ► Anti-resonance, Supporting over 6MW parallelled in one transformer
- ▶ Perfect commercial site monitoring solution
- ► Intelligent redundancy fan





Model:

400V: Solis-40K Solis-50K Solis-60K-4G 480V: Solis-50K-HV Solis-60K-HV Solis-70K-HV-4G



Datasheet						
Model Name	Solis-40K	Solis-50K	Solis-50K-HV	Solis-60K-HV	Solis-60K-4G	Solis-70K-HV-4G
Input DC						
Max. input power	48kW	60kW	60kW	72kW	72kW	84kW
Max. input voltage			1100	0V		
Rated voltage	600V	600V	720V	720V	600V	720V
Start-up voltage			200	١V		
MPPT voltage range			200-10	000V		
Max. input current	4*22A	4*28.5A	4*22A		4*28.5A	
Max. Short Circuit current	4*34.3A	4*44.5A	4*34.3A		4*44.5A	
MPPT number/Max. input strings number	4/8	4/12	4/8		4/12	
Output AC						
Rated output power	40kW	50kW	50kW	60kW	60kW	70kW
Max. apparent output power	44kVA	55kVA	55kVA	66kVA	66kVA	77kVA
Max. output power	44kW	55kW	55kW	66kW	66kW	77kW
					3/N/PE,	
Rated grid voltage	3/N/PE, 220/3	880V, 230/400V	3/PE, 4	480V	220/380V, 230/400V	3/PE, 480V
Rated grid frequency			50Hz/6	60Hz		
Rated grid output current	60.8A/58A	76.0A/72.2A	60.2A	72.2A	91.2A/86.6A	84.2A
Max. output current	66.9A	83.3A	66.2A	80A	100A	92.6A
Power Factor		>0.9	99 (Adjustable from 0.8	8 leading to 0.8 lagg	ging)	
THDi			<39	%		
Efficiency						
Max. efficiency	98.	8%	99.0	1%	99.0	%
EU efficiency	98.	4%	98.7	" %	98.5	%
Protection						
DC reverse-polarity protection			Yes	S		
Short circuit protection			Yes	S		
Output over current protection			Yes	S		
Surge protection (DC/AC)			Yes	S		
Grid monitoring			Yes	S		
Anti-Islanding protection			Yes	S		
Temperature protection			Yes	s		
Integrated DC switch			Optio	onal		
General Data			·			
Dimensions (W*H*D)			630mm*700m	nm*357mm		
Weight	61kg	63kg	61kg		63kg	
Topology		Ü	Transforr	merless	Ü	
Self consumption			<1W (N	light)		
Operating ambient temperature range			-25~6			
Relative humidity			0~10			
Ingress protection			IP6			
		Intelligent				
Cooling concept	Natural convection	redundant fan-cooling	Natural convection	Intell	igent redundant fan-co	oling
Max. operation altitude			4000)m		
Grid connection standard			V 0124, VDE V 0126-1-1 2, RD 1699, UNE 20600			
Safety/EMC standard			IEC 62109-1/-2, IEC621	116, EN 61000-6-2/-	4	
Features						
DC connection			MC	4		
AC connection			OT Terminal	connectors		
Display			LCD, 2×	<20 Z.		
Communication			RS485; WiFi/GP	RS (optional)		



Certificate Number: AZ 69023047

Page: 0001

CERTIFICATE OF SUITABILITY

Authorised marking:

TUV023047E

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards. the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER: Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai. (seafront), Industrial Park,

Xiangshan Ningbo, Zhejiang 315712

P. R. China

DESCRIPTION OF EQUIPMENT

Declared class: Non-declared

Grid-Connected PV Inverter Product:

Trade Name / Manufacturer: Ginlong

Model Number: Solis-3P5K-4G-AU; Solis-3P6K-4G-AU; Solis-3P8K-4G-AU;

Solis-3P9K-4G-AU; Solis-3P10K-4G-AU; Solis-3P12K-4G;

Solis-3P15K-4G; Solis-3P17K-4G; Solis-3P20K-4G.

(Ratings info refer to CONTINIATION SHEET 1 - 2). Ratings:

Standard: AS/NZS 4777.2:2015

> IEC 62109-1:2010 IEC 62109-2:2011

Issue Date: 02/10/2018 Expiry Date: 02/10/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

IAS-ANZ

Acc. No. 22870404AA www.jas-enz.org/register

Billy Chu

TUV Prestrand Australia Phy Ltd 182 Dougharty Road, Helselberg West VIC 3051 Phone: +61 (3) 9450 1400 Email certification@au.tuv.com Website www.inches.com



Certificate Number:

AZ 69023047

Page: 0002

CERTIFICATE OF SUITABILITY

Authorised marking:

TUV023047E

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Ratings information:

For all models:

Output voltage: 230/400Va.c., 3/N/PE, 50/60Hz, three-phase;

Class I, IP65, PD3, Transformerless;

Operating Temp.: -25°C to 60°C (>45°C derating); Overvoltage Category (OVC) for AC output: III;

Maximum input voltage: 1000Vd.c., Independent MPPT: 2;

MPPT Voltage: 160-850Vd.c.;

Overvoltage Category (OVC) for PV output: II.

For model Solis-3P5K-4G-AU:

Input: Imax: 22+11A, I(s.c.) input: 34.3+17.2Ad.c.;

Output: Pn: 5000W, Apparent Power: 5500VA, Imax: 7.9A.

For model Solis-3P6K-4G-AU:

Input: Imax: 22+11A, I(s.c.) input: 34.3+17.2Ad.c.;

Output: Pn: 6000W, Apparent Power: 6600VA, Imax: 9.5A.

For model Solis-3P8K-4G-AU:

Input: Imax: 22+22A, I(s.c.) input: 34.3+34.3Ad.c.;

Output: Pn: 8000W, Apparent Power: 8800VA, Imax: 12.7A.

For model Solis-3P9K-4G-AU:

Input: Imax: 22+22A, I(s.c.) input: 34.3+34.3Ad.c.;

Output: Pn: 9000W, Apparent Power: 9900VA, Imax: 14.2A.

Issue Date: 02/10/2018 Expiry Date: 02/10/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

C

Acc. No. Z2870404AA www.joo-anz.org/register

TUV Rheinland Australia Phy Ltd 182 Dougharty Road, Heidelberg West VIC 3081 Phone: +61 (3) 9450 1400

Email: peralitation@autus.com Website: prev.tu.fuv.com Billy Chu



Certificate Number: AZ 69023047

Page: 0003

CERTIFICATE OF SUITABILITY

Authorised marking:

TUV023047E

CONTINUATION SHEET 2

DESCRIPTION OF EQUIPMENT

Ratings information:

For model Solis-3P10K-4G-AU:

Input: Imax: 22+22A, I(s.c.) input: 34.3+34.3Ad.c.;

Output: Pn: 10000W, Apparent Power: 11000VA, Imax: 15.9A.

For model Solis -3P12K-4G:

Input: Imax: 22+22A, I(s.c.) input: 34.3+34.3Ad.c.;

Output: Pn: 12000W, Apparent Power: 13200VA, Imax: 19.1A.

For model Solis -3P15K-4G:

Input: Imax: 22+22A, I(s.c.) input: 34.3+34.3Ad.c.;

Output: Pn: 15000W, Apparent Power: 16500VA, Imax: 23.8A.

For model Solis -3P17K-4G:

Input: Imax: 22+22A, I(s.c.) input: 34.3+34.3Ad.c.;

Output: Pn: 17000W, Apparent Power: 18700VA, Imax: 27.0A.

For model Solis -3P20K-4G:

Input: Imax: 22+22A, I(s.c.) input: 34.3+34.3Ad.c.;

Output: Pn: 20000W, Apparent Power: 22000VA, Imax: 31.8A.

Issue Date: 02/10/2018 Expiry Date: 02/10/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

Billy Chu

Acc. No. 22570404AA www.jas-ank.org/register

THE REAL PROPERTY AND ADDRESS OF THE PARTY O

CERTIFICATE



of Conformity

Registration No.:

AK 50421012 0001

Report No .:

50171233 001

Holder:

Ningbo Ginlong technologies

Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo, Zhejiang 315712

P. R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation : Solis-3P5K-4G Solis-3P6K-4G

Solis-3P9K-4G Solis-3P8K-4G Solis-3P10K-4G Solis-3P12K-4G Solis-3P15K-4G Solis-3P17K-4G

Solis-3P20K-4G

Serial Number : Engineering Samples

Pirmware version : V18

: Refer to report 50171233 001 for details. Remark(s)

Tested acc. to:

IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of ANDV Bheinland mark of conformity.

Date

24.10.2018

Weichun Li

Certification Bod

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



Ningbo Ginlong technologies Co.,

Ltd.

Zhang Kun

: 25.10.2018 Our ref. : QJL 01

Your ref .: Kun Zhang

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo, Zhejiang 315712 P. R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AK 50421012 0001

Report No. : 50171233 001

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

CC: Ningbo Ginlong technologies

Enclosure

Certificate



Zertifikat Nr. Certificate No. R 50331629

Blatt Page 0001

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

52109827

01-DJW-15083814 001

26.02.2016

(day/mo/yr)

Genehmigungsinhaber License Holder

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

(seafront) industrial Park, Xiangsha (seafront) industrial Park, Xiangshan Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

No.57 Jintong Road, Binhai,

Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Bayart geprüft Sicherheit Regelmäßige überwachung

www.tuv.com

Geprüft nach Tested acc. to

IEC 62109-1:2010

IEC 62109-2:2011

EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

12

PV-Wechselrichter (Grid-connected PV Inverter)

Type Designation

: Solis-20K URE-20K GCI-20K-W

Solapowa-20K Soltaro-20K

: 1000 Vmax PV [Vd.c.]

: 23.4/23.4/23.4/23.4 Isc PV [Ad.c.]

: 200-800 MPP Voltage Range[Vd.c.] Max. Input Current[Ad.c.] : 18/18/18/18 Overvoltage Category (OVC) : II for PV

Rated Output Voltage[Va.c.]: 3~400 Rated Output Frequency[Hz] : 50 Rated Output Power[kW] Max. Output Current[Aa.c.] : 33.3

: [-0.80, 0.80] Power Factor Overvoltage Category (OVC) : III for AC mains

continued on page 0002

12

ANLAGE (Appendix): 1

Dem Zertistkat liegt unsere Prüf- und Zertistzerungsordnung zugrunde und es bestätigt die Konformitat des Produktes mit den oben genannten Standards und Prüfgrundlagen Zusätzliche Anforderungen in Landern, in denen das Produkt in Verkehr gebracht werden soll, mussen zusätzlich hetrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standard; and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel +49 221 806-1371 e-mail. cert-validity@de tuv com

Fax +49 221 806-3935 http://www.tuv.com/safety

TINOZO 4 04:09 😻 10V, FUEV and 10V are registered trademarks. Utilisal or and adulication requires print approval.



Certificate



Zertifikat Nr. Certificate No. R 50331629

Blatt Page 0002

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

52109827

01-DJW-15083814 001

26.02.2016

(day/mo/yr)

Genehmigungsinhaber License Holder

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

(seafront) industrial Park, Xiangsha (seafront) industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

No.57 Jintong Road, Binhai,

Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsgnudoswiedű

www.tuv.com 1D 1419032012

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011

EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) (Product Identification) Certified Product

Lizenzentgelte - Einheit License Fee - Unit

5

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001

Continuation

: Solis-25K URE-25K GCI-25K-W Type Designation Solapowa-25K Soltaro-25K

: 1000 Vmax PV [Vd.c.]

: 23.4/23.4/23.4/23.4 Isc PV [Ad.c.]

: 200-800 MPP Voltage Range[Vd.c.] Max. Input Current[Ad.c.] : 18/18/18/18 Overvoltage Category (OVC) : II for PV

Rated Output Voltage[Va.c.]: 3~400 Rated Output Frequency[Hz] : 50 Rated Output Power [kW] Max. Output Current[Aa.c.] : 41.7

: [-0.80, 0.80] Power Factor Overvoltage Category (OVC) : III for AC mains

continued on page 0003

5

ANLAGE (Appendix): 1

Dem Zertisikat liegt unsere Prus- und Zertisizerungsordnung zugrunde und es bestatigt die Konformität des Produktes mit den oben genannten Standards und Prusgrundlagen. Zusätzliche Anforderungen in Landern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusatzlich bewachtet werden. Die Herstellung des zertisszierten Produktes wird überwacht This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel +49 221 806-1371 e-mail.cert-validity@de tuv com

Fax +49 221 806-3935 http://www.tuv.com/safety 10,020 d. 04.08 B TUV, TEPV and TUV are registered tracemarks. Utilisation and application requires panel approval.



Certificate



Zertifikat Nr. Certificate No. R 50331629

Blatt Page 0003

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

52109827

01-DJW-15083814 001

26.02.2016

(day/mo/yr)

Genehmigungsinhaber License Holder

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

(seafront) industrial Park, Xiangsha (seafront) industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Bauart gepruft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1419032012

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001

Continuation

: Solis-30K URE-30K GCI-30K-W Type Designation Solapowa-30K Soltaro-30K

; 1000 Vmax PV [Vd.c.]

: 23.4/23.4/23.4/23.4 Isc PV [Ad.c.]

: 200-800 MPP Voltage Range[Vd.c.] Max. Input Current[Ad.c.] : 18/18/18/18 Overvoltage Category (OVC) : II for PV

Rated Output Voltage[Va.c.]: 3-400 Rated Output Frequency[Hz] : 50 Rated Output Power[kW] Max. Output Current[Aa.c.] : 47.8

: [-0.80, 0.80]Power Factor Overvoltage Category (OVC) : III for AC mains

continued on page 0004

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Pruf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformitat des Produktes mit den oben genannten Standards und Prufgrundlagen Zusatzliche Anforderungen ın Landeın, ın denen das Produkt ın Yerkehr gebracht werden soll, müssen zusatzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel +49 221 806-1371 e-mail: cert-validity@de tuv.com Fax. +49 221 806-3935 http://www.tuv.com/safety

mand LGA Prog TÜVRheinland

5

10/020 di di4 dix 🔌 — TÜV, TUF V and TUV are registere) trademanta. Univoloni and application requires prior approve

Certificate



Zertifikat Nr. Certificate No. R 50331629

Blatt Page 0004

Ihr Zeichen Client Reference 52109827

Unser Zeichen Our Reference 01-DJW-15083814 001 Ausstellungsdatum 26.02.2016

Date of Issue (day/mo/yr)

Genehmigungsinhaber License Holder

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai, (seafront) industrial Park, Xiangsha (seafront) industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Bauart gepruft Sicherheit Regelmáßige Produktionsüberwachung

www.tuv.com ID 1419032012

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001

Continuation Type Designation

: Solis-36K-HV Solapowa-36K-HV URE-36K-HV Soltaro-36K-HV

: 1000

Vmax PV [Vd.c.]

: 23.4/23.4/23.4/23.4

Isc PV (Ad.c.] MPF Voltage Range[Vd.c.] Max. Input Current [Ad.c.] : 18/18/18/18

: 200-800

Overvoltage Category (OVC) : II for PV

Rated Output Voltage[Va.c.]: 3~480 Rated Output Frequency[Hz] : 50

Rated Output Power[kW] Max. Output Current [Aa.c.] : 47.8

Power Factor

: [-0.80, 0.80]

Overvoltage Category (OVC) : III for AC mains

continued on page 0005

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Pruf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformitat des Produktes mit den ohen genannten Standards und Prufgrundlagen Zusätzliche Anforderungen in Landern, in denen das Produkt in Verkehr gebracht werden soll, mussen zusatzlich betrachtet werden Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel. +49 221 806-1371 e-mail cert-validity@dc tuv.com

Fax +49 221 806-3935 http://www.tuv.com/safety



Weichun Li

Certificate



Zertifikat Nr. Certificate No. R 50331629

Blatt Page 0005

Ihr Zeichen Client Reference

52109827

Unser Zeichen Our Reference

01-DJW-15083814 001

Ausstellungsdatum 26,02,2016

Date of Issue (day/mo/yr)

Genehmigungsinhaher License Holder

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

(seafront) industrial Park, Xiangsha (seafront) industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Bauart gepruft Sicherheit Regelmäßige Produktions: übe/wachung

www.tuv.com ID 1419032012

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001 Continuation

Type Designation

: Solis-40K-HV Solapowa-40K-HV

TIRE-40K-HV Soltaro-40K-HV

Vmax PV [Vd.c.] : 1000

: 23.4/23.4/23.4/23.4 Isc PV (Ad c.)

MPP Voltage Range[Vd.c.] : 200-800 Max. Input Current[Ad.c.] : 18/18/18/18 Overvoltage Category (OVC) : II for PV

Rated Output Voltage[Va.c.]: 3~480 Rated Output Frequency[Hz] : 50 Rated Output Power[kW] Max. Output Current[Aa.c.] : 48.1

: [-0.80, 0.80] Power Factor Overvoltage Category (OVC) : III for AC mains

continued on page 0006

ANLAGE (Appendix): 1

Dem Zertsfikat liegt unsere Pruf- und Zertsfizierungsordnung zugrunde und es bestaugt die Konformität des Produktes mit den oben genannten Standards und Prufgrundlagen Zusätzliche Anjorderungen in Landern, in denen das Produkt in Verkehr gebracht werden soll, mussen zusatzlich hetrachtet werden. Die Herstellung des zeitifizierten Produktes wird überwacht This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance

TUV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel +49 221 806-1371 e-mail cert-validity@de.tuv.com Fax +49 221 806-3935 http://www.tuv.com/safety

and LGA Pro

Certificate



Zertifikat Nr. Certificate No. R 50331629

Blatt Page 0006

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

52109827

01-DJW-15083814 001

26.02.2016

(day/mo/yi)

Genehmigungsinhaber License Holder

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

Ningbo, Zhejiang 315712

P.R. China

Fertigungsstätte Manufacturing Plant

Ningbo Ginlong technologies

No.57 Jintong Road, Binhai,

(seafront) industrial Park, Xiangsha (seafront) industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Prüfzeichen Test Mark



Bauart gepruft Sicherheit Regelmäßige Produktionsuberwachung

www.tuv.com ID 1419032012

Geprüft nach Tested acc. to

IEC 62109-1:2010

IEC 62109-2:2011 EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

Lizenzentgelte - Einheit License Fee - Unit (Product Identification)

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001 Continuation

Protective Class

: IP65

Enclosure Protection (IP)

: PD 2(inside), PD3(outside) Pollution degree (PD)

Altitude [m]

: 2000

Operating Temperature [°C] : -25 to 60 (> 45 derating)

Type of Inverter

: Non-isolated

The installation has to be carried out according to the attached installation instruction.

Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

ANLAGE (Appendix): 1

Dem Zertisikat liegt unsere Prüf- und Zertisizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prufgrundlagen Zusatzliche Anforderungen in Landern, in denen das Produkt in Verkehr gebracht werden soll, mussen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel +49 221 806-1371 e-mail cert-validity@de tuv com Fax +49 221 806-3935 http://www.tuv.com/safety

Weichun Li



Ningbo Ginlong technologies Co.,

Ltd.

Zhang Kun

Date : 26.02.2016

Our ref.: DJW 01 Your ref.: 52109827

No.57 Jintong Road, Binhai, (seafront) industrial Park, Xiangshan Ningbo, Zhejiang 315712 P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : Grid-connected PV Inverter Model Designation : See Certificate

Model Designation: See Certificate Certificate No. : R 50331629 0001 Report No. : 15083814 001

Dear Zhang Kun,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

Enclosure

CERTIFICATE



of Conformity Low Voltage Directive 2014/35/EU

Registration No.:

AN 50332210 0001

Report No.:

15083814 001

Holder:

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

(seafront) industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation : Solis-20K URE-20K GCI-20K-W

Solapowa-20K Soltaro-20K

See more tpye designation in attachment 1.1

Remark

Serial Number : Engineering Sample

: Issued in conjunction with TÜV Rheinland

license R 50331629 0001-0006.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date 26.02.2016

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

(E The CE marking may be used if all relevant and effective EC Directives are complied with. (E



TÜV Rheinland LGA Products GmbH

Tillystraße 2, 90431 Nürnberg

1.1

Attachment to

Registration No.: Report No.:

AN 50332210 0001

15083814 001

Manufacturer:

Ningbo Ginlong technologies

Co., Ltd.

No.57 Jintong Road, Binhai,

(seafront) industrial Park, Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Scope:

Solis-25K URE-25K GCI-25K-W

Solapowa-25K Soltaro-25K

Solis-30K URE-30K GCI-30K-W Solapowa-30K Soltaro-30K

Solis-36K-HV Solapowa-36K-HV URE-36K-HV Soltaro-36K-HV

Solis-40K-HV Solapowa-40K-HV URE-40K-HV Soltaro-40K-HV

Cologne, 26.02.2016

Weichun Li



Ningbo Ginlong technologies Co.,

Ltd.

Zhang Kun

Date : 26.02.2016 Our ref. : DJW 01 Your ref.: 52109827

No.57 Jintong Road, Binhai, (seafront) industrial Park,

Xiangshan

Ningbo, Zhejiang 315712

P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AN 50332210 0001 Report No. : 15083814 001

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Enclosure





Attestation of Conformity

No. N8A 17 10 86470 025

Holder of Certificate: Ningbo Ginlong Technologies Co., Ltd.

No.57 Jintong Road

Binhai Industrial Park, Xiangshan

315712 Ningbo, Zhejiang

PEOPLE'S REPUBLIC OF CHINA

Product: Converter

Grid-Tied Inverter

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits, It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no .: 704091716002-00



Date, 2017-11-03





After preparation of the necessary technical documentation as well as the EU conformity declaration the required CE marking can be affixed on the product. That declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 3



2



Attestation of Conformity No. N8A 17 10 86470 025

Model(s):

Solis-40K, Solis-50K, Solis-50K-HV, Solis-60K-HV, Solapowa-40K, Solapowa-50K, Solapowa-50K-HV, Solapowa-60K-HV, Soltaro-40K, Soltaro-50K, Soltaro-50K-HV, Soltaro-60K-HV, URE-40K, URE-50K,

Parameters:

Max. input voltage:
MPP voltage range;
Max. input current:
Isc PV (absolute maximum):
Rated grid voltage:
Rated grid frequency;
Max. AC output active power:
Max. AC output apparent power:

Max. continuous output current:
Adjustable cos(Ø):
Protection class:
Degree of protection:
Overvoltage category:
Ambient temperature:

Other ratings refer to attachments.

See attachments See attachments See attachments See attachments 50/60Hz See attachments See attachments See attachments See attachments -0.8...1...+0.8

IP65 II(PV), III(MAINS) -25... + 60°C

Tested according to:

EN 62109-1:2010 EN 62109-2:2011

Page 2 of 3



Attestation of Conformity No. N8A 17 10 86470 025



Electrical ratings for various models:

Models	Solis-40K URE-40K Solapowa-40K Soltaro-40K	Solis-50K URE-50K Solapowa-50K Soltaro-50K	Solis-50K-HV Solapowa-50K- HV Soltaro-50K-HV	Solis-60K-HV Solapowa-60K- HV Soltaro-60K-HV	
PV input ratigns:					
Max. input voltage:		d.c. 1	100 V		
MPP voltage range:		d.c. 20	0-1000V		
Max. Input current:	d.c. 22*4A	d.c. 28.5*4A	d.c. 22*4A	d.c. 28.5*4A	
Isc PV (absolute maximum):	d.c. 34.3 A	d.c. 44.5 A	d.c. 34.3 A	d.c. 44.5 A	
AC output:					
Rated grid voltage:	a.c.380V	a.c.380V	a.c. 480/500V	a.c. 480/500V	
Rated grid frequency:	50/60Hz				
Max. AC output active power:	44000VV	55000W	55000W	66000W	
Max. AC output apparent power:	44000VA	55000VA	55000VA	66000VA	
Max. Continuous output current.	a.c. 66.9 A	a,c. 83,3 A	a.c. 66.2 A	a.c. 80 A	





S6-GR1P(2.5-6)K-S

Solis Single Phase Inverters

Features:

- String current up to 16A
- Integrated with zero export power control function
- Light weight with compact design for easy installation
- 2 MPPT design with precise MPPT algorithm

Models:

S6-GR1P2.5K-S / S6-GR1P3K-S S6-GR1P3.6K-S / S6-GR1P4K-S S6-GR1P4.6K-S / S6-GR1P5K-S S6-GR1P6K-S





DATASHEET

S6-GR1P(2.5-6)K-S

Models	2.5K	3K	3.6K	4K	4.6K	5K	6K
Input DC							
Recommended max. PV power	3.75 kW	4.5 kW	5.4 kW	6 kW	6.9 kW	7.5 kW	9 kW
Max. input voltage	550 V						
Rated voltage	250 V						
Start-up voltage	60 V			10	0 V		
MPPT voltage range	50-550 V			90-5	50 V		
Max. input current				16 A / 16 A			
Max. short circuit current				22 A / 22 A			
MPPT number/Max. input strings number				2/2			
Output AC							
Rated output power	2.5 kW	3 kW	3.6 kW	4 kW	4.6 kW	5 kW	6 kW
Max. apparent output power	2.5 kVA	3 kVA	3.6 kVA	4 kVA	4.6 kVA	5 kVA	6 kVA
Max. output power	2.5 kW	3 kW	3.6 kW	4 kW	4.6 kW	5 kW	6 kW
Rated grid voltage				L/N/PE, 220 V / 230			
Rated grid frequency				50 Hz / 60 Hz			
Rated grid output current	11.4 A / 10.9 A	13.6 A / 13 A	16 A / 15.7 A	18.2 A / 17.4 A	20.9 A / 20 A	22.7 A / 21.7 A	27.3 A / 26.1
Max. output current	11.4 A / 10.5 A	13.6 A	16 A	18.2 A	20.9 A 20.9 A	22.7 A	27.3 A 20.1
Power factor	11.4 A	13.0 A		(0.8 leading - 0.8 la		22.1 A	21.3 A
			~0.55		881118/		
THDi	<3%						
Efficiency	07.00/					70/	
Max. efficiency	97.3%		.3%	97.		97.7%	
EU efficiency	96.5%	96.	.6%	97.	1%	97.	1%
Protection							
DC reverse-polarity protection				Yes			
Short circuit protection				Yes			
Output over current protection				Yes			
Surge protection				Yes			
Grid monitoring				Yes			
Anti-islanding protection				Yes			
Temperature protection				Yes			
Integrated AFCI (DC arc-fault circuit protection)				Yes (1)			
Integrated DC switch				Yes			
General Data							
Dimensions (W*H*D)				330*371*161 mm			
Weight	8.2 kg	8.3	3 kg		8.9 kg		9 kg
Topology	Transformerless						
Self-consumption (night)	<1 W						
Operating ambient temperature range	-25∼+60°C						
Relative humidity	0-100%						
Ingress protection	IP66						
Cooling concept	Natural convection						
Max. operation altitude	4000 m						
Grid connection standard	G98 ⁽²⁾ or G99, VDE-AR-N 4105 / VDE V 0124, EN 50549-1, VDE 0126 / UTE C 15 / VFR:2019, RD 1699 / RD 244 / UNE 206006 / UNE 206007-1, CEI 0-21, C10/11, NRS 097-2-1, EIFS 2018.2, IEC 62116, IEC 61727, IEC60068, IEC 61683, EN 50530, MEA, PEA						
Safety/EMC standard	IEC/EN 62109-1/-2, IEC/EN 61000-6-2/-3						
Features							
DC connection	MC4 connector						
AC connection	Quick connection plug						
Display	LED + APP						
Communication	RS485, USB, Optional: Wi-Fi, GPRS						

CERTIFICATE



of Conformity

Registration No.: AK 50577679 0001

Report No.: CN23NXBZ 001

Holder: Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product: PV-Inverter

(Grid-Connected PV Inverter)

Identification: Type Designation: S6-GR1PxxK-S (xx=2.5,3,3.6,4,4.6,5,6)

Serial Number : Engineering Samples

Firmware Version: Al

Remark : Refer to report CN23NXBZ 001 for details.

TÜVRheinland

Tested acc. to: IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date 24.03.2023

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



Ginlong technologies Co., Ltd. Qingying Cui

Date : 06.04.2023 Our ref. : Jiangyi 01 Your ref.: Qingying Cui

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : R 50580695 0001 : CN23ML60 001 Report No.

Dear Qingying Cui,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area. In case you have a change regarding your involved local representative for the certificate, please inform us in due time.

With kind regards,

Certification Body

Enclosure

邮编: 100176

Tel: 86 10 8524 2222 Fax: 86 10 8524 2200 e-mail: info@bj.chn.tuv.com Internet: http://www.chn.tuv.com

Certificate



Zertifikat Nr. Certificate No. R 50580695

Blatt Sheet

0001

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Jiangyi-CN23ML60 001 06.04.2023

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd.

No. 188 Jinkai Road, Binhai Industrial

Park, Xiangshan, Ningbo,

315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1111267338 Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011

EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) (Product Identification) Certified Product

Lizenzentgelte - Einheit License Fee - Unit

<u>PV-Wechselrichter</u> (Grid-connected PV Inverter)

Type Designation

: 1) S6-GR1P2.5K-S 2) S6-GR1P3K-S 3) S6-GR1P3.6K-S 4) S6-GR1P4K-S 13

Isc PV [Ad.c.]

: 22+22

Vmax PV [Vd.c.]

Max. Input Current Ad.c.] : 16+16

MPP Voltage Range[Vd.c.]

: 1)50-550 2)90-550

3)90-550

4)90-550

Overvoltage Category (OVC): II for PV

Rated Output Volt.[Va.c.] : L+N+PE,220/230

Rated Output Freq.[Hz] Max. Output Curr. [Aa.c.] : 50/60 : 1)11.4

3)3.6

2)13.6

3)16 4)18.2

Rated Output Power [kW]

: 1)2.52)3

Power Factor

: -0.8 to 0.8

Overvoltage Category (OVC): III for AC mains

4)4

continued on page 0002

13

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

Zertifizierungsstelle

Bruce Li

Certificate



Zertifikat Nr. Certificate No. R 50580695

Blatt Sheet 0002

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Jiangyi-CN23ML60 001 06.04.2023

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo

315712 Zhejiang

P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd.

No. 188 Jinkai Road, Binhai Industrial

Park, Xiangshan, Ningbo, 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1111267338 Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011

EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001 continuation

Type Designation

: 5) S6-GR1P4.6K-S 6) S6-GR1P5K-S

7) S6-GR1P6K-S

Isc PV [Ad.c.] Vmax PV [Vd.c.]

: 22+22 Max. Input Current Ad.c.] : 16+16

MPP Voltage Range [Vd.c.] : 90-550 Overvoltage Category (OVC): II for PV

Rated Output Volt. [Va.c.] : L+N+PE, 220/230

Rated Output Freq.[Hz] : 50/60 Max. Output Curr.[Aa.c.] : 5)20.

: 5)20.9 6)22.7

7)27.3

Rated Output Power[kW] : 5)4.6 6)5

7)6

Power Factor

: -0.8 to 0.8

Overvoltage Category (OVC): III for AC mains

continued on page 0003

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

Zertifizierungsstelle

Bruce Li

10/020 d 04.08 ® TÛV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approva

Certificate



Zertifikat Nr. Certificate No.

Blatt Sheet

R 50580695

0003

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Jiangyi-CN23ML60 001 06.04.2023

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd.

No. 188 Jinkai Road, Binhai Industrial

Park, Xiangshan, Ningbo,

315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1111267338 Geprüft nach Tested acc. to

IEC 62109-1:2010

IEC 62109-2:2011 EN 62109-1:2010

EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) Certified Product

(Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

<u>PV-Wechselrichter</u> (Grid-connected PV Inverter)

as page 0002 continuation

Protective Class

: IP66 Enclosure Protection (IP)

Pollution degree (PD)

: PD2(inside), PD3(outside)

Altitude [m]

: 4000

Operating Temperature [°C]

: -25 to 60 (>45 derating)

Type of Inverter

: Non-isolated

Remark:

The installation has to be carried out according to the Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität Dem Zertijikat tiegi unsere Frij- und Zerijikat unseren unserning und Britistung und Prüfigrundlagen. Zusätzliche Anforderungen des Produktes mit den oben genannten Standards und Prüfigrundlagen. Zusätzliche Anforderungen des Produktes mit den oben genannten Standards und Prüfigrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

Zertifizierungsstelle

Bruce Li

0/020 d 04.08 ® TÚV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approva



S6-GR1P(0.6-3.6)K-M

Solis Mini Series Inverters

Features:

- Max. efficiency 97.3%
- String current up to 14A
- Super high frequency switching technology
- Wide voltage range and low startup voltage
- Precise MPPT algorithm
- Integrated Export Power Manager (EPM)
- AFCI protection, proactively reduces fire risk
- Compact and lightweight
- Friendly and adaptable connection to the grid

Models:

S6-GR1P0.6K-M / S6-GR1P0.7K-M S6-GR1P1K-M / S6-GR1P1.5K-M S6-GR1P2K-M / S6-GR1P2.5K-M S6-GR1P3K-M / S6-GR1P3.6K-M









DATASHEET

S6-GR1P(0.6-3.6)K-M

Models	0.6K	0.7K	1K	1.5K	2K	2.5K	3K	3.6K
Input DC								
Recommended max. PV power	0.9 kW	1.1 kW	1.5 kW	2.3 kW	3 kW	3.8 kW	4.5 kW	5.4 kW
Max. input voltage	600 V							
Rated voltage	200 V 330 V					0 V		
Start-up voltage		60	0 V			90 V		
MPPT voltage range	50-500 V 80-500 V					00 V		
Max. input current				14 A				19 A
Max. short circuit current				22 A				24 A
MPPT number/Max. input strings number				1/1				1/2
Output AC								
Rated output power	0.6 kW	0.7 kW	1 kW	1.5 kW	2 kW	2.5 kW	3 kW	3.6 kW
Max. apparent output power	0.6 kVA	0.77 kVA	1.1 kVA	1.65 kVA	2.2 kVA	2.75 kVA	3.3 kVA	3.6 kVA
Max. output power	0.6 kW	0.77 kW	1.1 kW	1.65 kW	2.2 kW	2.75 kW	3.3 kW	3.6 kW
Rated grid voltage					20 V / 230 V			
Rated grid frequency					/ 60 Hz			
Rated grid output current	2.6 A	3.2 A / 3.0 A	4.5 A / 4.3 A	6.8 A / 6.5 A	9.1 A / 8.7 A	11.4 A / 10.9 A	13.6 A / 13 A	16 A
Max. output current	2.6 A	4.4 A	5.2 A	8.1 A	10.5 A	13.3 A	15.7 A	16 A
Power factor	2.071	1.17	0.271	>0.99 (0.8 leadi			10.171	2071
THDi					3%	/		
Efficiency				_	370			
Max. efficiency		96.6%		96.6%	97.1%	97	1%	97.3%
U efficiency		95.3%		95.4%	96.4%	96.		96.8%
Protection		33.370		33.470	30.470	50.	1 70	30.070
OC reverse-polarity protection				V	es			
Short circuit protection		Yes						
Output over current protection					es			
Surge protection					es			
Grid monitoring					es			
Anti-islanding protection					es			
Temperature protection					es			
ntegrated AFCI (DC arc-fault circuit protection)					es ⁽¹⁾			
ntegrated DC switch				Opt	ional			
General Data								
Dimensions (W*H*D)	310*373*160 mm							
Veight	7.4 kg 7.7 kg							
Topology	Transformerless							
Self-consumption (night)	<1 W							
Operating ambient temperature range	-25 ~ +60°C							
Relative humidity	0-100%							
ngress protection	IP66							
Cooling concept	Natural convection							
Max. operation altitude	4000 m							
Grid connection standard	G98 or G99, VDE-AR-N 4105 / VDE V 0124, EN 50549-1, VDE 0126 / UTE C 15 / VFR:2019, RD 1699 / RD 244 / UNE 206006 / UNE 206007-1, CEI 0-21, C10/11, NRS 097-2-1, EIFS 2018.2, IEC 62116, IEC 61727, IEC 60068, IEC 61683, EN 50530, MEA, PE/							
Safety/EMC standard			IEC/EN	N 62109-1/-2, IEC	C/EN 61000-6-1/	/-2/-3/-4		
Features								
OC connection				MC4 co	nnector			
AC connection	Quick connection plug							
Display				L	CD			
Communication	RS485, Optional: Wi-Fi, GPRS							

Certificate



Zertifikat Nr. Certificate No.

Blatt Sheet

R 50516877

0001

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Pengmar-CN21SFB3 001 30.08.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Bauart geprüft Sicherheit Regelmäßige Produktionsüberwechung

www.tuv.com ID 1111244287

Geprüft nach Tested acc. to

IÉC 62109-1:2010 IEC 62109-2:2011

EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) (Product Identification) Certified Product

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

Type Designation

: S6-GR1P0.7K-M-R S6-GR1P0.7K-M

13

Vmax PV [Vd.c.]

: 600 : 22

Isc PV [Ad.c.] MPP Voltage Range[Vd.c.]

: 50-500 Max. Input Current [Ad.c.] : 14

Rated Output Power[W] Max. Output Curr. [Aa.c.] 4 . 4

Type Designation

: S6-GR1P1K-M-R S6-GR1P1K-M

Vmax PV [Vd.c.]

: 600

Isc PV [Ad.c.]

: 22 : 50-500

MPP Voltage Range[Vd.c.] Max. Input Current[Ad.c.] : 14

Rated Output Power[W] Max. Output Curr. [Aa.c.] : 1000

Continued on page 0002

13

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markeheck@tuv.com

Fax: +49 221 806-3935





Ginlong technologies Co., Ltd.

Qingying Cui

Date : 17.09.2021 Our ref. : Pengmar 01 Your ref.: Qingying Cui

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : R 50516877 0001 Report No. : CN21SFB3 001

Dear Qingying Cui,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

Bruce Li

Enclosure

证书的详细资料请登录https://www.certipedia.com查阅,或拨打我司客服热线 800 999 3668/400 883 1300 咨询

www.chn.tuv.com

Certificate



Zertifikat Nr. Certificate No. R 50516877

Blatt Sheet

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Pengmar-CN21SFB3 001 17.09.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Prüfzeichen Test Mark



P.R. China

Bauart geprüft Sicherhelt Regelmäßige Produktionsüberwachung

www.tuv.com ID 1111244287 Geprüft nach Tested acc. to

TEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteldentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001 continuation

4

Type Designation : S6-GR1P1.5K-M-R S6-GR1P1.5K-M

Vmax PV [Vd.c.] : 600

Isc PV [Ad.c.] : 22

MPP Voltage Range[Vd.c.] : 50-500

Max. Input Current[Ad.c.] : 14

Rated Output Power[W] : 1500

Max. Output Curr.[Aa.c.] : 8.1

Type Designation : S6-GR1P2K-M-R S6-GR1P2K-M

 Vmax PV [Vd.c.]
 : 600

 Isc PV [Ad.c.]
 : 22

 MPP Voltage Range[Vd.c.]
 : 80-500

 Max. Input Current[Ad.c.]
 : 14

 Rated Output Power[W]
 : 2000

 Max. Output Curr.[Aa.c.]
 : 10.5

Continued on page 0003

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935



Bruce Li



Ginlong technologies Co., Ltd.

Qingying Cui

Date : 17.09.2021 Our ref.: Pengmar 01 Your ref.: Qingying Cui

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : R 50516877 0002 Report No. : CN21SFB3 001

Dear Qingying Cui,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

Bruce Li

cc: Ginlong technologies Co., Ltd.

Enclosure

证书的详细资料请登录https://www.certipedla.com查阅,或拨打我司客服热线 800 999 3668/400 883 1300 咨询

邮编: 100176

www.chn.tuv.com

Tel: 86 10 8524 2222

Certificate



Zertifikat Nr. Certificate No.

Blatt Sheet

R 50516877

0003

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Pengmar-CN21SFB3 001 17.09.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



Beuart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1111244287

Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011

EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) (Product Identification) Certified Product

Lizenzentgelte - Einheit License Fee - Unit

4

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0002 continuation

Type Designation

: \$6-GR1P2.5K-M-R \$6-GR1P2.5K-M

Vmax PV [Vd.c.] : 600 Isc PV [Ad.c.] : 22 MPP Voltage Range[Vd.c.] : 80-500 Max. Input Current[Ad.c.] : 14 Rated Output Power[W] : 2500 Max. Output Curr. [Aa.c.] : 13.3

Type Designation

Vmax PV [Vd.c.] : 600 Isc PV [Ad.c.] : 22 : 80-500 MPP Voltage Range[Vd.c.] Max. Input Current [Ad.c.] : 14 Rated Output Power[W] : 3000 Max. Output Curr. [Aa.c.] : 15.7

Continued on page 0004

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935



Bruce Li



Ginlong technologies Co., Ltd.

Qingying Cui

: 17.09.2021 Date Our ref. : Pengmar 01 Your ref.: Qingying Cui

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment: Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : R 50516877 0003 Report No. : CN21SFB3 001

Dear Qingying Cui,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

cc: Ginlong technologies Co., Ltd.

Enclosure

证书的详细资料请登录https://www.certipedia.com查阅,或拨打我司客服热线 800 999 3668/400 883 1300 咨询

电话: 86 10 8524 2222

Certificate



Zertifikat Nr. Certificate No. R 50516877

Blatt Sheet

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Pengmar-CN21SFB3 001 17.09.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Prüfzeichen Test Mark



P.R. China

Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1111244287 Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0003 continuation

Type Designation

: S6-GR1P3.6K-M-R S6-GR1P3.6K-M

Vmax PV [Vd.c.] : 600
Isc PV [Ad.c.] : 30
MPP Voltage Range[Vd.c.] : 80-500
Max. Input Current[Ad.c.] : 19
Rated Output Power[W] : 3600
Max. Output Curr.[Aa.c.] : 16

Continued on page 0005

2

2

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935



Bruce Li



Ginlong technologies Co., Ltd.

Qingying Cui

Date : 17.09.2021 Our ref.: Pengmar 01 Your ref.: Qingying Cui

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : R 50516877 0004 Report No. : CN21SFB3 001

Dear Qingying Cui,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

Bruce Li

cc: Ginlong technologies Co., Ltd.

Enclosure

证书的详细资料请登录https://www.certipedia.com查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询

www.chn.tuv.com

Tel: 86 10 8524 2222

Fax: 86 10 8524 2200

Certificate



Zertifikat Nr. Certificate No. R 50516877

Blatt Sheet

Ihr Zeichen Client Reference

Unser Zeichen Our Reference

Ausstellungsdatum

Date of Issue

Qingying Cui

01-Pengmar-CN21SFB3 001 17.09.2021

(day/mo/yr)

Genehmigungsinhaber License Holder

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang Fertigungsstätte Manufacturing Plant

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Prüfzeichen Test Mark



P.R. China

Bauart geprüft Sicherheit Regelmäßige Produktionsüberwachung

www.tuv.com ID 1111244287 Geprüft nach Tested acc. to

IEC 62109-1:2010 IEC 62109-2:2011 EN 62109-1:2010 EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0004 continuation

Overvoltage Category (OVC) : II for PV

Rated Output Volt. [Va.c.] : 1/N/PE, 220 V / 230 V

Rated Output Freq. [Hz] : 50 / 60

Power Factor : [-0.80, 0.80] Overvoltage Category (OVC) : III for AC mains

Protective Class : Class I Ingress Protection (IP) : IP66

Pollution Degree (PD) : PD 2 (inside) PD 3 (outside)

Altitude[m] : 2000

Operating Temperature [°C] : -25 to +60

Type of Inverter : Non-isolated

Remark(s):

The installation has to be carried out according to the attached installation instruction.

Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com

Fax: +49 221 806-3935



Bruce Li



Ginlong technologies Co., Ltd.

Qingying Cui

Date : 17.09.2021 Our ref. : Pengmar 01 Your ref.: Qingying Cui

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment: Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : R 50516877 0005 : CN21SFB3 001 Report No.

Dear Qingying Cui,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

cc: Ginlong technologies Co., Ltd.

Enclosure

证书的详细资料请登录https://www.cartipedla.com查阅,或拨打我司客服热线 800 999 3668/400 883 1300 咨询

www.chn.tuv.com



No. D 086470 0114 Rev. 00

Holder of Certificate: Ginlong Technologies Co., Ltd.

No.57 Jintong Road

Binhai Industrial Park, Xiangshan 315712 Ningbo, Zhejiang

PEOPLE'S REPUBLIC OF CHINA

Product: Converter

(PV-Inverter)

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64772228006301

Date, 2022-06-08

(Tony Liu)



No. D 086470 0114 Rev. 00

Model(s): S6-GR1P3.6K-M, S6-GR1P3K-M, S6-GR1P2.5K-M, S6-GR1P2K-

M, S6-GR1P1.5K-M, S6-GR1P1K-M, S6-GR1P0.7K-M, S6-GR1P3.6K-M-R, S6-GR1P3K-M-R, S6-GR1P2.5K-M-R, S6-GR1P1.5K-M-R, S6-GR1P1K-M-R, S6-GR1P1K-M-R,

GR1P0.7K-M-R

Trade name: solis





No. D 086470 0114 Rev. 00

Parameters:

Model:	S6-GR1P0.7K-M S6-GR1P0.7K-M-R	S6-GR1P1K-M S6-GR1P1K-M-R	S6-GR1P1.5K-M S6-GR1P1.5K-M-R			
INPUT						
V _{MAX} PV [Vdc]	600					
I _{SC} PV[A]		22				
MPP Voltage Range V _{MPP} [Vdc]		50-500				
Max. Input Current Imax [A]		14				
MPP Full Power Voltage Range [Vdc]	66-500	94-500	141-500			
Start PV Voltage [Vdc]		60				
Backfeed Current [A]		0				
Overvoltage Category (OVC)		II				
OUTPUT						
Rated Output Voltage Ur [Vac]		1/N/PE, 220/230V				
Normal Operating Voltage Range Un [Vac]		176-253V/184-264V				
Rated Output Frequency F _{NETZ} [Hz]		50/60				
Normal Operating Frequency Range F _n [Hz]		45-55Hz/55-65Hz				
Rated Output Power P _E [W]	700	1000	1500			
Max. Output Power P _{Emax} [W]	800	1100	1700			
Max. Output Current Imax [A]	4.4	5.2	8.1			
Power Factor cosφ [ʎ]	-0.8, 0.8					
Standby Power Consumption [W]	<1					
Night Power Consumption [W]	<1					
THD [V / I] (100% full power)		<3%				
Acoustic Noise [dB]	<20					
Overvoltage Category (OVC)	III					
SYSTEM						
Protective Class	I					
Enclosure Protection (IP)	IP66					
Operating Temperature Range [°C]	-25 to +60					
Pollution degree (PD)	PD2					
Altitude [m]	2000					
Array Insulation Resistance Detection [Ω]	200K					
The accuracy of resistance measurement [%]	<10					

Model:	S6-GR1P2K-M S6-GR1P2K-M-R	S6-GR1P2.5K-M S6-GR1P2.5K-M-R			
INPUT					
V _{MAX} PV [Vdc]	600				
I _{SC} PV[A]	22	2			
MPP Voltage Range V _{MPP} [Vdc]	80-5	500			
Max. Input Current Imax [A]	14	4			
MPP Full Power Voltage Range [Vdc]	187-500	234-500			
Start PV Voltage [Vdc]	90				
Backfeed Current [A]	0				
Overvoltage Category (OVC)	II				
OUTPUT					
Rated Output Voltage Ur [Vac]	1/N/PE, 220/230V				
Normal Operating Voltage Range Un [Vac]	176-253V/184-264V				
Rated Output Frequency F _{NETZ} [Hz]	50/60				
Normal Operating Frequency Range F _n [Hz]	45-55Hz/55-65Hz				
Rated Output Power P _E [W]	2000 2500				
Max. Output Power P _{Emax} [W]	2200 2800				
Max. Output Current Imax [A]	10.5 13.3				



No. D 086470 0114 Rev. 00

Power Factor cosφ [ʎ]	-0.8, 0.8	
Standby Power Consumption [W]	<1	
Night Power Consumption [W]	<1	
THD [V / I] (100% full power)	< 3%	
Acoustic Noise [dB]	<20	
Overvoltage Category (OVC)	III	
SYSTEM		
Protective Class	I	
Enclosure Protection (IP)	IP66	
Operating Temperature Range [°C]	-25 to +60	
Pollution degree (PD)	PD2	
Altitude [m]	2000	
Array Insulation Resistance Detection [Ω]	200K	
The accuracy of resistance measurement [%]	<10	

Model:	S6-GR1P3K-M S6-GR1P3K-M-R	S6-GR1P3.6K-M S6-GR1P3.6K-M-R			
INPUT		•			
V _{MAX} PV [Vdc]	600				
I _{SC} PV[A]	22 30				
MPP Voltage Range V _{MPP} [Vdc]	80-	-500			
Max. Input Current Imax [A]	14	19			
MPP Full Power Voltage Range [Vdc]	281-500	195-500			
Start PV Voltage [Vdc]	(90			
Backfeed Current [A]		0			
Overvoltage Category (OVC)		II			
OUTPUT					
Rated Output Voltage Ur [Vac]	<u> </u>	220/230V			
Normal Operating Voltage Range Un [Vac]		//184-264V			
Rated Output Frequency F _{NETZ} [Hz]	50/60				
Normal Operating Frequency Range F _n [Hz]	45-55Hz	z/55-65Hz			
Rated Output Power P _E [W]	3000	3600			
Max. Output Power P _{Emax} [W]	3300	3600			
Max. Output Current Imax [A]	15.7	16			
Power Factor cosφ [ʎ]	-0.8, 0.8				
Standby Power Consumption [W]	<	<1			
Night Power Consumption [W]	<1				
THD [V / I] (100% full power)	<	3%			
Acoustic Noise [dB]	<	.20			
Overvoltage Category (OVC)		III			
SYSTEM					
Protective Class	I				
Enclosure Protection (IP)	IP66				
Operating Temperature Range [°C]	-25 to +60				
Pollution degree (PD)	PD2				
Altitude [m]	2000				
Array Insulation Resistance Detection [Ω]	20	00K			
The accuracy of resistance measurement [%]	<10				

Tested according to:

EN IEC 61000-3-11:2019 EN 61000-3-12:2011





of Conformity Low Voltage Directive 2014/35/EU

Registration No.:

AN 50519078 0001

Report No.:

CN21SFB3 001

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: S6-GR1P3.6K-M S6-GR1P3K-M S6-GR1P2.5K-M S6-GR1P2K-M S6-GR1P1.5K-M S6-GR1P1K-M

S6-GR1P0.7K-M S6-GR1P3.6K-M-R S6-GR1P3K-M-R

S6-GR1P2.5K-M-R S6-GR1P2K-M-R S6-GR1P1.5K-M-R

S6-GR1P1K-M-R S6-GR1P0.7K-M-R

Serial Number : Engineering Sample

Remark(s)

: Issued in conjunction with TÜV Rheinland

erungsste

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date 17.09.2021

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Qingying Cui

Date : 17.09.2021

Our ref. : DJW 01 Your ref.: Qingving Cui

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AN 50519078 0001 Report No. : CN21SFB3 001

Dear Qingying Cui,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Bruce Li

Enclosure

证书的详细资料请登录https://www.certipedia.com查阅,或拨打我司客服热线 800 999 3668/400 883 1300 咨询

www.chn.fuv.com

电话: 86 10 8524 2222



of Conformity EC Council Directive 2014/30/EU **Electromagnetic Compatibility**

AE 50555891 0001 Registration No.:

Report No.: 50084876 012

Holder: Ginlong technologies Co., Ltd.

No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product: PV-Inverter

(Grid-connected PV Inverter)

Identification: See type designations in attachment 1.1

Serial No.: n.a.

Remark: Refer to test reports 50084876 001-012 for details.

TÜVRheinland

Continued on page 0002.

Tested acc. to: EN IEC 61000-6-4:2019

EN IEC 61000-6-3:2021 EN IEC 61000-6-2:2019 EN IEC 61000-6-1:2019 EN 55011:2016+A1+A11+A2

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2014/30/EU. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to the a.m. Directive.

Certification Body

dinhe in

Xinhua Lu

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Date 19.08.2022



of Conformity EC Council Directive 2014/30/EU **Electromagnetic Compatibility**

AE 50555891 0002 Registration No.:

Report No.: 50084876 012

Holder: Ginlong technologies Co., Ltd.

No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product: PV-Inverter

(Grid-connected PV Inverter)

Identification: See type designations in attachment 1.1

Serial No.: n.a.

Remark: Refer to test reports 50084876 001-012 for details.

TÜVRheinland

Refer to page 0001.

Tested acc. to: IEC 61000-6-4:2018

IEC 61000-6-3:2020 IEC 61000-6-2:2016 IEC 61000-6-1:2016 CISPR 11:2015+A1+A2

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2014/30/EU. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to the a.m. Directive.

Certification Body

dinhe h

Xinhua Lu

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Date 19.08.2022



1.1

TÜV Rheinland LGA Products GmbH Tillystraße 2, 90431 Nürnberg

Attachment to

Registration No.: AE 50555891 0001 Report No.: 50084876 012

Manufacturer:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Scope:

type designation: Solis-mini-700-4G S5-GR1P0.7K-M S6-GR1P0.7K-M S6-GR1P0.7K-M-R Solis-mini-1000-4G S5-GR1P1K-M S6-GR1P1K-M-R Solis-mini-1500-4G S5-GR1P1.5K-M S6-GR1P1.5K-M-R Solis-mini-2000-4G S5-GR1P2K-M S6-GR1P2K-M-R Solis-mini-2500-4G S5-GR1P2.5K-M S6-GR1P2.5K-M S6-GR1P2.5K-M-R Solis-mini-300 S5-GR1P3K-M S6-GR1P3K-M Solis-mini-3600-4G S5-GR1P3.6K-M S6-GR1P3.6K-M-R S6-GR1P1K-M-LV S6-GR1P0.6K-M

S6-GR1P2K-M S6-GR1P2.5K-M-R Solis-mini-3000-4G S6-GR1P3K-M-R S6-GR1P3.6K-M

Date: 2022-08-19



Xinhua Lu





EU Declaration of Conformity - CE

This is to declare that the products listed below have been manufactured according to the following EU directives:

- Low Voltage Directive 2014/35/EU
- Electromagnetic Compatibility 2014/30/EU
- 2011/65/EU RoHS Directive

Manufacturer	Ginlong (Solis) Technologies Co., Ltd.		
Address	NO.57 Jintong Road, Binhai Industrial Park, Xiangshan Ningbo, Zhejiang, 315712,		
19	China		
Product Type	Grid-connected PV Inverter		
Model	Solis-mini-700-4G, Solis-mini-1000-4G, Solis-mini-1500-4G, Solis-mini-2000-4G,		
	Solis-mini-2500-4G, Solis-mini-3000-4G, Solis-mini-3600-4G,		
	S5-GR1P0.7K-M, S5-GR1P1K-M, S5-GR1P1.5K-M, S5-GR1P2K-M,		
	S5-GR1P2.5K-M, S5-GR1P3K-M, S5-GR1P3.6K-M,		
	S6-GR1P0.7K-M, S6-GR1P1K-M, S6-GR1P1.5K-M, S6-GR1P2K-M,		
	S6-GR1P2.5K-M, S6-GR1P3K-M, S6-GR1P3.6K-M,		

The following standards have been applied according to the aforementioned directives:

Low Voltage Directive 2014/35/EU

EN 62109-1:2010, EN 62109-2:2011

Electromagnetic Compatibility 2014/30/EU

EN 55011:2016

EN 61000-6-1:2007, EN 61000-6-2:2005, EN 61000-6-3:2007+A1, EN 61000-6-4:2007+A1

IEC 61000-3-2:2018+A1, IEC 61000-3-3:2013+A1+A2

Rohs Directive 2011/65/EU

EN 63000:2018

All modifications to this declaration will be confirmed by Ginlong, otherwise this declaration will no longer be valid. The product defined here-in was manufactured under the condition of the EU directive and standards. Product responsibility is within the manufacturer's guarantee and this declaration of conformity is issued under the responsibility of the manufacturer.

Ningbo, 2.Nov.2021

锦浪科技股份左四公司GINLONG TECHNOLOGIES CO.,LTD.

PanRuyi Certification Supervisor



of Conformity

Registration No.:

AK 50522088 0001

Report No .:

50281041 007

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang

P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: Solis-aaK-5G (aa=25,30,33,36,40)

Solis-bbK-HV-5G (bb=40,50) Solis-ccK-LV-5G (cc=15,20,23) S5-GCxxK (xx=25,30,33,36,40) S5-GCyyK-HV (yy=40,50) S5-GCzzK-LV (zz=15,20,23)

Serial Number : Engineering Samples

Firmware version : V31

Remark(s) : Refer to report 50281041 007 for details.

Tested acc. to:

IEC 61727:2004 IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date

22.10.2021

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Certification



of Conformity

Registration No.: AK 50570569 0001

Report No.: CN22VJC9 001

Holder: Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product: PV-Inverter

(Grid-Connected PV Inverter)

Identification: Type Designation : Solis-xxK-5G-PRO(xx=75,80,100,110,125)

Serial Number : Engineering Samples

Firmware version : Al

Remark(s) : Refer to report CN22VJC9 001 for details.

TÜVRheinland

Tested acc. to: IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date 05.01.2023

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



of Conformity

AK 50514285 0001 Registration No.:

CN20G2DH 002 Report No .:

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product: **PV-Inverter**

(Grid-Connected PV Inverter)

Identification: Type Designation: S6-GR1PxxK (xx=2.5,3,3.6,4,4.6,5,6)

Solis-1Pxxk-4G (xx=2.5,3,3.6,4,4.6,5,6)

Firmware Version: V2F

Serial Number : Engineering Samples

: Refer to test report CN20G2DH 002 for Remark

detail.

Tested acc. to: IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TUV Rheinland mark of conformity.

27.08.2021 Date

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Zhang Kun

Date : 27.08.2021 Our ref. : LIUPHI 01 Your ref.: Z.K

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-Connected PV Inverter

Model Designation : See Certificate Certificate No. : AK 50514285 0001 Report No. : CN20G2DH 002

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询



of Conformity

Registration No.:

AK 50514507 0001

Report No .:

50171233 006

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: Solis-3PxK-4G S5-GR3PyK

(x=5,6,8,9,10,12,15,17,20)

(y=3,4,5,6,8,9,10,12,13,15,17,20)

Serial Number : Engineering Samples

Firmware version: V18

Remark(s) : Refer to report 50171233 006 for details.

Tested acc. to:

IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a Turnelland mark of conformity.

Date

13.08.2021

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Zhang Kun

Date : 13.08.2021 Our ref. : PJG 01 Your ref.: Kun Zhang

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AK 50514556 0001 Report No. : 50330358 004

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Weichun Li

CC: Ginlong technologies Co., Ltd.

Enclosure

Tel: (8610)6566 6660 Fax: (8610)6566 6667 e-mail: info@bj.chn.tuv.com Internet: http://www.chn.tuv.com



of Conformity

Registration No.:

AK 50510974 0001

Report No.:

CN21KSGT 001

Holder:

Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product:

PV-Inverter

(Grid-Connected PV Inverter)

Identification:

Type Designation : S5-GC50K S5-GC60K

S5-GC60K-HV S5-GC70K-HV

Serial Number : Engineering Samples

Firmware version : VD6

Remark(s) : Refer to report CN21KSGT 001 for details.

Tested acc. to:

IEC 61727:2004 IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TOV Rheinland mark of conformity.

Date 14.07.2021

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Zhang Kun

: 14.07.2021 Date Our ref. : PJG 01 Your ref .: Kun Zhang

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-Connected PV Inverter

Model Designation : See Certificate : AK 50510974 0001 Certificate No. : CN21KSGT 001 Report No.

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

CC: Ginlong technologies Co., Ltd.

Enclosure

Tel: (8610)6566 6660 Fax: (8610)6566 6667 e-mail: info@bj.chn.tuv.com Internet: http://www.chn.tuv.com



of Conformity

Registration No.:

AK 50522814 0001

Report No.:

CN214JCP 001

Holder:

Ginlong technologies Co., Ltd.

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Product:

PV-Inverter

(Grid-connected PV Inverter)

Identification:

Type Designation: S6-GR1P0.7K-M S6-GR1P1K-M

\$6-GR1P1.5K-M \$6-GR1P2K-M \$6-GR1P2.5K-M \$6-GR1P3K-M

Certification Body

A. Chen

S6-GR1P3.6K-M

Serial Number : Engineering Samples

Firmware version : V2F

: Refer to report CN214JCP 001 for details. Remark(s)

Tested acc. to:

IEC 61727:2004 IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TUV Rhefoland mark of conformity. TÜVRheinland

Date 27.10.2021

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.

Zhang Kun

No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Date : 27/10/2021 Our ref. : Pengmar 01 Your ref.: Zhang kun

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter

Model Designation : See Certificate Certificate No. : AK 50522814 0001 : CN214JCP 001 Report No.

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

CC: Ginlong technologies Co., Ltd.

Enclosure



of Conformity

Registration No.: AK 50577679 0001

Report No.: **CN23NXBZ 001**

Holder: Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai,

(seafront), Industrial Park,

Xiangshan Ningbo 315712 Zhejiang P.R. China

Product: PV-Inverter

(Grid-Connected PV Inverter)

Identification: Type Designation: S6-GR1PxxK-S (xx=2.5,3,3.6,4,4.6,5,6)

Serial Number : Engineering Samples

Firmware Version: Al

Remark : Refer to report CN23NXBZ 001 for details.

TÜVRheinland

Tested acc. to: IEC 61727:2004

IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date 24.03.2023

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



Compliance Document

No. D 086470 0138 Rev. 00

Holder of Certificate: Ginlong Technologies Co., Ltd.

No.57 Jintong Road

Binhai Industrial Park, Xiangshan 315712 Ningbo, Zhejiang PEOPLE'S REPUBLIC OF CHINA

Product: Converter

Hybrid Inverter

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704092304835-00

Date, 2023-05-24

(Zhengdong Ma)



Compliance Document

No. D 086470 0138 Rev. 00

Model(s): S6-EH1P3K-L-PRO, S6-EH1P3.6K-L-PRO, S6-EH1P8K-L-PRO

Parameters:

Models	S6-EH1P3K-L-PRO	S6-EH1P3.6K-L-PRO			
1) PV input					
Max. input voltage	600 Vd.c.	600 Vd.c.			
MPPT voltage range	90 - 520 Vd.c.	90 - 520 Vd.c.			
Max. input current	2x16A	2x16A			
Max. short-circuit input current	2x24A	2x24A			
2) Battery input		•			
Battery type	Li-ion / Lead-acid	Li-ion / Lead-acid			
Battery voltage range	40 - 60 Vd.c.	40 - 60 Vd.c.			
Max. charge current:	70 Ad.c.	80 Ad.c.			
Max. discharge current:	70 Ad.c.	80 Ad.c.			
3) AC-output (Back-up)		•			
Rated output voltage:	230 Va.c.	230 Va.c.			
Rated output frequency:	50 Hz	50 Hz			
Rated output current:	13A	15.7A			
Rated output power	3000W	3600W			

4) AC-output (Grid side)					
Rated output voltage:	230 Va.c.	230 Va.c.			
Rated output frequency:	50 Hz	50 Hz			
Max. output current:	15A	20A			
Max. apparent output power	3300VA	4000VA			
Power factor range	0.8(leading)-0.8(lagging)	0.8(leading)-0.8(lagging)			
5) AC input					
Rated output voltage:	230 Va.c.	230 Va.c.			
Rated output frequency:	50 Hz	50 Hz			
Max. continuous current:	20A	25A			



Compliance Document

No. D 086470 0138 Rev. 00

Models	S6-EH1P5K-L-PRO	S6-EH1P6K-L-PRO	S6-EH1P8K-L-PRO	
1) PV input				
Max. input voltage	600 Vd.c.	600 Vd.c.	600 Vd.c.	
MPPT voltage range	90 - 520 Vd.c.	90 - 520 Vd.c.	90 - 520 Vd.c.	
Max. input current	2x16A	2x16A	32A/20A	
Max. short-circuit input current	2x24A	2x24A	36A/30A	
2) Battery input				
Battery type	Li-ion / Lead-acid	Li-ion / Lead-acid	Li-ion / Lead-acid	
Battery voltage range	40 - 60 Vd.c.	40 - 60 Vd.c.	40 - 60 Vd.c.	
Max. charge current:	112 Ad.c.	135 Ad.c.	190 Ad.c.	
Max. discharge current:	112 Ad.c.	135 Ad.c.	190 Ad.c.	
3) AC-output (Back-up)	•			
Rated output voltage:	230 Va.c.	230 Va.c.	230 Va.c.	
Rated output frequency:	50 Hz	50 Hz	50 Hz	
Rated output current:	21.7A	26.1A	34.8A	
Rated output power	5000W	6000W	8000W	

4) AC-output (Grid side)						
Rated output voltage:	230 Va.c.					
Rated output frequency:	50 Hz	50 Hz 50 Hz				
Max. output current:	25A 30A 40A					
Max. apparent output power	5500VA	6600VA	8800VA			
Power factor range	0.8(leading)- 0.8(lagging)	0.8(leading)- 0.8(lagging)	0.8(leading)-0.8(lagging)			
5) AC input						
Rated output voltage:	230 Va.c.	230 Va.c. 230 Va.c.				
Rated output frequency:	50 Hz	50 Hz	50 Hz			
Max. continuous current: 32A 40A		50A				

Tested IEC 61727:2004 IEC 62116:2014 IEC 61683:1999 IEC 60068-2-1:2007

IEC 60068-2-1:2007
IEC 60068-2-2:2007
IEC 60068-2-14:2009
IEC 60068-2-27:2008
IEC 60068-2-30:2005
IEC 60068-2-64:2008

IEC 60068-2-64:2008/AMD1:2019



Page 1 of 99



TEST REPORT NRS 097-2-1:2017

Grid interconnection of embedded generation Part 2: Small-scale embedded generation

Report

 Report Number.
 6108594.50

 Date of issue.
 2021-09-08

 Total number of pages.
 99 pages

Testing Laboratory DEKRA Testing and Certification (Shanghai) Ltd.

Address 3F, #250 Jiangchangsan Road, Building 16, Headquarter Economy

Park Shibei Hi-Tech Park, Zhabei District, Shanghai 200436, China

Applicant's name Ginlong Technologies Co., Ltd.

Zhejiang, 315712, P.R. China.

Test specification:

Test procedure.....: Type test

Non-standard test method.....: N/A

Test Report Form No. NRS 097-2-1_V2.1

Test Report Form(s) Originator: DEKRA Testing and Certification (Shanghai) Ltd.

Master TRF...... Dated 2017-07

Test item description...... Grid-Connected PV Inverter

Trade Mark:

SOLIS inverters

Manufacturer Ginlong Technologies Co., Ltd.

No. 57 Jintong Road, Binhai Industrial Park, Xiangshan, Ningbo,

Zhejiang, 315712, P.R. China.

Model/Type reference Solis-1P1K-4G, Solis-1P1.5K-4G, Solis-1P2K-4G,

Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-

4G, Solis-1P4.6K-4G

S5-GR1P2.5K, S5-GR1P3K, S5-GR1P3.6K, S5-GR1P4K,

S5-GR1P4.6K

S6-GR1P2.5K, S6-GR1P3K, S6-GR1P3.6K, S6-GR1P4K,

S6-GR1P4.6K

Page 2 of 99 Report No.: 6108594.50

Ratings...... Ratings of the test product:

Operating temperature range: - 25°C to + 60°C

Protective class: I

Ingress protection rating: IP66 for S6 series, IP65 for other models Power factor range (adjustable): 0.8 leading...0.8 lagging

Solis-1P1K-4G:

PV input: max 550Vdc, MPP voltage range: 50-450Vdc, max 11A,

Isc PV: 17,2A

AC output: 230V, 50Hz, max 5,2A, 1100W

Solis-1P1.5K-4G:

PV input: max 550Vdc, MPP voltage range: 50-450Vdc, max 11A,

Isc PV: 17,2A

AC output: 230V, 50Hz, max 8,1A, 1700W

Solis-1P2K-4G:

PV input: max 550Vdc, MPP voltage range: 50-450Vdc, max 11A,

Isc PV: 17,2A

AC output: 230V, 50Hz, max 10,5A, 2200W

Solis-1P2.5K-4G:

PV input: max 550Vdc, MPP voltage range: 50-450Vdc, max 2x11A,

Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 13,3A, 2800W

Solis-1P3K-4G

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x11A,

Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 15,7A, 3300W

Solis-1P3.6K-4G:

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x11A,

Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 16A, 4000W

Solis-1P4K-4G:

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x11A,

Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 21A, 4400W

Solis-1P4.6K-4G:

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x11A,

Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 23,8A, 4600W

S5-GR1P2.5K

PV input: max 550Vdc, MPP voltage range: 50-450Vdc, max

2x12,5A, Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 13,3A, 2800W

S5-GR1P3K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max

2x12,5A, Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 15,7A, 3300W

S5-GR1P3.6K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max

2x12,5A, Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 16A, 4000W

S5-GR1P4K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max

2x12,5A, Isc PV: 2x17,2A

Page 3 of 99 Report No.: 6108594.50

AC output: 230V, 50Hz, max 21A, 4400W

S5-GR1P4.6K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max

2x12,5A, Isc PV: 2x17,2A

AC output: 230V, 50Hz, max 23,8A, 4600W

S6-GR1P2.5K

PV input: max 550Vdc, MPP voltage range: 50-450Vdc, max 2x14A,

Isc PV: 2x22A

AC output: 230V, 50Hz, max 13,3A, 2800W

S6-GR1P3K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x14A,

Isc PV: 2x22A

AC output: 230V, 50Hz, max 15,7A, 3300W

S6-GR1P3.6K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x14A,

Isc PV: 2x22A

AC output: 230V, 50Hz, max 16A, 4000W

S6-GR1P4K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x14A,

Isc PV: 2x22A

AC output: 230V, 50Hz, max 21A, 4400W

S6-GR1P4.6K

PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x14A,

Isc PV: 2x22A

AC output: 230V, 50Hz, max 23,8A, 4600W


Page 4 of 99 Report No.: 6108594.50


Resp	consible Testing Laboratory (as applicable)	, testing procedure and to	esting location(s):		
\boxtimes	Testing Laboratory: DEKRA Testing and Certification (Shanghai) Ltd.				
Testing location/ address:		3F, #250 Jiangchangsan Road, Building 16, Headquarter Economy Park Shibei Hi-Tech Park, Zhabei District, Shanghai 200436, China			
\boxtimes	Associated Testing Laboratory:	DEKRA Testing and Ce	rtification (Suzhou) Co., Ltd.		
Test	ing location/ address:	No.99, Hongye Road, Suzhou Industrial Park, Suzhou, Jiangsu, P.R. China			
Test	ed by (name, function, signature):	Hua Yu	hna. Tu		
Appr	roved by (name, function, signature):	Jason Guo	Jasala		
	T				
<u> </u>	Testing procedure: TMP/CTF Stage 1:				
Test	ing location/ address:				
Test	ed by (name, function, signature):				
Appr	oved by (name, function, signature):				
$\overline{}$	Tooking procedure: WMT/CTF Chare 2:				
=	Testing procedure: WMT/CTF Stage 2:				
I est	ing location/ address:				
Test	ed by (name + signature):				
Witn	essed by (name, function, signature):				
Appr	roved by (name, function, signature):				
	Testing procedure: SMT/CTF Stage 3 or 4:				
Test	ing location/ address:				
Test	ed by (name, function, signature):				
Witn	essed by (name, function, signature):				
Approved by (name, function, signature):					
Supe	ervised by (name, function, signature):				


Page 5 of 99 Report No.: 6108594.50

Copy of marking plate:

"The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCB's that own these marks"








Address: No. 57 Jintone Road, Binhai Industrial Park

Xiangshan, Ningbo, Zhejiang, 315712, P.R. China

Solis-1P2.5K-4G Model: Max.input voltage d.c 550V 50-450\ Mppt voltage range d.c. 2X11A Max.input current d.c. Isc PV (absolute maximum) d.c. 2X17.2A Rated grid voltage a.c. 50/60Hz Rated grid frequency Rated output power 2500W Max.AC output active power 2800W Max.AC output apparent powe 2800V A Max.continous output current 13.3A Adjustable cos(φ) -0.8...1...+0.8 -25....+60°C Operating temperature range Ingress protection IP65 Protective class II(PV) Overvoltage category III(MAINS) Inverter topology Non-isolated S/N:

Name: Ginlong Technologies Co.,Ltd.

Address: No. 57 Jintone Road, Binhai Industrial Park Xiangshan,Ningbo,Zhejiang,315712,P.R.China



Address: No. 57 Jintong Road, Binhai Industrial Park

Xiangshan, Ningbo, Zhejiang, 315712, P.R. China

Model: Solis-1P3.6K-4G Max.input voltage d.c. Mppt voltage range d.c. 90-520\ Max.input current d.c. Isc PV (absolute maximum) d.c. 2X17.2A Rated grid voltage a.c. 230V 50/60Hz Rated grid frequency Rated output power 3600W Max.AC output active power 4000W Max.AC output apparent power 4000VA Max.continous output current 16A Adjustable cos(φ) -0.8...1...+0.8 Operating temperature range -25....+60°C Ingress protection Protective class II(PV) Overvoltage category III(MAINS) Inverter topology S/N

Name: Ginlong Technologies Co.,Ltd.

Address: No. 57 Jintong Road, Binhai Industrial Park,


Xiangshan, Ningbo, Zhejiang, 315712, P.R.China



X Name: Ginlong Technologies Co.,Ltd. Address: No. 57 Jintong Road, Binhai Industrial Park Xiangshan,Ningbo,Zhejiang,315712,P.R.China

Page 6 of 99 Report No.: 6108594.50

Copy of marking plate:





S/N: 2222233333





Address:No.57 Jintong Road,Binhai Industrial Park Xiangshan,Ningbo,Zhejiang,315712,P.R.China



Solis-1P4.6K-4G
600V
. 90-520V
2X11A
um) d.c 2X17.2A
230V
50/60Hz
4600W
ower 5000W *2
t power 5000VA *2
23.8A *1
-0.81+0.8
range -25+60°C
IP65
II(PV) III(MAINS)
Non-isolated

*1:21.7A for AS/NZ 4777.2:2015 *2:4600 for VDE-AR N4105/NRS 097-2-1:2017



S/N: 2222233333

8



Name: Ginlong Technologies Co.,Ltd. Address:No.57 Jintong Road,Binhai Industrial Park Xiangshan,Ningbo,Zhejiang,315712,P.R.China



7000	
Model: S	5-GR1P2.5K
Max.input voltage d.c.	550∨
Mppt voltage range d.c.	50-450∨
Max.input current d.c.	2X12.5A
Isc PV(absolute maximum) d	.c. 2X17.2A
Rated grid voltage a.c.	1/N/PE, 220/230 V
Rated grid frequency	50/60Hz
Rated output power	2500W
Max.AC output active power	2800W
Max. AC output apparent pow	ver 2800∨A
Max.continous output currer a.c.	nt 13.3A
Adjustable cos(φ)	-0.81+0.8
Operating temperature rang	e -25+60°C
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV) III(MAINS)
Inverter topology	Non-isolated
G.K.G.	



S/N: 222223333





Name: Ginlong Technologies Co.,Ltd. Address:No.57 Jintong Road, Binhai Industrial Park, Xiangshan,Ningbo,Zhejiang,315712,P.R.China



7000	
Model:	S5-GR1P3K
Max.input voltage d.c.	600∨
Mppt voltage range d.c.	90-520∨
Max.input current d.c.	2X12.5A
Isc PV(absolute maximum) d.c.	2X17.2A
Rated grid voltage a.c.	1/N/PE, 220/230 V
Rated grid frequency	50/60Hz
Rated output power	3000W
Max.AC output active power	3300W
Max. AC output apparent power	3300VA
Max.continous output current a.c.	15.7A
Adjustable cos(φ)	-0.81+0.8
Operating temperature range	-25+60℃
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV) III(MAINS)
Inverter topology	Non-isolated



S/N: 2222233333



Name: Ginlong Technologies Co., Ltd. Address: No.57 Jintong Road, Binhai Industrial Park Xiangshan, Ningbo, Zhejiang, 315712, P.R. China



AND SO	
Model: \$5	-GR1P3.6K
Max.input voltage d.c.	600V
Mppt voltage range d.c.	90-520∨
Max.input current d.c.	2X12.5A
Isc PV(absolute maximum) d.c	2X17.2A
Rated grid voltage a.c.	1/N/PE, 220/230 V
Rated grid frequency	50/60Hz
Rated output power	3600W
Max .AC output active power	4000W
Max. AC output apparent powe	r 4000∨A
Max.continous output current	16A
a.c.	
Adjustable cos(φ)	-0.81+0.8
Operating temperature range	-25+60℃
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV)
orer rounge entergory	III(MAINS)
Inverter topology	Non-isolated



S/N: 2222233333



Name: Ginlong Technologies Co., Ltd.
Address: No.57 Jintong Road, Binhai Industrial Park
Xiangshan, Ningbo, Zhejiang, 315712, P.R. China



Model:	5-GR1P4K
Max.input voltage d.c.	600∨
Mppt voltage range d.c.	90-520∨
Max.input current d.c.	2X12.5A
Isc PV(absolute maximum)d.c.	2X17.2A
Rated grid voltage a.c.	1/N/PE, 220/230 V
Rated grid frequency	50/60Hz
Rated output power	4000W
Max.AC output active power	4400W
Max. AC output apparent power	4400VA
Max.continous output current a.c.	21A
Adjustable cos(φ)	-0.81+0.8
Operating temperature range	-25+60°C
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV) III(MAINS)
Inverter topology	Non-isolated
m&m	




S/N: 2222233333





Name: Ginlong Technologies Co.,Ltd. Address:No.57 Jintong Road,Binhai Industrial Park, Xiangshan,Ningbo,Zhejiang,315712,P.R.China Page 7 of 99 Report No.: 6108594.50



2222233333

Name: Ginlong Technologies Co.,Ltd.

Address: No.57 Jintong Road, Binhai Industrial Park

Xiangshan,Ningbo,Zhejiang,315712,P.R.China

SAA

R



2222233333


Name: Ginlong Technologies Co.,Ltd.


Address: No. 57 Jintong Road, Binhai Industrial Park


Xiangshan, Mingbo, Zhejiang, 315712, P.R. China

A

A








Name: Ginlong Technologies Co.,Ltd.

Address: No. 57 Jintong Road, Binhai Industrial Park

Xianeshan, Ninebo, Zheijane, 315712, P.R. China



Page 8 of 99 Report No.: 6108594.50

Test item particulars:					
Equipment mobility:	movable hand-held stationary fixed transportable for building-in		•		
Connection to the mains:				ect plug-in building-in	
Enviromental category:				indoor conditional	
Over voltage category Mains	OVC I	OVC II	OVC	<u>III</u>	OVC IV
Over voltage category PV	OVC I	OVC II	OVC	Ш	OVC IV
Mains supply tolerance (%)	According to South African deviation in NRS 097-2-1:2017 (Edition 2.1 July 2020)			NRS 097-2-	
Tested for power systems	TN				
IT testing, phase-phase voltage (V)	N/A				
Class of equipment:	Class I Not classifie	Class d	s II	Class III	
Mass of equipment (kg)	About 11,5 kg				
Pollution degree	PD2				
IP protection class	: IP66 for S6 series, IP65 for other models			s	
Possible test case verdicts:					
- test case does not apply to the test object	N/A				
- test object does meet the requirement	P (Pass)				
- test object does not meet the requirement	F (Fail)				
- this clause is information reference for installation.:	Info.				
Testing:					
Date of receipt of test item	2017-05-16	(samples	provided	by applic	ant)
Date (s) of performance of tests	: 2017-10-16 to 2017-11-06, 2020-12-01				
Date (s) of performance of tests	2017-10-16 to 2017-11-06, 2020-12-01				

General remarks:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

The measurement result is considered in conformance with the requirement if it is within the prescribed limit. It is not necessary to account the uncertainty associated with the measurement result.

The information provided by the customer in this report may affect the validity of the results, the test lab is not responsible for it.

This report is not used for social proof function in China market.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a \boxtimes comma / \square point is used as the decimal separator.

Name and address of factory (ies):

Ginlong Technologies Co., Ltd.

No. 57 Jintong Road, Binhai Industrial Park, Xiangshan, Ningbo, Zhejiang, 315712, P.R. China.

Page 9 of 99 Report No.: 6108594.50

General product information:

The products are single phase grid-connected photovoltaic inverter converts DC voltage into AC voltage.

The unit is providing EMC filtering at the input and output towards mains. The output was switched off redundant by the high power switching bridge and two relays in series. This assures that the opening of the output circuit will also operate in case of one error.

Block Diagram INVENTER LC波波 GRID RELAY IN+ 11 DC1 EMC滤 波器 >12 RCMU MONITOR DC/DC DSP DC/AC DSP GROUND DETECTION SCTXD

Description of the electrical circuit and functional safety (redundancy control):

The internal control is redundant built. It consists of two Microcontrollers; the master DSP can control the relays, sample the PV voltage, current and BUS voltage, measures grid voltage, frequency, AC current with injected DC, insulation resistance to ground and residual current. The slave DSP is redundant controller, it is using for control the relay, sample grid voltage, frequency and current. Both microcontrollers communicate with each other.

The voltage and frequency measurement were performed with resistors in serial that were connected directly to line and neutral. Both controllers get these signals and analyse the data.

The unit provides two relays in series in each phase. The relays are test before each start-up. When single-fault applied to one relay, an error code will appear on display panel, another redundant relay provides basic insulation maintained between the PV array and the mains.

Model difference:

- 1. The models Solis-1P1K-4G, Solis-1P1.5K-4G, Solis-1P2K-4G have single MPPT function and identical in hardware and just power derating according software.
- 2. The models Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G have dual MPPT function and identical in hardware and just power derating according software.
- 3. The models Solis-1P1K-4G, Solis-1P1.5K-4G, Solis-1P2K-4G are similar with Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G in software and hardware except the differences of electrical ratings, the number of BUS capacitors and the number of MPPT input.
- 4. The models S5-GR1P2.5K, S5-GR1P3K, S5-GR1P3.6K, S5-GR1P4K, S5-GR1P4.6K which are identical to Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G except max input current is different.
- 5. The models S6-GR1P2.5K, S6-GR1P3K, S6-GR1P3.6K, S6-GR1P4K, S6-GR1P4.6K which are identical to Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G

Page 10 of 99 Report No.: 6108594.50

except max input current is different.

The detail rating difference please see rating label for reference.

The product was tested on:

Hardware version:

Main board: MT2070-V3 Control board: DK1635-V2 LCD board: LG1635-V2

Software version:

DSP: V0C LCD: V0C

Amendment 1 report:

The original report No. 6018912.50 issued by DEKRA dated on 2017-11-28 were updated and including below modifications which were considered as technical modifications:

- --- The standard NRS 097-2-1:2017 was change to NRS 097-2-1:2017 (Edition 2.1 July 2020)
- --- The Manufacturer name of "Ningbo Ginlong Technologies Co., Ltd." was changed to "Ginlong Technologies Co., Ltd."
- --- Add model S5-GR1P2.5K, S5-GR1P3K, S5-GR1P3.6K, S5-GR1P4K, S5-GR1P4.6K. Deleted the model Solis-1P2.5K2-4G and Solis-1P3K-4G-ST of original report.

After reviewing, clause 4.1.13.2 unintentional conducted emissions were considered necessary, the test result see Appendix 3: EMC Report of Conducted Emission in the frequency band 30 kHz to 150 kHz.

Amendment 2 report:

The Amendment 1 No. 6092293.50 issued by DEKRA dated on 2020-12-30 were updated and including below modifications which were considered as technical modifications:

--- Add model S6-GR1P2.5K, S6-GR1P3K, S6-GR1P3.6K, S6-GR1P4K, S6-GR1P4.6K.

After reviewing and evaluated, no test was considered necessary.

Page 11 of 99 Report No.: 6108594.50

	Fage 11 01 99	Report No., 610	30334.30
NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict
4	Requirements		_
	In South Africa, safety is regulated via regulations such as and Safety (OHS) Act, calling on amongst others the elect regulations, which invokes other standards such as SANS	rical installation	_
	Performance aspects are regulated via international stand and licensing conditions, which include relevant parts of the		_
	In this part of NRS 097, 4.1 deals with performance aspec aspects and 4.3 deals with metering.	ts, 4.2 deals with safety	_
4.1	Utility compatibility (Performance aspects)		Р
4.1.1	General		Р
4.1.1.1	This clause describes the technical issues and the responsibilities related to interconnecting an embedded generator to a utility network.	Noticed.	Р
4.1.1.2	The quality of power provided by the embedded generator in the case of the on-site a.c. loads and the power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor. Deviation from these standards represents out-of-bounds conditions. The embedded generator is required to sense the deviation and might need to disconnect from the utility network.	Noticed.	Р
4.1.1.3	All power quality parameters (voltage, flicker, frequency and harmonics) shall be measured at the POC, unless otherwise specified (see annex A).	See appended table.	Р
	NOTE The frequency cannot be changed by an EG.		
	The power quality to be supplied to customers and influenced by SSEG shall comply with NRS 048-2. This implies that the combined voltage disturbances caused by the specific EG and other customers, added to normal background voltage disturbances, may not exceed levels stipulated by NRS 048-2. The maximum emission levels that may be contributed by SSEG are provided in this document (see 4.1.5 to 4.1.10).		Р
	The customer can expect power quality at the POC in line with NRS 048-2. As such, the generator may not contribute significant disturbances to the voltage supplied at the POC. Typical contributions for small customer installations (total installation) are provided in Annex D of NRS 048-4.		Р
4.1.1.4	The embedded generator's a.c. voltage, current and frequency shall be compatible with the utility at the POC.	Noticed.	Р
4.1.1.5	The embedded generator shall be type approved, unless otherwise agreed upon with the utility (see annex A).	Noticed.	Р
4.1.1.6	The maximum size of the embedded generator is limited to the rating of the supply point on the premises.	Rely in the responsibility of the installer.	N/A
4.1.1.7	The utility will approve the size of the embedded generator and will decide on the connection point and conditions. In some cases it may be required to create a separate supply point.		Р

Page 12 of 99 Report No.: 6108594.50

	Page 12 of 99	Report No.: 610	36594.50
NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict
4.1.1.8	Embedded generators larger than 13.8 kVA shall be of the balanced three-phase type unless only a single-phase network supply is available, in which case NRS 097-2-3 recommendations can be applied based on the NMD.	Less than 13.8 kVA	N/A
	NOTE 1 This value refers to the maximum export potential of the generation device/system.		
	NOTE 2 In the case of long feeder spurs the maximum desired capacity of the EG might require approval by the utility and might result in the requirement for a three-phase connection for smaller units.		
4.1.1.9		Single phase inverter used in single phase network.	N/A
	NOTE Balancing phases in a multiphase embedded generator is deemed desirable.		
4.1.1.10	Embedded generators or generator systems larger than 100 kVA may have additional requirements, for example, they must be able to receive communication signals for ceasing generation/disconnection from the utility supply, if the utility requires such. Communication facilities shall be provided to utility at no charge for integration with SCADA or other system when required. See Annex G (G.1).	Less than 13.8 kVA	N/A
	NOTE The RPP Grid Code requires category A3 units to be able to interface with the utility in order to receive stop and start signals.		
4.1.1.11	In line with the current Renewable Power Plant Grid Code, embedded generators smaller than 1000 kVA connected to low-voltage form part of Category A generators, with the following subcategories:		Р
	a) Category A1: 0 – 13.8 kVA;	Category A1 generator	Р
	This sub-category includes RPPs of Category A with rated power in the range from 0 to 13.8 kVA, inclusive of 13.8 kVA.		
	b) Category A2: 13.8 kVA - 100 kVA; and		N/A
	This sub-category includes RPPs of Category A with rated power in the range greater than 13.8 kVA but less than 100 kVA.		
	c) Category A3: 100 kVA - 1 MVA.		N/A
	This sub-category includes RPPs of Category A with rated power in the range from 100 kVA but less than 1 MVA.		
	NOTE 1 These sub-categories must be cross-checked with the Renewable Power Plant Grid Code (or other part of the Grid Code where applicable); where applicable, requirements will apply per sub-category and not per sizes defined here.		N/A

Page 13 of 99 Report No.: 6108594.50

	NRS 097-2-1:2017	торысто от	
Clause	Requirement – Test	Result – Remark	Verdict
	NOTE 2 Until a separate Grid Code for non-renewable technologies have been compiled and published, relevant categories from this document will apply to non-renewable SSEG.		N/A
4.1.1.12	In accordance with SANS 10142-1, all generators shall be wired permanently.		Р
	NOTE 1 Some international companies are distributing so-called "plug-in" generators, where a small PV panel and inverter is connected to the supply circuit via a standard (load) plug. At present such installations are not regarded as safe and in contravention of SANS 10142-1.		Р
	NOTE 2 This option will be reviewed when internationally accepted norms are finalised to ensure plugs and plug points are safe when feeding power into the grid as well as additional requirements for such generators or plugs.		Р
4.1.1.13	Any UPS/generating device that operates in parallel with the grid may only connect to the grid when it complies fully with the requirements of this part of NRS 097. This includes UPS configurations with or without EG.		Р
	NOTE The requirement is applicable irrespective of the duration of parallel operation.		
4.1.1.14	Standby-generators are covered by SANS 10142-1.		N/A
4.1.1.15	All generators larger than 100 kVA will be controllable, i.e. be able to control the active output power dependent on network conditions/abnormal conditions. This includes several smaller units that totals more than 100 kVA at a single POC.		N/A
4.1.1.16	Maximum DC Voltage may not exceed 1000V. This is the voltage on the DC side of the inverter, for example when no load is taken and maximum source energy is provided, e.g. peak solar radiation occurs on the solar panels.	Maximum DC voltage 600 V.	Р
4.1.2	Normal voltage operating range		Р
4.1.2.1	In accordance with IEC 61727, utility-interconnected embedded generators do not normally regulate voltage, they inject current into the utility. Therefore the voltage operating range for embedded generators is designed as protection which responds to abnormal utility network conditions and not as a voltage regulation function.		Р
4.1.2.2	The embedded generator shall synchronise (see 4.1.12) with the utility network before a connection is established. The embedded generator shall not control the voltage, unless agreed to by the utility (see annex A).	See clause 4.1.12	Р
4.1.2.3	An embedded generator that operates in parallel with the utility system shall operate within the voltage trip limits defined in 4.2.2.3.2.		Р
4.1.3	Reference source impedance and short-circuit levels (fault levels)		Ρ

Page 14 of 99 Report No.: 6108594.50

	PAGE 14 01 99	Report No., 610	7000-4.00
NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict
4.1.3.1	The impact of the generator on the network voltage and quality of supply levels is directly linked to the (complex) source impedance and short-circuit level. The minimum short-circuit level to which a generator can be connected should be based on the size of the generator as well as the design criteria.		Р
4.1.3.2	For general purposes of testing and design for potential worst case conditions, a minimum network strength of the following may be assumed:		Р
	Z_source = 1.05 + j 0.32 ohm, i.e. I_SC = 210 A and S_SC = 146 kVA (three-phase).		
	NOTE This does not imply a guarantee that the fault level will be more than this at all times. Fault levels less than this may be sufficient for small loads in certain applications.		
4.1.3.3	The maximum network strength will be assumed to be no more than 33 times the rated active power of the generator. The R/X ratio will be assumed between 0.33 to 3.		Р
	NOTE 1 In practice, the generators will connect to the network at a wide range of short-circuit ratios. The assumption of a maximum ratio of 33 will allow safe connection of the SSEG in most practical situations.		Р
	NOTE 2 The minimum fault level at which the generator may be connected is at the discretion of the manufacturer, provided that the requirements of this specification is met at the specified fault level.		
4.1.3.4	The relevant utility will advise whether equipment may be connected at other network characteristics, i.e. for weaker parts of the network.		Р
4.1.3.5	The generator documentation and nameplate shall state the reference impedance (complex impedance) and fault level that was used for design and certification and that it is not intended to connect the generator to a network with a higher network impedance than specified for the certification.		Р
	NOTE See Annex C (Network Impedance), for more information.		
4.1.4	General QOS requirements		Р
4.1.4.1	Embedded generators can expect QOS levels on networks to be in line with NRS 048-2. It is expected that the embedded generator will be able to operate continuously under worst-case conditions.		Р
4.1.4.2	Notwithstanding this, the embedded generator must protect itself from potential excursions beyond NRS 048-2 and ensure fail-safe conditions. Should the embedded generator be unable to operate according to requirements of this document for such excursions, it shall disconnect and cease generation onto the network.		Р
4.1.5	Flicker and voltage changes	See appended table.	Р
<u> </u>	- I	l	<u> </u>

Page 15 of 99 Report No.: 6108594.50

	NDC 007 2 4-2047	Nepolt No., on	0000-100
NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict
4.1.5.1	When connected to a network impedance equal to the reference impedance used during certification, no SSEG may generate flicker levels higher than the following:		Р
	a) short-term flicker severity (Pst) = 0.35; and		
	b) long-term flicker severity (Plt) = 0.30.		
4.1.5.2	It is anticipated that the utility will plan the connections in line with acceptable flicker limits, i.e. the ratio of the size of the generator to the network strength at the point of connection.		Р
4.1.5.3	According to VDE-AR-N 4105, no generator shall be connected to a system where generation rejection (i.e. tripping of SSEG while generating at full capacity, regardless of reason) will lead to a voltage change of 3 % or more at the PCC, thereby minimising the potential to exceed rapid voltage change limits.		Р
	NOTE 1 A voltage change of 3 % aligns to a ratio of the network fault level to generator size of 33 (ignoring network impedance angle and load power factor).		Р
	NOTE 2 Standard connection conditions for customers typically include a maximum flicker contribution in line with annex D of NRS 048-4. Should these flicker levels be exceeded, the customer will be required to put mitigating measures in place as and when required by the utility.		
4.1.6	Voltage unbalance		Р
4.1.6.1	Under normal circumstances, for single and dual-phase EG, the unbalanced generation may not exceed 4.6 kVA connected between any two or different phases at an installation. Units larger than 4.6 kVA will be split evenly over the available phase connections so that this can be maintained.		Р
	NOTE Depending on the network capacity, the utility may impose more stringent conditions.		
4.1.6.2	Three-phase generators may not contribute more than 0.2 % voltage unbalance when connected to a network with impedance equal to the reference impedance.	Single phase PV inverter.	N/A
	NOTE Standard connection conditions for customers typically include a maximum voltage unbalance contribution in line with NRS 048-4, Annex D. Should a three-phase customer exceed these voltage unbalance levels, the customer will be required to put mitigating measures in place as and when required by the utility.		
4.1.7	Commutation notches		Р
	The relative depth of commutation notches due to line-commutated inverters shall not exceed 5 % of nominal voltage at the POC for any operational state.		Р
4.1.8	DC injection		Р
		i	1

Page 16 of 99 Report No.: 6108594.50

	Page 16 of 99	Report No.: 61	00394.30
	NRS 097-2-1:2017	T	
Clause	Requirement – Test	Result – Remark	Verdict
4.1.8.1	The average d.c. current injected by the embedded generator shall not exceed 0.5 % of the rated a.c. output current over any 1-minute period, into the utility a.c. interface under any operating condition.	See appended table.	Р
4.1.8.2	According to section 4.2.2.5, the generator(s) must disconnect within 500 ms when the d.c. current exceeds this value.	See appended table.	Р
4.1.9	Normal frequency operating range		Р
	An embedded generator that operates in parallel with the utility system shall operate within the frequency trip limits defined in 4.2.2.3.3.		Р
4.1.10	Harmonics and waveform distortion		Р
4.1.10.1	Only devices that inject low levels of current and voltage harmonics will be accepted; the higher harmonic levels increase the potential for adverse effects on connected equipment.		Р
4.1.10.2	Acceptable levels of harmonic voltage and current depend upon distribution system characteristics, type of service, connected loads or apparatus, and established utility practice.		Р
4.1.10.3	The embedded generator output shall have low current-distortion levels to ensure that no adverse effects are caused to other equipment connected to the utility system.		Р
4.1.10.4	The harmonic and inter-harmonic current distortion shall comply with the relevant emission limits in accordance with IEC 61727, reproduced in table 1. Table 1 — Maximum harmonic current distortion as percentage of rated current		Р
	1 2 3 4 5 6 Harmonic order (h) h<11 115h<17 175h<23 235h<35 355h		
	Percentage of rated current 4,0 2,0 1,5 0,6 0,3 (Odd harmonics)		
	Percentage of rated current 1,0 0,5 0,38 0,15 0,08 (Even harmonics)		
	Percentage of rated current (Inter-harmonics)		
	NOTE 1 Even harmonics are limited to 25 % of the odd harmonic limits NOTE 2 Inter-harmonic are limited to 25 % of the odd harmonic limits and adjusted for the 200 Hz band measurement required by IEC 61000-4-7, except for the lower frequencies where the flicker contribution is more likely. NOTE 3 Total Demand Distortion = Total Harmonic Distortion		
4.1.10.5	The harmonic and inter-harmonic distortion applies up to 3 kHz (60th harmonic).	See appended table.	Р
	NOTE The harmonic limits above 2.5 kHz and all inter- harmonic limits refer to limits measured in accordance with IEC 61000-4-7.		
4.1.11	Power factor		Р
4.1.11.1	Irrespective of the number of phases to which an embedded generator is connected, it shall comply with the power factor requirements in accordance with 4.1.11.2 to 4.1.11.12 on each phase for system normal conditions when the output power exceeds 20 % of rated active power.	See appended table.	P

	Page 17 of 99	Report No.: 61	08594.50
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
4.1.11.2	For static power converter embedded generators and synchronous embedded generators of sub-categories A1 and A2, the power factor shall remain above 0.98 as shown in Figure 1. The embedded generator shall operate anywhere in the shaded area of figure 1.	Category A1 static power converter generator.	P
	with the RPP Grid Code.		
4.1.11.3	For asynchronous embedded generators of subcategories A1 and A2, which cannot control the power factor over any range, the power factor shall reach the shaded area of figure 1 within 60 s. The power factor shall remain above 0.98 as shown in figure 1. The embedded generator shall operate anywhere in the shaded area. NOTE At the time of publication, this is in contradiction with the RPP Grid Code.	Category A1 static power converter generator.	N/A
4.1.11.4	For static power converter embedded generators and synchronous embedded generators of sub-category A3, the power factor shall remain above 0.95 as shown in Figure 2. The embedded generator shall operate anywhere in the shaded area of Figure 2.	Category A1 static power converter generator.	N/A
4.1.11.5	For asynchronous embedded generators of sub-category A3, which cannot control the power factor over any range, the power factor shall reach the shaded area of Figure 2 within 60 s. The power factor shall remain above 0.95 as shown in Figure 2. The embedded generator shall operate anywhere in the shaded area.	Category A1 static power converter generator.	N/A
	III Over-excited Over-excited Figure 2 — Power factor operating requirements for SSEG categoried A3 (using the load-reference arrows system)		

Page 18 of 99 Report No.: 6108594.50

	1 age 10 01 33	report No.: 01	000000
	NRS 097-2-1:2017		1
Clause	Requirement – Test	Result – Remark	Verdict
4.1.11.6	Where the EG is capable of controlling the power factor at the POC, the EG should improve the power factor at the POC towards unity.		Р
4.1.11.7	Unless otherwise agreed with the utility, the standard power factor setting shall be unity for the full power output range.		Р
4.1.11.8	The maximum tolerance on the reactive power setting is 5 % of the rated active power.		Р
4.1.11.9	For embedded generators of sub-category A3, the power factor shall be settable to operate according to a characteristic curve provided by the utility, if required by the utility, within the range 0.95 leading and 0.95 lagging; An example of a standard characteristic curve is shown in figure 3.	Category A1 static power converter generator.	N/A
	Example of power factor characteristic curve 1.01 1.01 1.02 1.03 1.04 1.05 1.09 1.		
	Figure 3 — Example of power factor characteristics curve (under-excited)		
4.1.11.10	These limits apply, unless otherwise agreed upon with the utility (see annex A).		Р
4.1.11.11	Equipment for reactive power compensation shall either:		Р
	a) be connected or disconnected with the embedded generator, or b) operated via automatic control equipment for		Р
	disconnection when not required.		
4.1.11.12	The requirement for and type of detuning for reactive power compensation devices will be agreed upon by the owner of the generator and utility.		Р
	NOTE Detuning is highly recommended for all reactive power compensation devices to prevent (a) potential current overloading of capacitors due to existing voltage harmonics, (b) potential voltage transient amplification at the POC due to upstream switching conditions, and (c) potential resonance with the network impedance that may lead to excessive harmonic amplification.		Р
4.1.12	Synchronization		Р
4.1.12.1	All embedded generators shall synchronize with the utility network before the parallel connection is made. This applies to all embedded generators where a voltage exists at the generator terminals before connection with the utility network.		Р

Page 19 of 99 Report No.: 6108594.50

	Page 19 of 99	Report No.: 61	08594.50	
	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	
4.1.12.2	Automatic synchronization equipment shall be the only method of synchronization.		Р	
4.1.12.3	For a synchronous generator, the limits for the synchronizing parameters for each phase are: a) frequency difference: 0.3 Hz, b) voltage difference: 5 % of nominal voltage per phase, and c) phase angle difference: 20 ° (degrees).		Р	
4.1.12.4	Mains excited generators do not need to synchronise when the generator is started as a motor before generation starts.		Р	
4.1.12.5	Mains excited generators may require soft-starting when the start-up voltage change is anticipated to be more than 3 %.		Р	
4.1.12.6	The start-up current for static power converters shall not exceed the full-power rated current of the generator.		Р	
4.1.12.7	Also refer to 4.2.4 for re-synchronising conditions.		Р	
4.1.12.8	The embedded generator shall synchronize with the utility network only when the voltage and frequency has been stable within the ranges provided in 4.2.2.3 for at least 60 seconds. NOTE Some utilities may require this to be longer than		Р	
	60 seconds.			
4.1.13	Electromagnetic compatibility (EMC)		Р	
4.1.13.1	Electromagnetic compatibility (EMC) refers to the ability of equipment or a system to function satisfactorily in its electromagnetic environment without introducing intolerable electromagnetic disturbances to anything in that environment. EMC comprises two components, namely a radiated and conducted component. Significant attention is given to radiated EMC due to the potential impact over larger distances. However, with advances in smart grids and business management systems, the potential impacts from conducted EMI must be considered. The conditions in 4.1.13.2 and 4.1.13.6 below apply to conducted unintentional signals, while clause 4.1.13.7 applies to radiated unintentional emissions from generating equipment.	See TUV SUD EMC test report no.: 64.772.21.80058.02 for reference.	P	

Page 20 of 99

Report No.: 6108594.50

	NRS 097-2-1:2017	•	
Claves	1	Decult Demont	\/o.rd:o.t
Clause	Requirement – Test	Result – Remark	Verdict
4.1.13.2	All unintentional conducted emissions from generating equipment, in the frequency band 30 kHz to 150 kHz, shall be 9 dBµV lower than the compatibility levels specified in clause 4.12.3 of IEC 61000-2-2:2000+A2: 2018 when measured in unsymmetrical voltage mode (i.e. between any phase or neutral and the earth) using a quasi-peak detector. An illustration of the limits is provided in Figure 4, below.	See Appendix 3: EMC Report of Conducted Emission in the frequency band 30 kHz to 150 kHz with report No. 20C0120R- V2 by issued DEKRA.	Р
	TOTAL STATE OF THE		
4.1.13.3			-
4.1.13.3	The test method and set up for verifying compliance with 4.1.13.1, herein, shall be according to clause 7 of CISPR 16-2-1. The test receiver used for verification shall comply with clauses 4 and 5 of CISPR 16-1-1:2019, and the AMN or LISN used for verification shall comply with clause 4 of CISPR 16-1-2. NOTE When measuring conducted emissions at high currents, for example at ≥ 25 A, during testing, the AMN or LISN can be		Р
	connected as a voltage probe. See clause A.5 in Annexure A of CISPR 16-1-1.		
4.1.13.4	All unintentional conducted emissions from generating equipment, in the frequency band above 150 kHz to 30 MHz, shall comply with SANS 211 (CISPR11), in particular limits for Class A group 1 (< 20 kVA).	See TUV SUD EMC test report no.: 64.772.21.80058.02 for reference.	Р
4.1.13.5	The conducted emission requirement applies to all ports or connections to the utility supply, whether the connection is intended for monitoring, communication, power transfer or any other reason for connecting to the utility supply.		Р
4.1.13.6	In the event of susceptibility to electromagnetic interference, the unit shall be fail-safe, i.e. any deviation from intended performance must comply with all relevant specifications, both in terms of safety (i.e. disconnection) and impact on the network.		Р
4.1.13.7	Notwithstanding this, should any interference be experienced to existing or new ripple-control, building management system equipment and/or other PLC-based communication, the owner of the embedded generator should take the necessary remedial action to prevent further interference as will be agreed with the utility or the other affected party.		Р
4.1.13.8	All radiated emissions from generating equipment shall comply with ICASA requirements.		Р

Page 21 of 99 Report No.: 6108594.50

	1 age 21 01 33		0 0100004.00
	NRS 097-2-1:2017		T
Clause	Requirement – Test	Result – Remark	Verdict
4.1.14	Mains signalling (e.g. PLC and ripple control)		N/A
4.1.14.1	Mains signalling refers to intentional signals induced into the utility supply network, where the intention is to facilitate data transfer from one component to another.		N/A
4.1.14.2	All intentional emissions (communication signals) from generating equipment shall comply with limits for intentional emissions in SANS 50065-1, limited to an acceptable band as prescribed by SANS 50065-1.		N/A
4.1.14.3	Notwithstanding this, should any interference be experienced to existing or new ripple control, building management system equipment and/or other PLC-based communication, the owner of the embedded generator shall take the necessary remedial action to prevent further interference as will be agreed with the utility or the other affected party.		N/A
4.2	Safety protection and control		Р
4.2.1	General	Noticed.	Р
	The safe operation of the embedded generator in conjunction with the utility network shall be		Р
	ensured at all times. Safe operation includes people and equipment safety, i.e.:		
	a) People safety: and		Р
	i) owner (including personnel and / or inhabitants of the property) of the embedded generator;		
	ii) general public safety;		
	iii) utility personnel; and		
	iv) general emergency response personnel, e.g. fire brigade should a fire arise at the embedded generator.		
	b) Equipment safety:		Р
	i) utility equipment;		
	ii) other customers' equipment connected to the same network(s); and		
	iii) generator own equipment.		
	Some of the safety aspects mentioned above may be covered in other specifications and standards and the embedded generator should ensure that safe operation is maintained at all times taking cognisance of all of the above aspects.		P
	Furthermore, the embedded generator owner is responsible for precautions against damage to its own equipment due to utility originating events, e.g. switching events, voltage and frequency variations, automatic reclosing onto the network etc. However, this protection may not conflict with the requirements of this specification.		Р
4.2.2	Safety disconnect from utility network		Р
4.2.2.1	General		Р

Page 22 of 99 Report No.: 6108594.50

	Page 22 of 99	Report No.: 610	30334.30	
	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	
4.2.2.1.1	All SSEG shall comply with the safety requirements in accordance with SANS/IEC 62109-1 and IEC 62109-2.	See TUV SUD IEC 62109- 1/-2 test report no.: 70.409.16.237.04-05 for	Р	
	NOTE In principle, IEC 62109 documents only apply to PV inverters. However, other SSEG shall prove compliance to these safety requirements to the satisfaction of the utility.	reference.		
4.2.2.1.2	The embedded generator shall automatically and safely disconnect from the grid in the event of an abnormal condition. Abnormal conditions include:		Р	
	a) network voltage or frequency out-of-bounds conditions,			
	b) loss-of-grid conditions,c) d.c. current injection threshold exceeded (per phase),d) and residual d.c. current (phase and neutral currents summated).			
4.2.2.2	Disconnection device (previously disconnection switching unit)	See appended table.	Р	
4.2.2.2.1	The embedded generator shall be equipped with a disconnection device, which separates the embedded generator from the grid due to abnormal conditions. The disconnection unit may be integrated into one of the components of the embedded generator (for example the PV utility-interconnected inverter) or may be an independent device installed between the embedded generator and the utility interface.	The grid-connected PV inverter provides two relays integrated in series for both line and neutral.	P	
4.2.2.2.2	The disconnection switching unit shall be able to operate under all operating conditions of the utility network.		Р	
	NOTE It is the responsibility of the embedded generator owner to enquire about the operating conditions of the utility network, e.g. fault levels for the foreseeable future.			
4.2.2.2.3	A failure within the disconnection device shall lead to disconnection of the generator from the utility supply and indication of the failure condition.	See appended table.	Р	
4.2.2.2.4	A single failure within the disconnection switching unit shall not lead to failure to disconnect. Failures with one common cause shall be taken into account and addressed through adequate redundancy.	See appended table.	Р	
4.2.2.2.5	The disconnection device shall disconnect the generator from the network by means of two series connected robust automated load disconnect switches.	The grid-connected PV inverter provides two relays integrated in series for both line and neutral.	Р	
4.2.2.2.6	Both switches shall be electromechanical switches.		Р	
4.2.2.2.7	Each electromechanical switch shall disconnect the embedded generator on the neutral and the live wire(s).		Р	
	NOTE The switching unit need not disconnect its sensing circuits.			
4.2.2.2.8	All rotating generating units, e.g. synchronous or asynchronous generating units shall have adequate redundancy in accordance with 4.2.2.2.5.	Not rotating generating units.	N/A	

Page 23 of 99 Report No.: 6108594.50

Page 23 of 99	Report No.: 610	0000 1.00
NRS 097-2-1:2017		
Requirement – Test	Result – Remark	Verdict
A static power converter without simple separation shall make use of two series connected electromechanical disconnection switches.	The grid-connected PV inverter provides two relays integrated in series for both line and neutral.	Р
The current breaking capacity of each disconnecting switch shall be appropriately sized for the application. In cases where the disconnecting device is an electromechanical switching device such as a contactor, this requires suitable coordination with the upstream short circuit protection device (circuit breaker).		Р
Any programmable parameters of the disconnection switching unit shall be protected from interference by third-parties, i.e. password protected or access physically sealed.		Р
In order to allow customers to supply their own load in isolated operation (islanded) where this is feasible and required, the disconnection device may be incorporated upstream of part of or all of a customers' loads, provided that none of the network disconnection requirements in this document are violated.		Р
All EG installations larger than 30 kVA shall have a central disconnection device.	Category A1 static power converter generator less	N/A
NOTE 1 This requirement may be amended by the utility, i.e. the utility may require a central disconnection switch unit for any size and type of generator.	than 30kVA.	
NOTE 2 This requirement may be amended by the utility. The central disconnection switch unit will typically be waived only when a lockable disconnection switch, accessible to the utility, is installed.		
NOTE 3 This is an interim requirement based on requirements of VDE-AR-N 4105 and will be revisited as more information becomes available.		
The network and system grid protection voltage and frequency relay for the central disconnection device will be type-tested and certified on its own (stand-alone tested). All clauses of 4.2.2, except 4.2.2.4 (anti-islanding) apply.	Not used central disconnection device.	N/A
Overvoltage, undervoltage and frequency		
General	See appended table.	Р
The values in 4.2.2.3 relate to SSEG in sub-categories A1 and A2. These are kept from a historical perspective. The Grid Code requirements will override values and requirements in this category.	Category A1 static power converter generator.	Р
Sub-category A3 generators shall disconnect from the network according to the RPP Grid Code for all abnormal conditions as well as stay connected in accordance with the voltage ride-through requirements of the RPP Grid Code.		N/A
	Requirement – Test A static power converter without simple separation shall make use of two series connected electromechanical disconnection switches. The current breaking capacity of each disconnecting switch shall be appropriately sized for the application. In cases where the disconnecting device is an electromechanical switching device such as a contactor, this requires suitable coordination with the upstream short circuit protection device (circuit breaker). Any programmable parameters of the disconnection switching unit shall be protected from interference by third-parties, i.e. password protected or access physically sealed. In order to allow customers to supply their own load in isolated operation (islanded) where this is feasible and required, the disconnection device may be incorporated upstream of part of or all of a customers' loads, provided that none of the network disconnection requirements in this document are violated. All EG installations larger than 30 kVA shall have a central disconnection device. NOTE 1 This requirement may be amended by the utility, i.e. the utility may require a central disconnection switch unit for any size and type of generator. NOTE 2 This requirement may be amended by the utility. The central disconnection switch unit will typically be waived only when a lockable disconnection switch, accessible to the utility, is installed. NOTE 3 This is an interim requirement based on requirements of VDE-AR-N 4105 and will be revisited as more information becomes available. The network and system grid protection voltage and frequency relay for the central disconnection device will be type-tested and certified on its own (stand-alone tested). All clauses of 4.2.2, except 4.2.2.4 (antislanding) apply. Overvoltage, undervoltage and frequency General The values in 4.2.2.3 relate to SSEG in sub-categories A1 and A2. These are kept from a historical perspective. The Grid Code requirements will override values and requirements in this category. Sub-category A3 generators shall	Requirement – Test Result – Remark A static power converter without simple separation shall make use of two series connected electromechanical disconnection switches. The current breaking capacity of each disconnecting switch shall be appropriately sized for the application. In cases where the disconnecting device is an electromechanical switching device such as a contactor, this requires suitable coordination with the upstream short circuit protection device (circuit breaker). Any programmable parameters of the disconnection switching unit shall be protected from interference by third-parties, i.e. password protected or access physically sealed. In order to allow customers to supply their own load in isolated operation (islanded) where this is feasible and required, the disconnection device may be incorporated upstream of part of or all of a customers loads, provided that none of the network disconnection requirements in this document are violated. All EG installations larger than 30 kVA shall have a central disconnection device. NOTE 1 This requirement may be amended by the utility, i.e. the utility may require a central disconnection switch unit for any size and type of generator. NOTE 2 This requirement may be amended by the utility. The central disconnection switch unit will typically be waived only when a lockable disconnection switch, accessible to the utility, is installed. NOTE 3 This is an interim requirement based on requirements of VDE-AR-N 4105 and will be revisited as more information becomes available. The network and system grid protection voltage and frequency relay for the central disconnection device will be type-tested and certified on its own (stand-alone tested). All clauses of 4.2.2, except 4.2.2.4 (antisianding) apply. Overvoltage, undervoltage and frequency General The values in 4.2.2.3 relate to SSEG in sub-categories A1 and A2. These are kept from a historical perspective. The Grid Code requirements will override values and requirements in this category. See appended tabl

		Page 24 of 99	Report No.:	6108594.50
	T	NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict
	requires a response from to generator. This response is maintenance personnel are to avoid damage to conneutility conditions of concert excursions above or below	s to ensure the safety of utiled the general public, and all cted equipment. The abnorman are voltage and frequency the values stated in this Code (section 5.2 of version rator shall disconnect in	lity Iso mal	P
	to +1 % of the nominal vo	rip values shall be within 0 tage from the upper bounds to 0% of the nominal voltarip setting.	ary	Р
	to +0.1 % of the fundamer boundary trip setting, and	by trip values shall be within tal frequency from the uppo- within -0.1 % to 0 % of the om the lower boundary the to	er	P
4.2.2.3.2	Overvoltage and undervol	tage	See appended table.	Р
	shall cease to energize the should the network voltage specified in table 2. The formet, with voltages in r.m.s NOTE 1 All discussions rethe nominal voltage. NOTE 2 At the time of put contradiction to the RPP 6	e deviate outside the conditional conditional conditions shall be a and measured at the POC garding system voltage referring condition, these settings are a conditional condi	c. er to in be	P
	generally be sufficient for expected voltage drop acr EG to the POC is too high have to be adjusted.	the generator terminals will the overvoltage settings. If oss the cable connecting th , undervoltage settings migh ages for SSEG in sub-categories A1 and A	the e ht	
	1 Voltage grans	2 Maximum trip time		
	Voltage range (at point of connection)	S		
	V < 50 %	0,2 s		
	50 % ≤ V < 85 % 85 % ≤ V ≤ 110 %	10 s Continuous operation		
	110 % < V < 115 %	40 s		
	115% ≤ V < 120%	2 s		
		0,16 s ings are not possible, the more stringent e.g. 2 s between 110% and 120% of		

Page 25 of 99 Report No.: 6108594.50

	Page 25 of 99	Report No.: 61	08594.50
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
	The purpose of the allowed time delay is to ride through short-term disturbances to avoid excessive nuisance tripping. The generator does not have to cease to energize if the voltage returns to the normal utility continuous operating condition within the specified trip time.		P
	NOTE Induction/synchronous generators need to be mindful of synchronisation issues and may have to apply faster trip times.		
	A customer with a multiphase connection shall monitor all phases for out-of-bounds voltage conditions. The EG shall be disconnected if an out-of-bounds voltage condition is detected on any of the phases.		P
	In line with NRS 048-2, it is recommended that A1 and A2 SSEG be able to ride through at least Y and X1 type dips, i.e. not disconnect for these events. The purpose is to avoid excessive nuisance tripping.		Р
	Category A3 SSEG shall be able to ride through low and/or high voltage events in accordance with the RPP Grid Code.		N/A
	The generator shall maintain the pre-dip current during any dip event for which it remains connected.		Р
	The ride-through and trip times are shown graphically in figure 4. Decreed 0.16s Decreed 4.1bs Discorded 11bs Discorded 11bs		P
	30% 32% 33% 9% 9% 9% 9%		
	Figure 5 — Graphical representation of voltage-ride-through and voltage disconnect requirements for A1 and A2 EG		
4.2.2.3.3	Over-frequency and under-frequency	See appended table.	Р
	This requirement is in line with the RPP Grid Code (version 3.0) and applies to all EG in category A. NOTE The RPP Grid Code should be consulted for developments in the requirements for response to over-frequency and under-frequency events.		P
	The embedded generation system shall cease to energize the utility network when the utility frequency deviates outside the specified conditions. Both over- and under-frequency conditions indicate system abnormal conditions and all generators are expected to assist in stabilising the system during such periods.		Р
	When the utility frequency is less than 47 Hz, the embedded generator shall disconnect from the utility network within 0.2 s.		Р

Page 26 of 99 Report No.: 6108594.50

	Page 26 of 99	Report No.: 61	08594.50
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
	While the utility frequency is in the range of 47 Hz and 50.5 Hz, the system shall operate normally. In order to prevent hysteresis switching (on-off toggling) during overfrequency conditions, the output power shall be reduced as follows:		Р
	When the utility frequency exceeds 50.5 Hz, the active power available at the time shall be stored as the maximum power value P _M ; this value P _M shall not be exceeded until the frequency has stabilised below 50.5 Hz for at least 4 seconds.		Р
	The EG system shall control the output power as a function of PM at a gradient of 50 % per Hertz as illustrated in figure 5. The power generation shall follow the curve shown in figure 5 up and down while the system frequency is in the range 50.5 Hz to 52 Hz.		P
	When the utility frequency is more than 52 Hz for longer than 4 seconds, the embedded generator shall cease to energise the utility line within 0.5 s.		Р
4.2.2.3.3. 1	Relaxation for non-controllable generators		Р
	Non-controllable generators may disconnect randomly within the frequency range 50.5 Hz to 52 Hz. The disconnect frequency for non-controllable generators will each be set at a random value by the manufacturer, with the option of changing this to a utility provided setting. The random disconnect frequency shall be selected so that all generators from any specific manufacturer will disconnect uniformly over the range with 0.1 Hz increments.		P
	When the utility frequency is more than the non-controllable generator over-frequency setpoint for longer than 4 seconds, the non-controllable generator shall cease to energise the utility line within 0.5 s. NOTE At the time of publication, this is in contradiction with the RPP Grid Code. Power curtailment during over-frequency 110		P
4.2.2.4			P
7.2.2.4	Prevention of islanding		Г

Page 27 of 99 Report No.: 6108594.50

	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	
4.2.2.4.1	A utility distribution network can become de-energized for several reasons: for example, a substation breaker that opens due to a fault condition or the distribution network might be switched off for maintenance purposes. Should the load and (embedded) generation within an isolated network be closely matched, then the voltage and frequency limits may not be triggered. If the embedded generator control system only made use of passive voltage and frequency out-of-bounds detection, this would result in an unintentional island that could continue beyond the allowed time limits.	See appended table.	Р	
4.2.2.4.2	In order to detect an islanding condition, the embedded generator shall make use of at least one active islanding detection method. An active islanding detection method intentionally varies an output parameter and monitors the response or it attempts to cause an abnormal condition at the utility interface to trigger an out-of-bounds condition. If the utility supply is available, the attempt to vary an output parameter or cause an abnormal condition will fail and no response will be detected. However, if the utility supply network is de-energized, there will be a response to the change which can be detected. This signals an island condition to the embedded generator upon detection of which the embedded generator shall cease to energize the utility network within a specific time period.	The active islanding detection methods frequency shifting was employed in the gridconnected PV inverter.	P	
4.2.2.4.3	Active island detection shall be used in all cases where the EG interfaces with the utility network.		Р	
4.2.2.4.4	An islanding condition shall cause the embedded generator to cease to energize the utility network within 2 s, irrespective of connected loads or other embedded generators. The embedded generator employing active islanding detection shall comply with the requirements of IEC 62116 (ed.1). NOTE Prevention of islanding measures is only considered on the embedded generator side, i.e. no utility	See appended table.	Р	
	installed anti-islanding measures are considered.			
4.2.2.4.5	All rotating generators shall use a minimum of two islanding detection methods (e.g. rate-of-change-of-frequency and voltage vector shift detection due to the dead bands (slow detection) of islands in both methods).	Not rotating generator.	N/A	
	NOTE It is possible for a condition to exist, where a mains-excited generator becomes self-excited due to capacitance of the network (either cable capacitance or power factor correction). Under such conditions, the mains-excited generator will not disconnect from an island, hence effective islanding detection is required for all rotating generators.			
4.2.2.4.6	Passive methods of islanding detection shall not be the sole method to detect an island condition. When used, passive methods of islanding detection shall be done by three-phase voltage detection and shall be verified by an AC voltage source.		Р	

Page 28 of 99 Report No.: 6108594.50

NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict
4.2.2.4.7	The embedded generator shall physically disconnect from the utility network in accordance with the requirements in 4.2.2.2.		Р
4.2.2.5	DC current injection	See appended table.	Р
	The embedded generator shall not inject d.c. current greater than 0.5 % of the rated a.c. output current into the utility interface under any operating condition, measured over a 1-minute interval. The EG shall cease to energize the utility network within 500 ms if this threshold is exceeded.		P
4.2.3	Emergency personnel safety		Info.
	No requirements for emergency personnel safety (e.g. fire brigade) existed at the time of publication. It is expected that such issues will be dealt with in other documents, e.g. OHS Act, SANS 10142-1.		Info.
4.2.4	Response to utility recovery		Р
4.2.4.1	The embedded generator shall ensure synchronisation before re-energizing at all times in accordance with 4.1.12.		Р
4.2.4.2	After a voltage or frequency out-of-range condition that has caused the embedded generator to cease energizing the utility network, the generator shall not re-energize the utility network until the utility service voltage and frequency have remained within the specified ranges for a continuous and uninterrupted period of 60 s. The reconnection shall commence as follows:		P
4.2.4.2.1	Non-controllable generators may connect randomly within the 1 minute to 10 minute period after voltage and frequency recovery (period includes the 60 s to confirm recovery). The delay for non-controllable generators will each be set at a random value by the manufacturer, with the option of changing this to a utility provided setting. The random value shall be selected so that no more than 2 % of generators from any specific manufacturer will reconnect within 10s of each other.		P
4.2.4.2.2	Controllable generators may reconnect immediately after the 60 s delay confirming recovery of the system voltage and frequency at a maximum rate of 10 % of rated power per minute, i.e. full power output will only be reached after 10 minutes.		N/A
	This ramp rate may be modified at the request of the utility or in consultation with the utility.		Р
4.2.5	Isolation		Р
4.2.5.1	In line with SANS 10142-1 (as amended), each energy source should have its own, appropriately rated, isolation device.		Р
4.2.5.2	It is expected that isolation requirements will be dealt with in more detail in future in e.g. SANS 10142-1/3. Such requirements shall supersede 4.2.5.		Р

Page 29 of 99 Report No.: 6108594.50

	Page 29 of 99	Report No.: 61	08594.50
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
4.2.5.3	The embedded generator shall provide a means of isolating from the utility interface in order to allow for safe maintenance of the EG. The disconnection device shall be a double pole for a single-phase EG, a three-pole for a three-phase delta-connected EG, and a four-pole for a three phase star-connected EG. The grid supply side shall be wired as the source.		P
4.2.5.4	The breaking capacity of the isolation circuit-breaker closest to the point of utility connection shall be rated appropriately for the installation point in accordance with SANS 60947-2. This disconnection device does not need to be accessible to the utility.		P
4.2.5.5	For dedicated supplies, a means shall be provided of isolating from the point of supply in order to allow for safe maintenance of the utility network. The disconnection device shall be a double pole for a single-phase EG, a three-pole for a three-phase delta-connected EG, and a four-pole for a three-phase star-connected EG.		P
	This disconnection device shall be lockable and accessible to the utility.		Р
	NOTE 1 A device inside a lockable box is deemed a lockable device.		
	NOTE 2 This disconnection device may become the new point of control as defined by SANS10142-1.		
4.2.5.6	The requirement for the utility accessible disconnection device may only be waived by the utility where the risk to the network is deemed acceptable to the utility. Such permission shall be provided in writing.		Р
	NOTE Full verification form to be signed off and accepted by the utility.		
4.2.6	Earthing		Р
4.2.6.1	The electrical installation shall be earthed in accordance with SANS 10142-1 (as applicable). The earthing requirements for different embedded generation configurations in conjunction with the customer network are described in annex B for the most common earthing systems.	Rely in the responsibility of the installer.	N/A
	NOTE SANS 10142-1 applies to EG feeding a UPS and no connection to the utility supply (see table B5).		

Page 30 of 99 Report No.: 6108594.50

NRS 097-2-1:2017					
Clause	<u> </u>	Docult Domork	\/ordiot		
Clause	Requirement – Test	Result – Remark	Verdict		
4.2.6.2	Installations with utility-interconnected inverters without simple separation shall make use of earth leakage protection which are able to respond to d.c. fault currents including smooth d.c. fault currents (i.e. without zero crossings) according to IEC 62109-2 unless the inverter can exclude the occurrence of d.c. earth fault currents on any phase, neutral or earth connection through its circuit design ¹⁾ . This function may be internal or external to the inverter.	Rely in the responsibility of the installer.	N/A		
	NOTE IEC 62109-2, Edition 2011, section 4.8.3.5 gives selection criteria for RCD sensitivities.				
	1) The appropriate earth leakage unit should be selected to accommodate the higher leakage current of inverters without transformers to avoid nuisance tripping.				
4.2.6.3	Where an electrical installation includes a PV power supply system without at least simple separation between the AC side and the DC side, an integrated RCD function shall be present to provide fault protection by automatic disconnection of supply shall be type B according to IEC/TR 60755, amendment 2. Where the PV inverter by construction is not able to feed DC fault currents into the electrical installation, an RCD of type B according to IEC/TR 60755 amendment 2 is not required.	The inverter was tested and fulfils IEC 62109-1 and IEC 62109-2 for the residual current device (RCD) or residual current monitor (RCM). However if an external residual current device (RCD) is mandatory, the	Р		
	NOTE 1 Consideration must also be given to ensure that any d.c. currents do not impair the effectiveness of any other RCD'S installed throughout the a.c. system.	switch must be triggered at a failure current of 300 mA or higher was required			
	NOTE 2 The earth leakage unit may also fulfil the requirement of the all-pole disconnection device as stated in 4.2.6.	in the user manual.			
	NOTE 3 The function of this RCD is not to provide protection against circulating d.c. currents in the inverter and a.c. supply, i.e. does not override 4.1.8.				
4.2.7	Short-circuit protection		Р		
4.2.7.1	The embedded generator shall have suitably rated short-circuit protection at the connection to the AC mains in accordance with SANS 10142-1 and 3.		Р		
4.2.7.2	The short-circuit characteristics for the SSEG shall be supplied to the utility.	Not rotating generators.	N/A		
4.2.8	Maximum short-circuit contribution		Р		
	Embedded generators have the potential to increase the fault level of the network to which it is connected. In order to limit the fault level changes in low voltage networks and allow coordination of fault levels with the utility, no generator will exceed the following fault level contribution:		Р		
	a) for synchronous generators: 8 times the rated current;b) for asynchronous generators: 6 times the rated current; and		Р		
	c) for generators with inverters: 1 times the rated current.				

Page 31 of 99 Report No.: 6108594.50

r	Page 31 of 99	Report No.: 610	J8594.5U
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
	NOTE At the time of installation, the short-circuit capacity of all existing equipment should be confirmed and upgraded where necessary. Suitable fault current limiting devices may be required to ensure a safe installation. The potential impact on neighbouring installations should also be considered to ensure that those installations remain safe.		Р
4.2.9	Labelling		Р
4.2.9.1	A label on the distribution board of the premises where the embedded generator is connected shown in figure 7, shall state: "WARNING: ON-SITE EMBEDDED GENERATION. DO NOT WORK ON THIS EQUIPMENT UNTIL IT IS ISOLATED FROM BOTH MAINS AND ON-SITE GENERATION SUPPLIES." or similar warning. Disconnection points for all supplies shall be indicated.	Rely in the responsibility of the installer and is stated in the installation instruction of the manufacturer.	N/A
	WARNING: ON-SITE EMBEDDED GENERATION DO NOT WORK ON THIS QUIPMENT UNTIL IT IS ISOLATED FROM BOTH MAINS AND ON-SITE GENERATION ISOLATE ON-SITE GENERATOR AT ISOLATE MAINS SUPPLY AT Figure 7 — Example of labelling (more isolation points to be added as required)		
4.2.9.2	The label shall be permanent with lettering of height at least 8 mm.		N/A
4.2.9.3	The label shall comply to requirements of SABS 1186-1.		Р
4.2.9.4	The absence of emergency shutdown capabilities will be indicated on signage in accordance with 4.2.2.		Р
4.2.10	Robustness requirements		Р
	According to 4.2.2.1 all SSEG shall comply with safety requirements in accordance to SANS/IEC 62109-1 and IEC 62109-2. NOTE This section will be expanded in future revisions.	See TUV SUD IEC 62109- 1/-2 test report no.: 70.409.16.237.04-05 for reference.	Р
4.3	Metering	The meter was not part of the equipment under evaluation in this report.	N/A
4.3.1	General		N/A
4.3.1.1	All meters utilized by the utility shall be the property of the utility even when the meters are located on the premises of the customer. Meters that are embedded in the customer's network shall be accessible to the utility on request.		N/A

Page 32 of 99 Report No.: 6108594.50

	Page 32 of 99	Report No.: 6108	3334.30
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
4.3.1.2	Three metering configurations are known in the case of premises where embedded generators are operated, dependent on the tariff structure required or implemented by the supplier. The details are given in 4.3.2 and 4.3.3.		N/A
4.3.1.3	The utility will advise what metering is required based on the application and location of the embedded generator.		N/A
4.3.1.4	Metering will comply to SANS 474/NRS 057 and SANS 473/NRS 071.		N/A
4.3.1.5	Where applicable (manual reading), suitable signage will be attached at the meter, indicating that import and export registers need to be read. Refer to Figure 8 and 4.2.9.		N/A
	NOTE: ON-SITE EMBEDDED GENERATION (EG) CONNECTED. READ IMPORT AND EXPORT REGISTERS SEPARATELY		
	Figure 8 — Example of labelling for metering points (Colouring and other requirements to be confirmed with the utility).		
4.3.2	Single-quadrant meter installation		N/A
4.3.2.1	The single-meter arrangement is given in figure 9.		N/A
	DB distribution board EG embedded generation L customer network U utility network NOTE This type of installation requires an electronic meter where differentiated import and export rates apply. Figure 9 — Single meter installation		
4.3.2.2	The EG feeds into the customer network (L), offsetting the customer's own consumption. If the customer is a net electricity importer from the utility (U), the cumulative consumption meter reading will increase. If the customer is a net exporter, the cumulative consumption meter reading decreases.		N/A
4.3.2.3	As a result of using a single meter, the overall consumption and generation of the customer is not recorded. The net import and export of energy is metered and balanced over the metering period.		N/A

Page 33 of 99 Report No.: 6108594.50

	Page 33 of 99		.: 6108594.50			
NRS 097-2-1:2017						
Clause	Requirement – Test	Result – Remark	Verdict			
4.3.2.4	A net meter records and balances energy in a single register. An alternative to the net meter is a bi-directional meter which records energy import and export in separate registers. The registers need to be balanced off against each other to provide the necessary information to the billing system. Separate register meters may be preferred by utilities for reasons of revenue protection.		N/A			
4.3.3	Multiple meter installation		N/A			
	NOTE The feed-in tariff may be worded differently in policy documents, however, the principle is discussed in this section.		N/A			
4.3.3.1	Feed-in tariff metering records all the energy generated from the embedded generator and reimburses the EG customer at the set FIT. The consumption of the EG customer is recorded in full and billed in the conventional manner. A customer with embedded generation and consumption therefore requires two meters or a bidirectional active energy meter that records energy flow in both directions.		N/A			
4.3.3.2	The metering configuration for FIT metering is given in figure 8 and is referred to as "separate metering". An existing consumption meter, whether prepayment or conventional, can remain in place. The embedded generation meter shall be a bi-directional active energy meter that records energy flow in both directions.		N/A			
4.3.3.3	This metering configuration records overall consumption (L) and overall generation (EG) which is exported to the utility network (U).		N/A			
4.3.3.4	The separate metering configuration in figure 10 is the most basic FIT metering configuration.		N/A			
	NOTE The relevant regulations applicable in municipalities may not allow this metering configuration in which case the EG can be connected through the separate embedded generation metering configuration shown in figure 10.					
	Embedded generation water two motor two transumption water two transumption with the consumption of the consumption water two transumptions are the consumption of the consumption with the consumption of					
	Ü					
	Legend DB distribution board EG overall generation L overall consumption U utility network					
	NOTE The EG may have auxiliary supply (electricity usage)					

Page 34 of 99 Report No.: 6108594.50

Page 34 of 99 Report No.: 6108594.50					
	NRS 097-2-1:2017		Г		
Clause	Requirement – Test	Result – Remark	Verdict		
4.3.3.5	In the case where the output of the EG cannot physically be taken to the main distribution board of the customer's premises, an EG meter may be embedded in the customer's network. The appropriate metering configuration is given in figure 11. Legend DB distribution board EG embedded generation L consumption U utility network		N/A		
	Figure 11 — Separate embedded metering				
4.3.3.6	The overall generation of the EG is recorded in the bi-directional embedded generation meter while the overall consumption is balanced off between the net meter and the EG meter ²). The net meter shall be a bi-directional meter. 2) The overall electricity consumption over a period is equivalent to the sum of the net meter differential		N/A		
4.3.4	reading and the EG meter differential reading. Types of meter		N/A		
4.3.4.1	Energy meters used in conjunction with embedded generation shall record active energy. The meters shall be bi-directional type meters. The meters can either be of the single or the separate register type.		N/A		
4.3.4.2	The current specification for pre-payment meters does not cater for embedded generation.		N/A		
4.3.4.3	In the event that installations with embedded generators are required to record reactive energy in conjunction with active energy, four-quadrant electronic meters shall be utilized.		N/A		
4.3.4.4	Meters with the capability of metering quality of supply parameters shall activate the monitoring facility on the meter. NOTE The modalities of the billing and revenue procedures for EG customers will be addressed in the future NRS 097-2-4 specification.		N/A		
Annex A	Notes to purchasers		N/A		
	NOTE The customer is advised to contact the utility to discuss potential further connection requirements.		N/A		

Page 35 of 99 Report No.: 6108594.50

	Page 35 of 99	Report No.: 61	00334.30
	NRS 097-2-1:2017		ı
Clause	Requirement – Test	Result – Remark	Verdict
A.1	The following requirement shall be specified in tender invitations and in each order or contract:		N/A
	Whether all power quality parameters shall be measured at the POC (see 4.1.1.3).		N/A
A.2	The following requirements shall be agreed upon between the customer and the utility:		N/A
	a) whether the EG shall be type approved (see 4.1.1.5);		N/A
	b) whether the EG may control the voltage (see 4.1.2.2);		N/A
	c) the power factor limits (see 4.1.11).		N/A
Annex B	Earthing systems		Р
	NOTE SANS 10142-1 does not apply to embedded generators (i.e. connected in parallel to the utility network). Annex B is provided as minimum requirements for earthing systems until the update of SANS 10142-1.		Р
B.1	Application of SANS 10142-1	See below.	Р
B.1.1	General		Р
	SANS 10142-1 applies to low-voltage wiring, earthing, bonding and safety. The requirements in B.1.2 to B.1.5 relating to earthing and to neutral and earth path connections apply.		Р
B.1.2	Neutral conductor		Р
	The neutral conductor shall not be connected direct to earth or to the earth continuity conductor on the load side of the point of control (see 6.1.6 in SANS 10142-1:2012).		Р
B.1.3	Customer's earth terminal		N/A
	Each installation shall have a consumer's earth terminal (see 3.18 of SANS 10142-1:2012) at or near the point where the supply cables enter the building or structure. All conductive parts that are to be earthed (see 6.12.3 in SANS 10142-1:2012) shall be connected to the main earthing terminal (see 3.29.4 in SANS 10142-1:2012), which shall be connected to the consumer's earth terminal. The consumer's earth terminal shall be earthed by connecting it to the supply earth terminal (see 3.78 in SANS 10142-1:2012) or the protective conductor (see 3.15.8 in SANS 10142-1:2012) and, if installed, the earth electrode. The effectiveness of the supply protective conductor shall be determined in accordance with 8.7.5 in SANS 10142-1:2012 (see 6.11.1 as amended by amendment No. 6 in SANS 10142-1:2012).	Rely in the responsibility of the installer.	N/A
B.1.4	Earthing of combined sources		N/A

Page 36 of 99 Report No.: 6108594.50

Page 36 of 99 Report No.: 6108594.50					
	NRS 097-2-1:2017	T	1		
Clause	Requirement – Test	Result – Remark	Verdict		
	When an installation that has a common neutral is supplied from a combination of transformers and generators located near one another, the neutral terminal of these shall be connected to a single neutral bar. This neutral bar shall be the only point at which the neutral of the installation is earthed except in the case in 7.12.3.1.3 in SANS 10142-1:2012 (see 6.12.4 as amended by amendment No. 6 in SANS 10142-1:2012).	Rely in the responsibility of the installer.	N/A		
B.1.5	Neutral bar earthing	Rely in the responsibility of the installer.	N/A		
B.1.5.1	Protection in accordance with the requirements in 6.7 in SANS 10142-1:2012 shall be provided for the electrical installation in such a manner as to ensure correct operation of the protection devices, irrespective of the supply or combination of sources of supply. Operation of the protection devices shall not rely upon the connection to the earthing point of the main supply.		N/A		
B.1.5.2	Where there is no existing earth electrode in the electrical installation, a suitable earth electrode may be installed in accordance with SANS 10199. When installed, the electrode shall be bonded to the consumer's earth terminal and to the earthing point of the generating set with a conductor of at least half the cross-section of that of the phase conductor, but not less than 6 mm copper, or equivalent. This also applies to a single-phase supply.		N/A		
	NOTE 1 In the case of the TN system of electricity supply, an earth electrode is normally not required in an electrical installation (see 7.12.3.1.1 as amended by amendment No. 6 in SANS 10142-1:2012).				
	NOTE 2 IEC 60364-1 distinguishes three families of earthing arrangement, using the two-letter codes TN, TT, and IT. The first letter indicates the connection between earth and the power-supply equipment (generator or transformer). The second letter indicates the connection between earth and the electrical device being supplied. In the case of TN systems, T indicates a direct connection of a point with earth (Latin: terra) and N indicates direct connection to neutral at the origin of the installation, which is connected to the earth.				
B.1.5.3	When an installation is supplied from a combination of transformers and generators located near one another, including alternative supplies, the neutral terminal of these shall be connected to a single earthed neutral bar. This neutral bar shall be the only point at which the neutral of the installation is earthed. Any earth leakage unit shall be positioned to avoid incorrect operation due to the existence of the parallel neutral or earth path (see 7.12.3.1.2 as amended by amendment No. 6 in SANS 10142-1:2012).		N/A		

Page 37 of 99 Report No.: 6108594.50

					19e 37 C	-1:2017		Kepon No., orc	7000 1.00
Clause	Require	ement – Tes	t					Result – Remark	Verdict
B.1.5.4	Where alternative supplies are installed remotely from the installation and it is not possible to make use of a single neutral bar, which is earthed, the neutral of each unit shall be earthed at the unit and these points shall be bonded to the consumer's earth terminal (see 6.12.4 of SANS 10142-1:2012). The supply that supplies the installation or part of the installation shall be switched by means of a switch that breaks all live conductors operating substantially together (see annex S of SANS 10142-1:2012), to disconnect the earthed neutral point from the installation neutral when the alternative supply is not connected (see also 6.1.6 of SANS 10142-1:2012 and 7.12.3.1.3 (as amended by amendment No. 6 in SANS 10142-1:2012)).							N/A	
B.1.5.5	Where only part of an installation is switched to the alternative supply in the same distribution board, the neutral bar shall be split (see figure S.2 in annex S of SANS 10142-1:2012) and 7.12.3.1.3 (as amended by amendment No. 6 in SANS 10142-1: 2012).					N/A			
B.2	Embedo	ded generat	or and UPS	S config	guration	S			Р
	main ele TN-C-S NOTE T Africa, b electrific	s were exame ectrical supplements. Table B.1 he TT configure to could some ation network.	oly earthing shows the uration is ge etimes be fo c spurs.	config permu nerally round in d	urations tations not used certain ru	s (i.e. T explore in South ural	N-S, d. n	system.	
	9	- Generic embedde	-				guration		
	1	2	Alternative supply characteristic		5 ectricity supply iguration exam				
	Figure reference	Application type	Internal N-PE bridge connection	TN-S	TN-C-S	тт			
	Table B.2	Alternative generator, e.g. stand-by diesel or stand-alone	Unbridged N-PE N-PE bridged	Y	Y	Y			
	Table B.3	generator Embedded generator, e.g. utility interconnected PV system	, s z singes	Υ	Y	Y			
	Table B.4	UPS system with a.c. coupled embedded generator	Unbridged N-PE N-PE bridged	Y	Y	Y			
	9	UPS system	Unbridged N-PE	Y	Y	Y			
		UPS system with	N-PE bridged Unbridged N-PE	Y	Y	Y	-		
	Table B.5	d.c. coupled embedded generator (e.g. PV or wind)	N-PE bridged	Y	Y	Y			

		Page 3	88 of 99	Report No.: 61	08594.50
		NRS 097	7-2-1:2017		
Clause	Requirement	t – Test		Result – Remark	Verdict
	configuration	Diesel generator in alternativ	The unit under test was single phase Grid-Connected PV Inverter and not diesel generator.		
	1 Supply earthing system	2 Wiring diagram	3 Earthing comments	and not diesel generator.	
	TN-S Five-wire supply. Consumer's earth electrode not required. No N-PE bridge on consumer's earth terminal	Total day (P) - Service Service	Requirements Alternative supply earth electrode required Bridge N-PE required on alternative supply. Four-pole change-over switch required.		
	TN-C-S • Four-wire supply. • Consumer's earth electrode not required. • Bridge N-PE required on consumer's earth terminal	Service Granting Protect Installing	Requirements Alternative supply earth electrode required Options If bridged N-PE on alternative supply, then four-pole change-over switch required. If open N-PE on alternative supply, then three-pole change-over switch required.		
	TT Four-wire supply. Consumer's earth electrode required. No N-PE bridge on consumer's earth terminal	Songresiano. PE ostato Invasive Liday.	Requirements Bridge N-PE required on alternative supply. Four-pole change- over switch required.		

		Page 3	39 of 99	Report No.	.: 6108594.50
		NRS 09	7-2-1:2017		
lause	Requiremen	t – Test		Result – Remark	Verdict
	supply	Embedded generator without			N/A
	1 Supply earthing	2 Wiring diagram	3 Earthing comments		
	system TN-S Five-wire supply. Consumer's earth electrode not required. No N-PE bridge on consumer's earth terminal Main supply = Point of Control Main DB	State Name Port of Control State Name Port of Control State Name State Na	Requirements RCD (Type B) required for transformerless inverters. Options EG aarth electrode desired		
	TN-C-S • Four-wire supply. • Consumer's earth electrode not required. • Bridge N-PE required on consumer's earth terminal	Total State of State	Requirements • EG on E/L device Options • EG earth electrode desired		
	TT Four-wire supply. Consumer's earth electhode required. No N-PE bridge on consumer's earth terminal	Sea to Control of Cont	Requirements • EG on E/L device		

		Page 4	0 of 99	Report No	.: 6108594.50
		NRS 097	7-2-1:2017		
Clause	Requirement	– Test		Result – Remark	Verdict
	embedded ge	Alternative supply with a.c. onerator — Alternative supply with a.c. coupled embedded			N/A
	1	2	3		
	Supply earthing system TN-S • Five-wire supply. • Consumer's earth electrode not required. • No N-PE bridge on consumer's earth terminal	Wiring diagram	Earthing comments Requirements EG on E/L device Alternative supply earth electrode required Bridge N-PE required on alternative supply. Change-over switch 1 required to be four-pole Change-over switch 2 required to be four-pole.		
	TN-C-S Four-wire supply Consumer's earth electrode not required. Bridge N-PE required on consumer's earth terminal	TOTAL CONTROL OF THE PARTY OF T	Requirements • EG on E/L device • Alternative supply earth electrode required Options • If bridged N-PE on alternative supply, then change-over switch 1 required to be four-pole. • If open N-PE on alternative supply, then change-over switch 1 required to be three-pole. • Change-over switch 2 required to be four-pole		
	TT Four-wire supply. Consumer's earth electrode required. No N-PE bridge on consumer's earth terminal	Control of the contro	Requirements • EG on E/L device • Bridge N-PE required on alternative supply. • Change-over switch 1 required to be four-pole • Change-over switch 2 required to be four-pole.		

	Page 41 of 99	Report No.: 61	08594.50
-	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
	Table B.5 — Alternative supply with or without d.c. coupled embedded generator Table B.5 — Alternative supply with or without d.c. coupled embedded generator		N/A
	1 2 3 Supply earthing Wiring diagram Earthing comments		
	system TN-S • Five-wire supply. • Consumer's earth electrode not required. • No N-PE bridge on consumer's earth terminal • Five-wire supply. • Consumer's earth terminal • If bridged N-PE on alternative supply, then four-poen N-PE on alternative supply. • If bridged N-PE on alternative supply, then four-poen N-PE on		
	TN-C-S Four-wire supply. Consumer's earth electrode on required. Bridge N-PE required on consumer's earth terminal Four-wire supply in the four-pole change-over switch required. If bridged N-PE on alternative supply, then three-pole change-over switch required.		
	Four-wire supply. Consumer's earth electrode required. No N-PE bridge on consumer's earth terminal		
D 0	Key: CB circult-breaker DB distribution board GFDI ground fault detector interrupter GEN alternative generator EG embedded generator UPS battery alternative supply		
B.3	Rules of thumb established for embedded generation and backup systems		P
B.3.1	General		Р
	Earthing and wiring guidelines were developed as a result of the above rigorous analysis. See tables B.2 to B.5.		Р
B.3.2	Earth electrode		N/A
B.3.2.1	All alternative systems shall have an own earth electrode connected to the consumer's earth terminal and shall comply with 7.12.3.1.1 in SANS 10142-1:2012.		N/A
B.3.2.2	Embedded generators need not have their own earth electrode in accordance with SANS 10142-1, but an own earth electrode is preferred.		N/A
B.3.3	N-PE bridge on consumer's earth terminal	Rely in the responsibility of the installer.	N/A
B.3.3.1	The TN-C-S system shall be bridged between N and PE on the consumer's earth terminal in the installation on the supply side of the point of control.		N/A
B.3.3.2	TN-S and TT systems shall be un-bridged (as normal practice). NOTE This is to comply with standard installation requirements for safety.		N/A

Page 42 of 99 Report No.: 6108594.50

	Page 42 of 99	Report No.: 61	U8594.5U
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict
B.3.4	N-PE bridge on alternative supply	Rely in the responsibility of the installer.	N/A
B.3.4.1	TN-S and TT systems shall be bridged.		N/A
B.3.4.2	The TN-C-S may be either bridged or un-bridged. This, however, impacts on change-over switch requirements.		N/A
B.3.5	Change-over switch No. 1 (between main supply and backup supply)	Rely in the responsibility of the installer.	N/A
B.3.5.1	In the case of backup systems WITHOUT an internal N-PE bridge (i.e. where N and PE are isolated), the following is required:		N/A
	a) for a three-phase system: a three-pole change-over switch with common neutral bar; and		N/A
	b) for a single-phase system: a single-pole change-over switch with common neutral bar.		
B.3.5.2	In the case of backup systems WITH an internal N-PE bridge, the following is required:		N/A
	a) for a three-phase system: a four-pole change-over switch including neutral, or a three-pole with overlapping neutral; and		N/A
	b) for a single-phase system: a two-pole change-over switch including neutral, or a single pole with overlapping neutral.		
B.3.5.3	Manual change-over switches shall be three position switches, i.e. break-before-make.		N/A
B.3.6	Change-over switch No. 2 (between a.c. coupled embedded generator and backup supply)	Rely in the responsibility of the installer.	N/A
B.3.6.1	In the case of a three-phase system, there shall be a four-pole change-over switch including neutral, or a three-pole with overlapping neutral.		N/A
B.3.6.2	In the case of a single-phase system, there shall be a two-pole change-over switch including neutral, or a single pole with overlapping neutral.		N/A
Annex C	Network impedance		Info.
Annex D	(Annex A of VDE-AR-N 4105) Explanations		Info.
Annex E	(Annex B of VDE-AR-N 4105) Connection examples		Info.
Annex F	(Annex C of VDE-AR-N 4105) Example of meter panel configurations		Info.
Annex G	Generation management network security management		Р
G.1	Generation management network security management		Р

Page 43 of 99 Report No.: 6108594.50

	Page 43 of 99	Report No.: 61085	94.50
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	erdict
	NOTE While no South African utility currently has the required communication systems in place for LV systems, embedded generators may be NERSA exempt in providing on-line communication interfaces. However, should the utility require this in future, the embedded generator will provide the required interface at their own cost. Section G.1 provides the recommended requirements for such an interface. At the time of publication, basic communication requirements for category A3 generators are provided in the RPP Grid Code.		P
G.1.1	In addition to requirements elsewhere in this specification, the embedded generator shall be able to control the following parameters as and where signals are sent by the utility:		Р
G.1.1.1	Active power control, typically a temporary reduction in active power output;		Р
G.1.1.2	Reactive power control, i.e. change of the operating power factor or power factor curve of the generator.		Р
G.1.2	For each operational state and/or operational point, the embedded generator must be able to reduce the output power to less than or equal to an active power set-point provided by the utility.		Р
G.1.3	Embedded generation systems with a power output capability of 100 kVA or more shall be able to control the output power in steps of 10 % or less of the rated active power.		Р
G.1.4	The embedded generator active power output shall reach the new set-point within a period of 1 minute. If this set-point cannot be reached within 5 minutes, the embedded generator shall disconnect from the system. NOTE This implies that embedded generators without the capability to control the output power adequately or in adequate steps, shall disconnect from the system when a reduction in active power output is requested.		P
G.1.5	Embedded generation systems with a power output capability of 100 kVA or more shall be able to control the reactive power (power factor) is steps of 5 % or less of the rated power.		Р
G.1.6	Reactive power shall reach the new set-point within a period of 1 minute. If this set-point cannot be reached within 5 minutes, the embedded generator shall disconnect from the system.		Р

Page 44 of 99 Report No.: 6108594.50

	NRS 097-2-1:2017	report ito:	. 6106594.50
Clause		Dogult Domonic	\/ordiot
Clause	Requirement – Test	Result – Remark	Verdict
G.1.7	According to the RPP Grid Code version 3.0, the accuracy of the control performed for both the active power and reactive power controls, and of the setpoint of both the active power and reactive power, shall not deviate by more than ± 2 % of the setpoint value or by ± 0.5 % of the rated power, depending on which yields the highest tolerance.		P
	NOTE Appropriate communication protocols are under discussion with the Grid Code Advisory Committee and will be provided in a future edition of this document. This capability will then become compulsory for all new equipment.		
G.2	Principles for network support		Р
	As a rule, power generation systems of subcategory A3 shall be able to contribute to the static voltage stability in the utility network. Static voltage stability is the voltage stability in the low-voltage network at which the slow voltage changes are maintained within compatible limits in the distribution network. If required due to network related circumstances and by the utility, the embedded generator shall contribute to the static voltage stability in the low-voltage network.		P
	Dynamic grid support, i.e. voltage stability in the event of voltage drops in higher voltage levels, is not required for embedded generators connected to low-voltage networks. NOTE This requirement applies tor units larger than 100 kVA only, smaller units on dedicated circuits (i.e. part of		P
	sub-category A3) are exempt.		
G.3	Emergency personnel safety		Р
	The safety of emergency personnel, e.g. fire brigade, shall be dealt with elsewhere.		Р
	DC installations will be covered by SANS 10142-X (future document).		Р
	A utility accessible disconnector will be available to emergency personnel that will disconnect the a.c.		Р
	NOTE This clause will be superseded by requirements in the future SANS 10142-X document or other relevant requirements based on the Occupational Health and Safety act (Act No. 85 of 1993) as amended.		
G.3.1	Appropriate signage shall be installed. The requirements shall be cross-checked with requirements of SANS 10142-1. An example of signage as required by this section of NRS 097 is provided in 4.2.10.		Р
G.3.2	It is preferable that all SSEG be installed with emergency shutdown equipment. Examples of requirements are listed in G.3.2.1 to G.3.2.4. The manufacturer shall prove that the emergency shutdown processes and procedures are in line with current international best practices.		Р

Page 45 of 99 Report No.: 6108594.50

Fage 45 01 99	Report No., 61	00334.30
NRS 097-2-1:2017		
Requirement – Test	Result – Remark	Verdict
All a.c. voltages should be shut off, regardless of the operating mode of the equipment at the time of shutdown.		Р
All fuel inputs to a SSEG (e.g. water feed to a hydrogenerator, d.c. input to an inverter, etc.) should be shut off; regardless of the operating mode of the equipment at the time of shutdown.		Р
NOTE PV panels cannot be switched off.		
Equipment that have emergency shutdown capabilities, shall have a "fireman's switch" installed in accordance with SANS 10142-1 at the time of installation in order to activate emergency shutdown.		Р
NOTE The d.c. from PV panels and/or battery storage will be assumed to be live.		
The absence of emergency shutdown capabilities will be indicated on signage referred to in G.3.1.		Р
	NRS 097-2-1:2017 Requirement – Test All a.c. voltages should be shut off, regardless of the operating mode of the equipment at the time of shutdown. All fuel inputs to a SSEG (e.g. water feed to a hydrogenerator, d.c. input to an inverter, etc.) should be shut off; regardless of the operating mode of the equipment at the time of shutdown. NOTE PV panels cannot be switched off. Equipment that have emergency shutdown capabilities, shall have a "fireman's switch" installed in accordance with SANS 10142-1 at the time of installation in order to activate emergency shutdown. NOTE The d.c. from PV panels and/or battery storage will be assumed to be live. The absence of emergency shutdown capabilities will be	NRS 097-2-1:2017 Requirement – Test All a.c. voltages should be shut off, regardless of the operating mode of the equipment at the time of shutdown. All fuel inputs to a SSEG (e.g. water feed to a hydrogenerator, d.c. input to an inverter, etc.) should be shut off; regardless of the operating mode of the equipment at the time of shutdown. NOTE PV panels cannot be switched off. Equipment that have emergency shutdown capabilities, shall have a "fireman's switch" installed in accordance with SANS 10142-1 at the time of installation in order to activate emergency shutdown. NOTE The d.c. from PV panels and/or battery storage will be assumed to be live. The absence of emergency shutdown capabilities will be

Page 46 of 99 Report No.: 6108594.50

	1 age +0 01 00	Ropolt No.: 01	00004.00
NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict

Test overview:				
	NRS 097-2-1:2017			
Clause	Test item	Result		
4.1.5	Flicker and voltage changes	Р		
4.1.6	Voltage unbalance	Р		
4.1.8.1	DC injection	Р		
4.1.8.2 & 4.2.2.5	DC current injection	Р		
4.1.10	Harmonics and waveform distortion	Р		
4.1.11	Power factor	Р		
4.2.2.2	Disconnection device (previously disconnection switching unit)	Р		
4.2.2.3.2	Overvoltage and undervoltage	Р		
4.2.2.3.3	Overfrequency and underfrequency	Р		
4.2.2.4	Prevention of islanding (in accordance with IEC 62116)	Р		
4.2.4	Response to utility recovery (see table 4.2.2.3.2 & 4.2.2.3.3)	Р		

Page 47 of 99 Report No.: 6108594.50

NRS 097-2-1:2017				
Clause	Requirement – Test		Result – Remark	Verdict

4.1.5 TABLE: Flicker and voltage changes					
Test conditions:		Maximum permissible voltage fluctuation (expressed as a percentage of nominal voltage at 100 % power) and flicker			ge
Model: So	olis-1P4.6K-4G				
Limit		dc = 3,3 (%)	P _{st} =0,35	P _{it} =0,30	
Test value		0,08	0,12	0,08	

Note:


Calculation of the maximum permissible grid impedance at the point of common coupling based on dc:

Zmax = Zref * 3,3% / dc(Pn)

The tests should be based on the limits of the EN 61000-3-11 for more than 16A.

The tests were performed on model Solis-1P4.6K-4G and are also applicable for all other models stated in this report.





Page 48 of 99 Report No.: 6108594.50

		1 490 10 01 00	Troport Troil on	0000 1100
NRS 097-2-1:2017				
Clause	Requirement – Test		Result – Remark	Verdict

4.1.6.2 TABLE: Voltage unbalance for three-phase generators							N/A
Measurem	nent No.	1	2	3	4	5	
Test at rat	ed power @ cos φ	= 1					
U _{E60} [V]: L	1						
U _{E60} [V]: L	2						
U _{E60} [V]: L	3						
U _{E60} [V]: L	_1 - L2						
U _{E60} [V]: L	_2 - L3						
U _{E60} [V]: L	_3 - L1						
cos φ _{E60} m	nax.:						
max volta	ge unbalance						
Limit, 0,2%	%U _{Rated} [V]:						

Note:

Three-phase generators may not contribute more than 0,2 % voltage unbalance when connected to a network with impedance equal to the reference impedance.


The PV inverters were single phase not used in three-phase system.

Page 49 of 99 Report No.: 6108594.50

		1 490 10 01 00	Troport Troil on	0000 1100
NRS 097-2-1:2017				
Clause	Requirement – Test		Result – Remark	Verdict

4.1.8.1 TABLE: DC injection	TABLE: DC injection				
Model: Solis-1P4.6K-4G					
Limit:	0,5% of I _{rated} (0,1 A)				
Output power level (%)	25%	50%	100%		
Max test value (A)	0,035	0,052	0,082		
Percent of rated AC current (%)	0,18% 0,26% 0,4				

Diagram of permanent DC-Injection (25% / 50% / 100%Pn)




Note:

The average d.c. current injected by the embedded generator shall not exceed 0,5 % of the rated a.c. output current over any 1-minute period, into the utility a.c. interface under any operating condition.

	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict

4.1.8.1	TABLE: DC injection				
Model: Solis-1P1K-4G					
Limit:		0,5% of I _{rated} (0,022 A)			
Output power level (%)		25%	50%	100%	
Max test value (A)		0,014 -0,015		-0,021	
Percent of	rated AC current (%)	0,32%	0,35%	0,49%	

Diagram of permanent DC-Injection (25% / 50% / 100%Pn)



Note:

The average d.c. current injected by the embedded generator shall not exceed 0,5 % of the rated a.c. output current over any 1-minute period, into the utility a.c. interface under any operating condition.

The tests were performed on model Solis-1P4.6K-4G and Solis-1P1K-4G are also applicable for all other models stated in this report.

Page 51 of 99 Report No.: 6108594.50

		95 5 . 5 . 5 .	. topon ton on	000000
NRS 097-2-1:2017				
Clause	Requirement – Test		Result – Remark	Verdict

4.1.8.2& 4.2.2.5 TABLE: DC current injection					Р
Model: Solis-1P4.6K-40	Model: Solis-1P4.6K-4G				
DC Injection (A)	Limits	Trip Time (ms)			
Tested with +0,1 A	I _{DC} :>0,5% I _{rated} , EG disconnection within 500 ms	146	138	1	29
Tested with -0,1 A	I _{DC} :>0,5% I _{rated} , EG disconnection within 500 ms	135	116	1	28

Note:

The EG shall cease to energize the utility network within 500 ms if inject d.c. current greater than 0.5% of the rated a.c. output current into the utility interface.

The tests were performed on model Solis-1P4.6K-4G and are also applicable for all other models stated in this report.

1 age 62 61 66		noport No c	100004.00
NRS 097-2-1:2017		2017	
Clause	Requirement – Test	Result – Remark	Verdict

4.1.10	TABLE: Harmonics and wa	aveform distor	tion		Р			
Harmonio	cs							
Model: S	olis-1P4.6K-4G							
	Active power (kW) 4,604							
	Voltage (V)			230,23				
	Current (A)			19,99				
	Frequency (Hz)			50,00				
	THD (%)		1,62					
Harmonio	Current Magnitude (A)	% of Fundam	nental	Phase	Harmonic Current Limits (%)			
1st	19,999			Single Phase				
2nd	0,081	0,406		Single Phase	1%			
3rd	0,121	0,607		Single Phase	4%			
4th	0,02	0,098		Single Phase	1%			
5th	0,177	0,883		Single Phase	4%			
6th	0,012	0,060		Single Phase	1%			
7th 0,134		0,669		Single Phase	4%			
8th	0,008	0,039		Single Phase	1%			
9th	0,099	0,496		Single Phase	4%			
10th	0,006	0,032		Single Phase	1%			
11th 0,082		0,409		Single Phase	2%			
12th 0,006		0,029		Single Phase	0,5%			
13th	0,064	0,319		Single Phase	2%			
14th 0,004		0,021	0,021		0,5%			
15th 0,055 0,275			Single Phase	2%				
16th	0,004	0,019		Single Phase	0,5%			
17th	0,046	0,232		Single Phase	1,5%			
18th	0,002	0,012		Single Phase	0,38%			
19th	0,044	0,218		Single Phase	1,5%			
20th	0,002	0,011		Single Phase	0,38%			
21th 0,037 0,185		0,185		Single Phase	1,5%			
22th 0,003 0,013			Single Phase	0,38%				
23th	0,032	0,162		Single Phase	0,6%			
24th	0,003	0,016		Single Phase	0,15%			
25th	0,026	0,131		Single Phase	0,6%			
26th	0,002	0,010		Single Phase	0,15%			
27th	0,023	0,114		Single Phase	0,6%			

Page 53 of 99 Report No.: 6108594.50

		Page 53 of 99	Report	: No.: 6108594.50
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict
28th	0,002	0,008	Single Phase	0,15%
29th	0,021	0,105	Single Phase	0,6%
30th	0,001	0,007	Single Phase	0,15%
31th	0,020	0,098	Single Phase	0,6%
32th	0,002	0,009	Single Phase	0,15%
33th	0,017	0,084	Single Phase	0,6%
34th	0,003	0,013	Single Phase	0,15%
35th	0,015	0,077	Single Phase	0,3%
36th	0,003	0,016	Single Phase	0,08%
37th	0,014	0,069	Single Phase	0,3%
38th	0,002	0,011	Single Phase	0,08%
39th	0,012	0,062	Single Phase	0,3%
40th	0,002	0,010	Single Phase	0,08%
41th	0,011	0,053	Single Phase	0,3%
42th	0,002	0,011	Single Phase	0,08%
43th	0,010	0,050	Single Phase	0,3%
44th	0,003	0,017	Single Phase	0,08%
45th	0,009	0,047	Single Phase	0,3%
46th	0,002	0,012	Single Phase	0,08%
47th	0,008	0,042	Single Phase	0,3%
48th	0,003	0,013	Single Phase	0,08%
49th	0,008	0,038	Single Phase	0,3%
50th	0,002	0,012	Single Phase	0,08%

		i age 34 oi 33	Report No., on	00.75.00
Clause	Requirement – Test		Result – Remark	Verdict

4.1.10	TABLE: Harmonics and wa	aveform distortion		Р	
Inter-harm	onics				
Model: So	lis-1P4.6K-4G				
Frequency [Hz]	Current Magnitude (A)	% of Fundamental	Phase	Harmonic Current Limits (%)	
75	0,013	0,064	Single Phase	0,1%	
125	0,02	0,098	Single Phase	0,1%	
175	0,019	0,095	Single Phase	0,1%	
225	0,008	0,041	Single Phase	0,1%	
275	0,004	0,021	Single Phase	0,1%	
325	0,004	0,020	Single Phase	0,1%	
375	0,003	0,015	Single Phase	0,1%	
425	0,003	0,015	Single Phase	0,1%	
475	0,003	0,014	Single Phase	0,1%	
525	0,006	0,028	Single Phase	0,1%	
575	0,005	0,023	Single Phase	0,25%	
625	0,004	0,021	Single Phase	0,25%	
675	0,002	0,012	Single Phase	0,25%	
725	0,003	0,016	Single Phase	0,25%	
775	0,003	0,014	Single Phase	0,25%	
825	0,003	0,013	Single Phase	0,25%	
875	0,002	0,010	Single Phase	0,19%	
925	0,003	0,013	Single Phase	0,19%	
975	0,002	0,011	Single Phase	0,19%	
1025	0,002	0,011	Single Phase	0,19%	
1075	0,002	0,009	Single Phase	0,19%	
1125	0,002	0,008	Single Phase	0,19%	
1175	0,002	0,008	Single Phase	0,08%	
1225	0,003			0,08%	
1275	0,002	0,011	Single Phase	0,08%	
1325	0,002	0,008	Single Phase	0,08%	
1375	0,001	0,006	Single Phase	0,08%	
1425	0,001	0,007	Single Phase	0,08%	
1475	0,001	0,007	Single Phase	0,08%	
1525	0,004	0,022	Single Phase	0,08%	
1575	0,002	0,008	Single Phase	0,08%	
1625	0,004	0,019	Single Phase	0,08%	

Page 55 of 99 Report No.: 6108594.50

		1 ago 00 01 00		01111011 010000 1100	
Clause	Requirement – Test		Result – Remark	Verdict	
1675	0,005	0,025	Single Phase	0,08%	
1725	0,003	0,017	Single Phase	0,08%	
1775	0,001	0,007	Single Phase	0,03%	
1825	0,001	0,005	Single Phase	0,03%	
1875	0,001	0,006	Single Phase	0,03%	
1925	0,001	0,006	Single Phase	0,03%	
1975	0,002	0,008	Single Phase	0,03%	

	1 age 66 61 88	Report No.: 01	00007.00
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict

4.1.10	TABLE: Harmonics and wa	aveform distortio	n	Р				
Harmoni	CS .							
Model: S	olis-1P1K-4G							
Active power (kW) 1,076								
	Voltage (V)		230,41					
	Current (A)		4,687					
	Frequency (Hz)		50,00					
	THD (%)		2,64					
Harmonio	<u> </u>	% of Fundame	ntal Phase	Harmonic Current Limits (%)				
1st	4,685		Single Phase					
2nd	0,025	0,542	Single Phase	1%				
3rd	0,076	1,613	Single Phase	4%				
4th	0,024	0,509	Single Phase	1%				
5th	0,062	1,324	Single Phase	4%				
6th	0,007	0,155	Single Phase	1%				
7th	0,049	1,039	Single Phase	4%				
8th	0,006	0,129	Single Phase	1%				
9th	0,027	0,579	Single Phase	4%				
10th	0,004	0,081	Single Phase	1%				
11th	0,019	0,412	Single Phase	2%				
12th	0,004	0,078	Single Phase	0,5%				
13th	0,010	0,222	Single Phase	2%				
14th	0,004	0,075	Single Phase	0,5%				
15th	0,007	0,155	Single Phase	2%				
16th	0,003	0,073	Single Phase	0,5%				
17th	0,003	0,074	Single Phase	1,5%				
18th	0,003	0,059	Single Phase	0,38%				
19th	0,003	0,056	Single Phase	1,5%				
20th	0,002	0,048	Single Phase	0,38%				
21th	0,002	0,037	Single Phase	1,5%				
22th	0,003	0,058	Single Phase	0,38%				
23th	0,002	0,043	Single Phase	0,6%				
24th	0,001	0,029	Single Phase	0,15%				
25th	0,001	0,027	Single Phase	0,6%				
26th	0,001	0,021	Single Phase	0,15%				
27th	0,001	0,020	Single Phase	0,6%				

Page 57 of 99 Report No.: 6108594.50

		Page 57 of 99	Report	i No.: 6108594.50	
		NRS 097-2-1:2017			
Clause	Requirement – Test		Result – Remark	Verdict	
28th	0,003	0,054	Single Phase	0,15%	
29th	0,001	0,028	Single Phase	0,6%	
30th	0,003	0,054	Single Phase	0,15%	
31th	0,003	0,066	Single Phase	0,6%	
32th	0,002	0,037	Single Phase	0,15%	
33th	0,005	0,110	Single Phase	0,6%	
34th	0,002	0,046	Single Phase	0,15%	
35th	0,006	0,133	Single Phase	0,3%	
36th	0,001	0,025	Single Phase	0,08%	
37th	0,005	0,113	Single Phase	0,3%	
38th	0,002	0,046	Single Phase	0,08%	
39th	0,005	0,107	Single Phase	0,3%	
40th	0,002	0,053	Single Phase	0,08%	
41th	0,005	0,111	Single Phase	0,3%	
42th	0,002	0,040	Single Phase	0,08%	
43th	0,005	0,108	Single Phase	0,3%	
44th	0,001	0,021	Single Phase	0,08%	
45th	0,005	0,117	Single Phase	0,3%	
46th	0,001	0,018	Single Phase	0,08%	
47th	0,005	0,115	Single Phase	0,3%	
48th	0,001	0,026	Single Phase	0,08%	
49th	0,006	0,119	Single Phase	0,3%	
50th	0,001	0,017	Single Phase	0,08%	

	1 age 60 61 65	rtoport rto or	00004.00
	NRS 097-2-1:2017		
Clause	Requirement – Test	Result – Remark	Verdict

4.1.10	TABLE: Harmonics and wa	aveform distortion		Р	
Inter-harm	onics				
Model: Sol	lis-1P1K-4G				
Frequency [Hz]	Current Magnitude (A)	% of Fundamental	Phase	Harmonic Current Limits (%)	
75	0,005	0,097	Single Phase	0,1%	
125	0,001	0,026	Single Phase	0,1%	
175	0,001	0,027	Single Phase	0,1%	
225	0,001	0,028	Single Phase	0,1%	
275	0,001	0,027	Single Phase	0,1%	
325	0,001	0,026	Single Phase	0,1%	
375	0,001	0,025	Single Phase	0,1%	
425	0,001	0,030	Single Phase	0,1%	
475	0,001	0,025	Single Phase	0,1%	
525	0,001	0,025	Single Phase	0,1%	
575	0,001	0,028	Single Phase	0,25%	
625	0,001	0,028	Single Phase	0,25%	
675	0,001	0,030	Single Phase	0,25%	
725	0,001	0,029	Single Phase	0,25%	
775	0,001	0,028	Single Phase	0,25%	
825	0,001	0,029	Single Phase	0,25%	
875	0,001	0,031	Single Phase	0,19%	
925	0,002	0,033	Single Phase	0,19%	
975	0,002	0,035	Single Phase	0,19%	
1025	0,002	0,033	Single Phase	0,19%	
1075	0,002	0,034	Single Phase	0,19%	
1125	0,002	0,035	Single Phase	0,19%	
1175	0,002	0,037	Single Phase	0,08%	
1225	0,002			0,08%	
1275	0,002	0,042	Single Phase	0,08%	
1325	0,002	0,040	Single Phase	0,08%	
1375	0,002	0,042	Single Phase	0,08%	
1425	0,003	0,054	Single Phase	0,08%	
1475	0,002	0,045	Single Phase	0,08%	
1525	0,002	0,046	Single Phase	0,08%	
1575	0,002			0,08%	
1625	0,002	0,046	Single Phase	0,08%	

		Page 59 of 99	Rep	oort No.: 6108594.50	
		NRS 097-2-1:2017			
Clause	Requirement – Test		Result – Remar	k Verdict	
1675	0,002	0,049	Single Phase	0,08%	
1725	0,003	0,057	Single Phase	0,08%	
1775	0,001	0,001 0,028		0,03%	
1825	5 0,001 0,02		Single Phase	0,03%	
1875	0,001	0,028	Single Phase	0,03%	
1925	0,001	0,029	Single Phase	0,03%	
1975	0,001	0,028	Single Phase	0,03%	

Note:

The tests were performed on model Solis-1P4.6K-4G and Solis-1P1K-4G are also applicable for all other models stated in this report.

Page 60 of 99

Report No.: 6108594.50

		1 490 00 01 00	Troport Hon on	0000 1100
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.1.11	TABLE: Power factor						Р			
Model	Solis	s-1P4.6K-	4G							_
Output Po	wer	20 ± 5	30 ± 5	40 ± 5	50 ± 5	60 ± 5	70 ± 5	80 ± 5	90 ± 5	100 ± 5
Vrms (V)		230,1	230,2	230,2	230,3	230,4	230,4	230,5	230,6	230,7
Arms (A)		3,997	6,021	8,041	10,042	12,048	14,038	16,028	18,010	19,987
Active Pov (kW)	wer	0,917	1,383	1,849	2,312	2,773	3,233	3,693	4,151	4,609
Reactive Power (kV	ar)	0,069	0,076	0,084	0,091	0,099	0,107	0,115	0,124	0,134
Apparent Power (kV	(A)	0,920	1,386	1,851	2,314	2,775	3,235	3,695	4,153	4,611
PF Limit		>0,98	>0,98	>0,98	>0,98	>0,98	>0,98	>0,98	>0,98	>0,98
Power Fac	ctor	0,997	0,998	0,999	0,999	0,999	0,999	0,999	0,999	0,999

Note:

For static power converter embedded generators and synchronous embedded generators of sub-categories A1 and A2, the power factor shall remain above 0,98 as shown in Figure 1. For static power converter embedded generators and synchronous embedded generators of sub-category A3, the power factor shall remain above 0,95 as shown in Figure 2.

In line with the current Renewable Power Plant Grid Code, embedded generators smaller than 1000 kVA connected to low-voltage form part of Category A generators, with the following subcategories:

a) Category A1: 0 – 13,8 kVA;

This sub-category includes RPPs of Category A with rated power in the range from 0 to 13,8 kVA, inclusive of 13,8 kVA.

b) Category A2: 13,8 kVA - 100 kVA; and

This sub-category includes RPPs of Category A with rated power in the range greater than 13,8 kVA but less than 100 kVA.

c) Category A3: 100 kVA - 1 MVA.

This sub-category includes RPPs of Category A with rated power in the range from 100 kVA but less than 1 MVA.

	Page 61 of 99 Report No.: 6108594.50					
		NRS 097-2-1:2017				
Clause	Requirement – Test		Result – Remark	Verdict		

4.1.11	ТАВ	BLE: Power factor								
Model	Model Solis-1P1K-4G							_		
Output Po	wer	20 ± 5	30 ± 5	40 ± 5	50 ± 5	60 ± 5	70 ± 5	80 ± 5	90 ± 5	100 ± 5
Vrms (V)		230,0	230,0	230,0	230,0	230,0	230,0	230,0	230,1	230,1
Arms (A)		0,981	1,396	1,763	2,194	2,614	3,077	3,496	3,917	4,389
Active Pov (kW)	wer	0,221	0,318	0,403	0,503	0,599	0,706	0,803	0,900	1,008
Apparent Power (kV	(A)	0,225	0,321	0,406	0,505	0,601	0,708	0,804	0,901	1,010
PF Limit		>0,90	>0,90	>0,90	>0,90	>0,90	>0,90	>0,90	>0,90	>0,90
Power Fac	ctor	0,980	0,990	0,994	0,996	0,997	0,998	0,998	0,999	0,999

Note:

For static power converter embedded generators and synchronous embedded generators of subcategories A1 and A2, the power factor shall remain above 0,98 as shown in Figure 1. For static power converter embedded generators and synchronous embedded generators of sub-category A3, the power factor shall remain above 0,95 as shown in Figure 2.

In line with the current Renewable Power Plant Grid Code, embedded generators smaller than 1000 kVA connected to low-voltage form part of Category A generators, with the following subcategories:

a) Category A1: 0 - 13,8 kVA;

This sub-category includes RPPs of Category A with rated power in the range from 0 to 13,8 kVA, inclusive of 13,8 kVA.

b) Category A2: 13,8 kVA - 100 kVA; and

This sub-category includes RPPs of Category A with rated power in the range greater than 13,8 kVA but less than 100 kVA.

c) Category A3: 100 kVA - 1 MVA.

This sub-category includes RPPs of Category A with rated power in the range from 100 kVA but less than 1 MVA.

The tests were performed on model Solis-1P4.6K-4G and Solis-1P1K-4G are also applicable for all other models stated in this report.

Page 62 of 99 Report No.: 6108594.50

		report item or	Report Hon or cook nee		
		NRS 097-2-1:2017			
Clause	Requirement – Test		Result – Remark	Verdict	

4.2.2.	2 TABL	E: Disconne	ction switchi	ing unit -	fault cor	ndition te	sts	Р
No.	componer No.	fault	test voltage [V]	test time	fuse No.	fuse current [A]	Test result	
1.	Relay K1	Pin 1 and pin 2 short circuit before start	MAINS: 230V; PV: 500V	10mim			The EUT can't start up, I indicate RelayChk-FAIL, can recover after remov fault, no damage, no haz	EUT ing the
2.	Relay K2	Pin 1 and pin 2 short circuit before start	MAINS: 230V; PV: 500V	10mim			The EUT can't start up, I indicate RelayChk-FAIL, can recover after remov fault, no damage, no haz	EUT ing the
3.	Relay K3	Pin 1 and pin 2 short circuit before start	MAINS: 230V; PV: 500V	10mim			The EUT can't start up, I indicate RelayChk-FAIL, can recover after remov fault, no damage, no haz	EUT ing the
4.	Relay K4	Pin 1 and pin 2 short circuit before start	MAINS: 230V; PV: 500V	10mim			The EUT can't start up, I indicate RelayChk-FAIL, can recover after remov fault, no damage, no haz	EUT ing the
5.	AC Voltage measurement disabled R54	e circuit	MAINS: 230V; PV: 500V	10mim			The EUT can't start up, I indicate UN-G-V01, EUT recover after removing t no damage, no hazard.	can
6.	AC Voltage measurement disabled R54	e circuit	MAINS: 230V; PV: 500V	10mim			The EUT can't start up, I indicate UN-G-V01, EUT recover after removing t no damage, no hazard.	can
7.	DC Voltage measurement disabled R52	e circuit	MAINS: 230V; PV: 500V	10mim			The EUT run normally. E recover after removing t no damage, no hazard.	
8.	DC Voltage measurement disabled R52	e circuit	MAINS: 230V; PV: 500V	10mim			The EUT can't start up, I LCD indicate waiting, EU recover after removing t no damage, no hazard.	JT can
9.	DC BUS Voltage measurement disabled R65		MAINS: 230V; PV: 500V	10mim			The EUT run normally. E recover after removing t no damage, no hazard.	

Page 63 of 99 Report No.: 6108594.50

				raye o			кероп по с	7100001100
	T			NRS 097	-2-1:2017			
Claus	se Require	ement – Te	st				Result – Remark	Verdict
10.	DC BUS Voltage measureme nt disabled, R65	Open circuit	MAINS: 230V; PV: 500V	10mim			The EUT can't start up indicate Grid-INTF, EU recover after removing no damage, no hazard	JT can g the fault,
11.	Frequency Measureme nt disabled, R54	Open circuit	MAINS: 230V; PV: 500V	10mim		1	The EUT can't start up indicate UN-G-F01, E recover after removing no damage, no hazard	UT can g the fault,
12.	Frequency Measureme nt disabled, R54	Short circuit	MAINS: 230V; PV: 500V	10mim		-	The EUT can't start up indicate UN-G-F01, E recover after removing no damage, no hazard	UT can g the fault,
13.	DC Current sensor defect, C6	Short circuit	MAINS: 230V; PV: 500V	10mim			The EUT shutdown ar disconnected from grid immediately, LCD indistribution in INTF. EUT can recove removing the fault, no no hazard.	d icate DC- er after
14.	Leakage Sensor defect, R38	Short circuit	MAINS: 230V; PV: 500V	10mim			The EUT shutdown ar disconnected from grid immediately, LCD indipersent PR; EUT can recover removing the fault, no no hazard.	d icate ILeak- after
15.	Leakage Sensor defect, R37	Short circuit	MAINS: 230V; PV: 500V	10mim			The EUT shutdown ar disconnected from grid immediately, LCD indipersion PR; EUT can recover removing the fault, no no hazard.	d icate ILeak- after
16.	Leakage Sensor defect, C47	Short circuit	MAINS: 230V; PV: 500V	10mim		1	The EUT shutdown ar disconnected from grid immediately, LCD indipersion PR; EUT can recover removing the fault, no no hazard.	d icate ILeak- after
17.	Main DSP loss of control, R5	Open circuit	MAINS: 230V; PV: 500V	10mim			The EUT shutdown ar disconnected from grid immediately, all data states LCD, EUT can recove removing the fault, no no hazard.	d show "0" in r after
18.	Slave DSP loss of control, R222	Open circuit	MAINS: 230V; PV: 500V	10mim			The EUT shutdown ar disconnected from gri immediately, LCD indi B-FAULT. EUT can re removing the fault, no no hazard.	d icate DSP- cover after

					Page 64	4 of 99		Report No.: 6	108594.50
					NRS 097	-2-1:2017			
Clau	Clause Requirement – Test Result – Remark Verdict								
19.	ion Micr	nmunicat ocontroll efect, 1	Open circuit	MAINS: 230V; PV: 500V	10mim			The EUT shutdown and disconnected from grid immediately, all data s LCD, EUT can recover removing the fault, no no hazard.	now "0" in after
Note The	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1								

report.

Page 65 of 99 Report No.: 6108594.50

	1 ago 55 51 55			0000 1100
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.2.2.3.2 TABI	E: Overvoltag	e and und	dervoltag	е				Р
Model: Solis-1P	4.6K-4G						<u> </u>	
Test conditions:			(wer: 4603 W ncy: 50 Hz			
			First	t Level	10y. 00 1 1 <u>2</u>			
		Under Vo	Itage		Over Voltage			
Parameter	Voltage		Time		Voltage	Time		
Limit	195,5V		4.0		253,0V		40	
Trip value (V)	195,2V	1	<= 10s		255,2V		<= 40s	
Disconnection time (s)	200V to 190V	8,02	8,04	8,02	248V to 258V	38,03	38,0	38,0
Reconnection time (s)	min. 60s		69,0		min. 60s		70,8	
			Secor	nd Level				
Under Voltage						Over Vol	tage	
Parameter	Voltage		Time		Voltage		Time	
Limit	115,0V		. 0.2.5		264,5V	4- 20		
Trip value (V)	114,5V		<= 0,2 s		264,7V	<= 2s		
Disconnection time (s)	230V to 110V	0,144	0,143	0,143	230V to 270V	0,152	0,153	0,154
Reconnection time (s)	min. 60s		78,0		min. 60s		72,6	
			Third	d Level				
		Under Vo	Itage			Over Vol	tage	
Parameter					Voltage		Time	
Limit		_			276,0V		- 160ma	
Trip value (V)					276,7V		<= 160ms	
Disconnection time (s)					230V to 280V	0,154	0,153	0,153
Reconnection time (s)					min. 60s		74,0	

Note:

The accuracy for voltage trip values shall be within 0 % to +1 % of the nominal voltage from the upper boundary trip setting, and within -1% to 0% of the nominal voltage from the lower boundary trip setting.

Controllable generators may reconnect immediately after the 60 s delay confirming recovery of the system voltage and frequency at a maximum rate of 10 % of rated power per minute, i.e. full power output will only be reached after 10 minutes.

The tests were performed on model Solis-1P4.6K-4G are also applicable for all other models stated in this report.

Page 66 of 99 Report No.: 6108594.50

	. age ee a. ee			
	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	




保存到文件 = [lvrt_23

回调菜单

Page 67 of 99 Report No.: 6108594.50

		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict






Page 68 of 99 Report No.: 6108594.50

 $\overline{\Delta Y(1)}$:

+8.00000A

按下

		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict



保存到文件 = [lvrt_27

回调菜单


Page 69 of 99 Report No.: 6108594.50

 $\Delta Y(1)$:

+8.00000A

按下

		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict




保存到文件 = [l vr t_25] 保存菜单

回调菜单

Page 70 of 99 Report No.: 6108594.50

按下

	1 ago 70 01 00	rtoport rton or	0000 1100	
	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	



保存菜单

回调菜单

Page 71 of 99 Report No.: 6108594.50

		. age e. ee	rtoport rton on	0000 1100
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.2.2.3.3 TABLE: Overfrequency and underfrequency										
Model: Soli	Model: Solis-1P4.6K-4G									
Test conditions		Output power: 4609 W Frequency: 50 Hz								
		Under free	quency			Over freq	uency			
Parameter	Frequency Time Frequency Time				Time					
Output Voltage		90%U _N	U _N	110%U _N		90%U _N	U _N	110%U _N		
Limit (ms)	47,00Hz		200 52,00Hz		52,00Hz	4000+500)		
Trip value (Hz)		47,0	47,0	47,0		52,00	52,00	52,00		
Disconnecti on time (ms)	48,00Hz to 47,00Hz	146,4	158,0	160,0	51,50Hz to 52,50Hz	4250	4300	4230		
Reconnecti on time (s)	min. 60s		72,9		min. 60s		72,4			

Note:


When the utility frequency is less than 47 Hz, the embedded generator shall disconnect from the utility network within 0,2 s. When the utility frequency is more than 52 Hz for longer than 4 seconds, the embedded generator shall cease to energise the utility line within 0,5 s.

Controllable generators may reconnect immediately after the 60 s delay confirming recovery of the system voltage and frequency at a maximum rate of 10 % of rated power per minute, i.e. full power output will only be reached after 10 minutes.

The tests were performed on model Solis-1P4.6K-4G are also applicable for all other models stated in this report.


Page 72 of 99 Report No.: 6108594.50

	: age : = c: cc	. topoit iton or		
	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	



Page 73 of 99 Report No.: 6108594.50

	1 ago 7 o o. o o	Troport Tron. o T	0000 1100	
	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	



Report No.: 6108594.50

		: age : : 5: 55	. topon in on	
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.2.2.3.3 TAI	BLE: Power	curtailment o	during over-f	requency			Р	
•							•	
Test:	Test:							
1-min mean value	a) 50,00 Hz	b) 50,60 Hz	c) 51,25 Hz	d) 51,75 Hz	e) 51,25 Hz	f) 50,60 Hz	g) 50,00 Hz	
1. Measuremen	nt a) to g): Ac	tive power ou	tput > 80% P	Emax				
Frequency [Hz]:	50,00	50,60	51,25	51,75	51,25	50,60	50,00	
P _{setpoint} [kW]:	N/A	4,405	2,773	1,664	2,773	4,215	N/A	
P _E 60 [kW]:	4,637	4,447	2,949	1,793	2,948	4,447	4,645	
$\Delta P_{E60}/P_{Setpoint}$ [%]:	N/A	0,95	6,34	7,75	6,31	5,50	N/A	
2. Measuremen	nt a) to g): Ac	tive power ou	tput 40% and	60% after fr	eezing > 80%	P _{Emax}		
Frequency [Hz]:	50	50,6	51,25	51,75	51,25	50,6	50	
P _{setpoint} [kW]:	N/A	2,209	1,453	0,872	1,453	2,209	N/A	
P _E 60 [kW]:	2,325	2,229	1,479	0,906	1,481	2,232	2,325	
$\Delta P_{E60}/P_{Setpoint}$ [%]:	N/A	0,92	1,78	3,91	1,92	1,05	N/A	
Limit ΔP _{E60} /P _{Setpoint} :			+	10 % of P _{Em}	ax			

Note:

The EG system shall control the output power as a function of PM at a gradient of 50 % per Hertz as illustrated in figure 5. The power generation shall follow the curve shown in figure 5 up and down while the system frequency is in the range 50,5 Hz to 52 Hz.

The tests were performed on model Solis-1P4.6K-4G are also applicable for all other models stated in this report.




Figure 5 — Power curtailment during over-frequency

		1 490 10 01 00	Troport Troil or	0000 1100
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.2.2.4 TABLE: Prevention of islanding (In accordance	e with IEC 62116)	Р
Test circuit and parameters		-
Parameter	Symbol	Units
EUT DC Input		
DC voltage	V _{DC}	V
DC Current	IDC	A
DC Power	P _{DC}	W
EUT AC ouput	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \
AC voltage AC current	V _{EUT}	V A
Real power	I _{EUT} P _{EUT}	Ŵ
Reactive power	QEUT	VAr
Test Load	SEO1	7711
Resistive load current	I_R	Α
Inductive load current	IL.	Α
Capacitive load current	Ic	Α
AC (utility) power source		
Utility real power	P _{AC}	W
Utility reactive power	Q _{AC}	VAr
Utility current Block diagram test circuit IEC 62116.	IAC	A
DC power source (PV) PDC EUT VEUT VEUT VEUT VEUT VEUT VEUT VEUT V	S1 PAC QAC AC pow source (utility)	
	IEC	2 1567/08
Figure 1 - Test circuit for islanding detection fund	ction in a power condit	tioner (inverter

Page 76 of 99 Report No.: 6108594.50

		1 490 10 01 00	Troport Troil or	0000 1100
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.2.2	' A		ntion of island with IEC 6211		condition	A (EUT οι	ıtput = 10	0%)	Р
Mode	Model: Solis-1P4.6K-4G								
Di	isconnection	n limit				2,0 s			
No	P _{EUT} ^{a)} (% of EUT rating)	Reactiv load (% of Q _L ir 6.1.d) 1	(% of nominal)	Q _{ac} c) (% of nominal)	Run on Time (ms)	P _{EUT} (kW)	Actual Q _f	V _{DC} ^{d)}	Remarks ^{e)}
1	100	100	0	0	279	4,60	1,00	400	Test A at BL
2	100	100	- 5	- 5	201	4,60	0,97	400	Test A at IB
3	100	100	- 5	0	225	4,60	0,98	400	Test A at IB
4	100	100	- 5	+ 5	266	4,60	1,01	400	Test A at IB
5	100	100	0	- 5	222	4,60	0,97	400	Test A at IB
6	100	100	0	+ 5	182	4,60	1,02	400	Test A at IB
7	100	100	+ 5	- 5	154	4,60	0,99	400	Test A at IB
8	100	100	+ 5	0	180	4,60	1,02	400	Test A at IB
9	100	100	+ 5	+ 5	125	4,60	1,03	400	Test A at IB

Note:

a) PEUT: EUT output power

^{b)} Pac: Active power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

 $^{^{\}rm c)}$ $Q_{\rm ac}$: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

 $^{^{}d)}$ For test condition A, > 75 % of rated input voltage range used, for test condition B, 50 % of rated input voltage range, ± 10 % used, for test condition C, < 20 % of rated input voltage range used. Based on EUT rated input operating range. For example, if range is between X volts and Y volts, 75 % of range = X + 0,75 × (Y - X). Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the EUT should not be operated outside of its allowable input voltage range.

e) BL: Balance condition, IB: Imbalance condition.

		1 ago 11 01 00	rtoport rto or	0000 1.00
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.2.2	TABLE: Prevention of islanding In accordance with IEC 62116, For test condition B (EUT output = 50 % – 66 %)								
Mod	Model: Solis-1P4.6K-4G								
D	isconnection	limit				2,0 s			
No	P _{EUT} a) (% of EUT rating)	Reactive load (% of Q _L in 6.1.d) 1)	(% of	Q _{ac} c) (% of nominal)	Run on Time (ms)	P _{EUT} (kW)	Actual Q _f	V _{DC} d)	Remarks e)
1	66	66	0	- 5	171	3,03	0,96	300	Test B at IB
2	66	66	0	- 4	271	3,03	0,97	300	Test B at IB
3	66	66	0	- 3	280	3,03	0,98	300	Test B at IB
4	66	66	0	- 2	257	3,03	0,98	300	Test B at IB
5	66	66	0	- 1	282	3,03	0,99	300	Test B at IB
6	66	66	0	0	280	3,03	1,00	300	Test B at BL
7	66	66	0	+ 1	264	3,03	1,01	300	Test B at IB
8	66	66	0	+ 2	181	3,03	1,02	300	Test B at IB
9	66	66	0	+ 3	178	3,03	1,02	300	Test B at IB
10	66	66	0	+ 4	176	3,03	1,03	300	Test B at IB
11	66	66	0	+ 5	157	3,03	1,04	300	Test B at IB

Note:

a) PEUT: EUT output power

b) Pac: Active power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

^{c)} Q_{ac}: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

 $^{^{}d)}$ For test condition A, > 75 % of rated input voltage range used, for test condition B, 50 % of rated input voltage range, ±10 % used, for test condition C, < 20 % of rated input voltage range used. Based on EUT rated input operating range. For example, if range is between X volts and Y volts, 75 % of range = X + 0,75 × (Y - X). Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the EUT should not be operated outside of its allowable input voltage range.

e) BL: Balance condition, IB: Imbalance condition.

			. topon ton on	000000
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict

4.2.2	' Δ Ι		tion of island with IEC 6211	•	condition	C (EUT ou	ıtput = 25	5 % – 33	5 %) P
Mod	el: Solis-1I	P4.6K-4G							
D	isconnectio	n limit				2,0 s			
No	P _{EUT} ^{a)} (% of EUT rating)	Reactive load (% of Q _L in 6.1.d) 1	(% of	Q _{ac} c) (% of nominal)	Run on Time (ms)	P _{EUT} (kW)	Actual Q _f	V _{DC} d)	Remarks ^{e)}
1	33	33	0	- 5	183	1,52	0,96	160	Test C at IB
2	33	33	0	- 4	204	1,52	0,97	160	Test C at IB
3	33	33	0	- 3	232	1,52	0,98	160	Test C at IB
4	33	33	0	- 2	295	1,52	0,98	160	Test C at IB
5	33	33	0	- 1	213	1,52	0,99	160	Test C at IB
6	33	33	0	0	202	1,52	1,00	160	Test C at BL
7	33	33	0	+ 1	178	1,52	1,01	160	Test C at IB
8	33	33	0	+ 2	192	1,52	1,02	160	Test C at IB
9	33	33	0	+ 3	182	1,52	1,03	160	Test C at IB
10	33	33	0	+ 4	182	1,52	1,04	160	Test C at IB
11	33	33	0	+ 5	174	1,52	1,05	160	Test C at IB

Note:

The tests were performed on model Solis-1P4.6K-4G are also applicable for all other models stated in this report.

a) PEUT: EUT output power

b) Pac: Active power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.


 $^{^{\}rm c)}$ $Q_{\rm ac}$: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.


 $^{^{}d)}$ For test condition A, > 75 % of rated input voltage range used, for test condition B, 50 % of rated input voltage range, ±10 % used, for test condition C, < 20 % of rated input voltage range used. Based on EUT rated input operating range. For example, if range is between X volts and Y volts, 75 % of range = X + 0,75 × (Y - X). Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the EUT should not be operated outside of its allowable input voltage range.

e) BL: Balance condition, IB: Imbalance condition.

Page 79 of 99 Report No.: 6108594.50


	: «ge : e e: ee	. topoit iton or		
	NRS 097-2-1:2017			
Clause	Requirement – Test	Result – Remark	Verdict	





Page 80 of 99 Report No.: 6108594.50

		1 490 00 01 00	Troport Troil or	0000 1100
		NRS 097-2-1:2017		
Clause	Requirement – Test		Result – Remark	Verdict



Appendix 1: Specification of the relay

AZSR131 _

35 AMP MINIATURE POWER RELAY

FEATURES:

- Dielectric strength 4500Vrms
- 35 Amp switching
- Contact gap: 1.8mm/2.3 mm available
- Clearance / creepage > 6.4 / 7.5mm
- UL CUR file: E469841
- TUV Pending
- CQC Pending



CONTACTS

Arrangement	SPST (1 Form A)				
	Resistive load:				
H-12/2002	Max. switched power: 9695VA				
Ratings	Max. switched current: 35A				
	Max. switched voltage: 277VAC				
Rated Load	26A at 277 VAC, resistive, 85°C, 50k cycles				
UL	31A at 277 VAC, resistive, 85°C, 30k cycles				
	35A at 277 VAC, resistive, 85°C, 30k cycles				
TUV	26A at 277 VAC, resistive, 85°C, 50k cycles				
	31A at 277 VAC, cos phi 0.8, 85°C, 30k cycles *				
	35A at 277 VAC, cos phi 0.8, 85°C, 30k cycles *				
	* duty factor: 0.1 seconds on / 10 seconds off				
Material	Silver tin oxide				
Resistance	< 100 mΩ initially				
Resistance	(at 6V, 1A, voltage drop method)				

Coil

Power	0.000
At pickup Voltage	790 mw (typical)
Max. Continuous	2.0 W at 20°C(68°F) ambient
Dissipation	0.0
Temperature Rise	70°C Max. at Rated voltage,35A,85°C
Temperature	Max. 155°C(311°F) class F

Notes

ľ	1.All values at 20°C(68°F)
2270	2.Relay may pull in with less than "Must Operate" value
3	3 Specifications subject to change without notice

GENERAL DATA

Life Expectancy: Mechanical	Minimum operations 100,000 cycles Min. (2.3mm gap) 300,000 cycles Min. (1.8mm gap)
Electrical	30k cycles @35A 277VAC Res. 30k cycles @35A 277VAC cos phi 0.8
Operate Time(typical)	20 ms Max. at nominal coil voltage
Release Time(typical)	10 ms Max. at nominal coil voltage (with no coil suppression)
Dielectric Strength (at sea level for 1min.)	4500 Vrms(coil to contacts) 3500 Vrms(between open contacts)
Surge Voltage	10KV @1.2/50µs (coil to contacts)
Insulation Resistance	1,000MΩ min. at 20°C 500VDC 50% RF
Holding voltage	Greater than 35% of nominal coil voltage
Dropout	Greater than 5% of nominal coil voltage
Ambient Temperature Operating Storage	At rated coil voltage -40°C(-40F) to 85°C(140°F) -40°C(-40F) to 105°C(221°F)
Vibration	1.5mm DA at 10-55 Hz,
Shock	20g
Enclosure	P.B.T, Polyester
Terminals	Tinned copper alloy, P.C.
Max. Solder Temp.	270°C(518°F)
Max. solder time	5 seconds
Weight	25g

ZETTLER RELAY (XIAMEN) CO., LTD.

www.zettlercn.com

East of 3/F, Yinfeng Building No. 48-50 Huli Road Huli District, Xiamen Tel:(0592)6151211 Fax: (0592)6151221

Page 82 of 99 Report No.: 6108594.50


AZSR131 ___

Relay ordering data

	C	OIL SPECIFICA	ATIONS		
Nominal Coil VDC	Must Operate VDC	Min holding VDC	Max. Continuous VDC	Coil Resistance Ω±10%	ORDER NUMBER
5	3.75	1.75	6	18	AZSR131-1AE-5D
9	6.75	3.15	10.8	58	AZSR131-1AE-9D
12	9	4.2	14.4	103	AZSR131-1AE-12D
18	13.5	6.3	21.6	230	AZSR131-1AE-18D
24	18	8.4	28.8	410	AZSR131-1AE-24D
48	36	16.8	57.6	1650	AZSR131-1AE-48D

Add suffix "GW" after "D" for glow wire version. Add suffix " (200) " for 2.3mm gap version. All values at 20° C

Mechanical data



Tolerance: ±0.3mm

ZETTLER RELAY (XIAMEN) CO., LTD. www.zettlercn.com


East of 3/F, Yinfeng Building No. 48-50 Huli Road Huli District, Xiamen Tel:(0592)6151211 Fax: (0592)6151221

Appendix 2: Photo documentation

Enclosure - Front View




Enclosure - Rear View



Enclosure - Left Side View



Enclosure - Right Side View



Enclosure – Bottom View (Dual Channel MPPT Input)



Enclosure - Bottom View (Single Channel MPPT Input)



Enclosure – Top View



Heat-sink Internal View



Internal View of Open Top Cover




Internal View of Open Top Cover



Main Board - Component Side




Main Board - Solder Side



Main Board - Component Side




Main Board - Solder Side



Control Board - Component Side




Control Board - Solder Side



LCD Board - Component Side



LCD Board - Solder Side



Page 92 of 99 Report No.: 6108594.50

Appendix 3: EMC Report of Conducted Emission in the frequency band 30 kHz to 150 kHz



Test Report

Product Name : PV Grid-Tied Inverter

Model No. : Solis-1P4.6K-4G

IEC 61000-2-2:2002+A1:2017+A2:2018 Applicable Standard

(Clause 4.12.3:30KHz-150KHz)

Test Result : PASS

: 20C0120R-V2 Report No.

Applicant : Ginlong Technologies Co., Ltd.

No.57 Jintong Road, Binhai Industrial Park, Xiangshan, Ningbo, Address

Zhejiang, PEOPLE'S REPUBLIC OF CHINA

Test Laboratory : DEKRA Testing and Certification (Suzhou) Co., Ltd.

Address : No.99 Hongye Rd., Suzhou Industrial Park, Suzhou,215006, Jiangsu,China

Tel / Fax : 0512-6251-5088 / 0512-6251-5098

Hui Yu Documented By

(Project Assistant: Hui Yu)

Reviewed By

(Supervisor: Star Wang)

Approved By

(Manager: Jerry Pan)

Note: The test results relate only to the samples tested.

Report No.: 6108594.50



Report No.: 20C0120R-V2

1. Overview of results

EMISSION TESTS		.,,	10
Requirement – Test case	Basic standard(s)	Verdict	Remark
Conducted disturbance voltage at AC mains power port	IEC 61000-2-2	PASS	

Report No.: 6108594.50


Report No.: 20C0120R-V2



2. Conducted Emission

2.1. Test Result

Engineer: Yves	
Site: AC1	Time: 2020/12/01
Limit: IEC61000-2-2-CE-Mains(30KHz-150KHz)	Margin: 0
Probe: NNLK 8129(0.009-30MHz)	Polarity: Line
EUT: PV Grid-Tied Inverter	Power: Input :400V DC, Output : 230Vac,50Hz
Note: PV Mode	



No	Mark	Frequency (MHz)	Measure Level (dBuV)	Reading Level (dBuV)	Over Limit (dB)	Limit (dBuV)	Probe (dB)	Cable (dB)	Amp (dB)	Туре
1	*	0.030	112.736	112.348	-0.264	113.000	0.359	0.029	0.000	QP
2		0.046	57.860	57.764	-52.610	110.469	0.067	0.029	0.000	QP
3		0.060	95.441	95.358	-8.013	103.453	0.054	0.029	0.000	QP
4		0.090	79.013	78.945	-23.222	102.235	0.039	0.029	0.000	QP
5		0.120	55,425	55.361	-45.939	101.364	0.035	0.029	0.000	QP
6		0.149	44.658	44.597	-56.061	100.720	0.033	0.029	0.000	QP

Note:

- 1. " * ", means this data is the worst emission level.
- 2. Measurement Level = Reading Level + Factor(Probe+Cable-Amp).



Engineer: Yves			
Site: AC1	Time: 2020/12/01		
Limit: IEC61000-2-2-CE-Mains(30KHz-150KHz)	Margin: 0		
Probe: NNLK 8129(0.009-30MHz)	Polarity: Neutral		
EUT: PV Grid-Tied Inverter	Power: Input :400V DC, Output : 230Vac,50Hz		
Note: PV Mode	*		

130 80 Level(dBuV) 70 60 50 40 30 20 10 0 -10 -20 0.1 0.15 Frequency(MHz)

No	Mark	Frequency (MHz)	Measure Level (dBuV)	Reading Level (dBuV)	Over Limit (dB)	Limit (dBuV)	Probe (dB)	Cable (dB)	Amp (dB)	Туре
1	*	0.030	112.880	112.496	-0.120	113.000	0.355	0.029	0.000	QP
2		0.044	54.802	54.703	-56.013	110.815	0.071	0.029	0.000	QP
3		0.060	94.670	94.587	-8.783	103.453	0.055	0.029	0.000	QP
4		0.090	79.763	79.694	-22.478	102.241	0.040	0.029	0.000	QP
5		0.120	55.042	54.978	-46.338	101.380	0.035	0.029	0.000	QP
6		0.150	44.467	44.405	-56.246	100.713	0.033	0.029	0.000	QP

Note:

- 1. " * ", means this data is the worst emission level.
- 2. Measurement Level = Reading Level + Factor(Probe+Cable-Amp).


Report No.: 6108594.50



Report No.: 20C0120R-V2

Test Photograph

Description: Conducted Emission Test Setup



Report No.: 6108594.50



3. Test and measure equipment list

Report No.: 20C0120R-V2

Conducted disturbance voltage (AC mains port)

Instrument	Manufacturer	Model No.	Serial No.	Cali. Due Date
EMI Test Receiver	R&S	ESCI	100906	2021.04.17
Artificial Mains Network	SCHWARZBECK	NNLK 8129	8129-282	2021.04.16
Coaxial Cable	Huber+Suhner	RG 223	TR1-C1	2021.08.26
Temperature/Humidity Meter	RTS	RTS-8S	AC1-TH	2021.08.18

Report No.: 20C0120R-V2



4. EUT PHOTOS



EUT PHOTOS (2)



Page 7 of 8

Report No.: 20C0120R-V2







Page 8 of 8

-----END-----